TECHNICAL REPORT

FEASIBILITY STUDY & DESIGN FOR AN END-OF-CATCHMENT WETLAND TREATMENT SYSTEM – ELLEN BROOK

> STAGE 2 REPORT – TECHNICAL & ENVIRONMENTAL PRE-FEASIBILITY

> > **FINAL REPORT**

MARCH 2012

FOR DEPARTMENT OF ENVIRONMENT AND CONSERVATION ON BEHALF OF THE SWAN RIVER TRUST



Perth 12 Monger Street PerthWA, Australia 6000 t +61[0]8 9227 9355 f +61[0]9 9227 5033

Melbourne

2/26-36 High Street Northcote VICAustralia 3070 t +61[0]3 9481 6288 f +61[0]3 9481 6299

ABN : 39 092 638 410

www.syrinx.net.au

SYRINX ENVIRONMENTAL PL REPORT NO. RPT-1012-002 V5

LIMITATIONS OF REPORT

Syrinx Environmental PL has prepared this report as an environmental consultant provider. No other warranty, expressed or implied, is made as to the professional advice included in this report. This report has not been prepared for the use, perusal or otherwise, by parties other than the Client, the Owner and their nominated consulting advisors without the consent of the Owner. No further information can be added without the consent of the Owner, nor does the report contain sufficient information for purposes of other parties or for other uses. The information contained in this report has been prepared in good faith, and accuracy of data at date of issue has been compiled to the best of our knowledge. However, Syrinx Environmental PL is not responsible for changes in conditions that may affect or alter information contained in this report before, during or after the date of issue.

Syrinx Environmental PL accepts site conditions as an indeterminable factor, creating variations that can never be fully defined by investigation. Measurements and values obtained from sampling and testing are indicative within a limited time frame and unless otherwise specified, should not be accepted as actual realities of conditions on site beyond that timeframe.

| Version No. | Date | Author | Reviewer | Comment |
|-------------|----------|--------|----------|-------------------------------------|
| 1 | 24.01.12 | EB/EO | LP | Preliminary draft issue for comment |
| 2 | 07.02.12 | EB/EO | KM/LP | Preliminary draft issue for comment |
| 3 | 13/02/12 | EB/EO | | Draft issue for comment |
| 4 | 28/02/12 | EB | | Final issue |
| 5 | 12/03/12 | EB | | Final issue |
| | | | | |

REPORT DETAILS:

© 2012 Syrinx Environmental PL

Except as provided by the Copyright Act 1968, no part of this document may be reproduced, stored in a retrieval system or transmitted in any form or by any means without the prior written permission of Syrinx Environmental PL. Enquiries should be directed to the Corporate Intellectual Property Officer.

TABLE OF CONTENTS

| EXECU | EXECUTIVE SUMMARY | | | | |
|--------|------------------------------------|----|--|--|--|
| PART 1 | PART 1 INTRODUCTION | | | | |
| 1.0 | INTRODUCTION | 11 | | | |
| 1.1 | PROJECT BACKGROUND | 11 | | | |
| 1.2 | PROJECT OBJECTIVES | 13 | | | |
| 1.3 | PURPOSE OF THIS DOCUMENT | 14 | | | |
| PART 2 | PILOT TRIAL OUTCOMES | 15 | | | |
| 2.0 | OVERVIEW | 15 | | | |
| 3.0 | PILOT TRIAL 1 (PTV1) | 15 | | | |
| 3.1 | SYSTEM DESCRIPTION | 15 | | | |
| 3.2 | OUTCOMES | 16 | | | |
| 4.0 | PILOT TRIAL 2 (PTV2) | 16 | | | |
| 4.1 | PASSIVE SYSTEM | 16 | | | |
| 4.1.1 | System Description | 16 | | | |
| 4.1.2 | Physical Outcomes | 17 | | | |
| 4.1.3 | Chemical Outcomes | 19 | | | |
| 4.1.4 | Discussion of Passive System Trial | 25 | | | |
| 4.2 | ACTIVE SYSTEM | 28 | | | |
| 4.2.1 | System Description | 28 | | | |
| 4.2.2 | Physical Outcomes | 29 | | | |
| 4.2.3 | Chemical Outcomes | 30 | | | |

| 4.2.4 | Discussion | | | | | | |
|---|--|----|--|--|--|--|--|
| PART 3 END-OF-CATCHMENT TREATMENT SYSTEM PRE-FEASIBILITY ASSESSMENT 3 | | | | | | | |
| 5.0 | PURPOSE OF PRE-FEASIBILITY ASSESSMENT | | | | | | |
| 6.0 | ISSUES & UNCERTAINTIES | | | | | | |
| 6.1 | POTENTIAL ISSUES & RISKS | | | | | | |
| 7.0 | IMPLICATIONS FOR DESIGN OF AN END-OF-CATCHMENT TREATMENT SYSTEM | | | | | | |
| 7.1 | KEY RECOMMENDATIONS | 40 | | | | | |
| PART 4 | CONCEPT DESIGN | 41 | | | | | |
| 8.0 | END-OF-CATCHMENT WETLAND TREATMENT SYSTEM | 41 | | | | | |
| 8.1 | DESIGN CRITERIA | 42 | | | | | |
| 8.2 | SYSTEM DESCRIPTION 4 | | | | | | |
| 8.2.1 | Riffles | 43 | | | | | |
| 8.2.2 | Ephemeral Pools | 43 | | | | | |
| 8.2.3 | Surface Flow Wetlands | | | | | | |
| 8.3 | INTEGRATION OF NUA BLEND FILTER | | | | | | |
| 8.4 | DOMINANT PROCESSES 46 | | | | | | |
| 8.5 | WATER QUANTITY | 49 | | | | | |
| 8.6 | TREATMENT EFFICIENCY | 49 | | | | | |
| 8.6.1 | Total Suspended Solids | 49 | | | | | |
| 8.6.2 | Nutrients | 50 | | | | | |
| 8.7 | OTHER NUTRIENT MANAGEMENT MEASURES 5 | | | | | | |
| REFERE | ENCES | 54 | | | | | |
| 9.0 | BIBLIOGRAPHY | 54 | | | | | |

FIGURES57APPENDICES89LIST OF TABLES7able 1 PTV2 passive system flow, hydraulic conductivity and contact time for 40% and

| 25% NUA blends | 19 |
|--|----|
| Table 2 PTV2 Active system contact time for active system 1 (AS1) and active system 2 | |
| (AS2) | 30 |
| Table 3 NUA issues matrix | 35 |
| Table 4 Site 1 and Site 2 pool surface area and volume | 44 |
| Table 5 Site 1 and Site 2 wetlands surface area and volume | 45 |
| Table 6 Best practice river restoration and end-of-catchment treatment system dominant | |
| processes | 47 |
| Table 7 Total phosphorus removal rates for passive NUA blend filter and end-of- | |
| catchment wetland | 51 |
| Table 8 Total nitrogen removal rates for passive NUA blend filter and end-of-catchment | |
| wetland | 51 |
| Table 9 Alternative commercially available amendments dominant processes | 52 |

LIST OF FIGURES (COMPILED AT END OF DOCUMENT)

| Figure 1 PTV1 & PTV2 SITE LOCATION | 58 |
|--|----|
| Figure 2 PTV2 PASSIVE SYSTEM DRAWINGS | 59 |
| Figure 3 PTV2 PASSIVE SYSTEM FLOW RATE AND HYDRAULIC CONDUCTIVITY | 60 |
| Figure 4 MAJOR ION TRENDS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 61 |
| Figure 5 Ca & SO4 TRENDS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 62 |
| Figure 6 MAJOR ION CHEMISTRY OF SELECTED PASSIVE SYSTEM EFLUENT SAMPLES TAKEN FROM THE BEGINNING, MIDDLE & END OF THE TRIAL | 63 |
| Figure 7 SULFIDE TRENDS IN ALL PASSIVE AND ACTIVE SYSTEM EFFLUENT SAMPLES | 64 |
| Figure 8 pH, EC & DO TRENDS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 65 |
| Figure 9 NUTRIENT CONCENTRATION FROM ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 66 |
| Figure 10 DOMINANT RELATIONSHIPS IMPACTING THE NUTRIENT CONCENTRATIONS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 67 |
| Figure 11 TREND OF KEY NITROGEN SPECIES IN ALL PASSIVE SYSTEM EFFLULENT SAMPLES | 68 |

| Figure 12 TRENDS OF KEY PHOSPHORUS SPECIES IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 69 |
|--|----|
| Figure 13 CONCENTRATIONS OF METALS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 70 |
| Figure 14 CONCENTRATION TRENDS OF KEY METALS IN ALL PASSIVE SYSTEM EFFLUENT SAMPLES | 71 |
| Figure 15 KEY METAL TRENDS IN EFFLUENT WATER SAMPLES FROM PS3OUT and AS1OUT | 72 |
| Figure 16 PTVS ACTIVE SYSTEM DRAWINGS | 73 |
| Figure 17 PTVS ACTIVE SYSTEM FLOW RATES AND HYDRAULIC CONDUCTIVITY FOR AS1OUT AND AS2OUT | 74 |
| Figure 18 MAJOR ION TRENDS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 75 |
| Figure 19 Ca & SO4 TRENDS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 76 |
| Figure 20 MAJOR ION CHEMISTRY OF SELECTED ACTIVE SYSTEM EFFLUENT SAMPLES TAKEN FROM THE BEGINNING, MIDDLE AND END OF TRIAL | 77 |
| Figure 21 pH, EC & DO TRENDS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES AND ELLEN BROOK WATER | 78 |
| Figure 22 NUTRIENT CONCENTRATIONS FROM ALL ACTIVE EFFLUENT SAMPLES AND ELLEN BROOK WATER | 79 |
| Figure 23 DOMINANT RELATIONSHIPS IMPACTING NUTRIENT CONCENTRATIONS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 80 |
| Figure 24 TRENDS OF KEY NITROGEN SPECIES IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 81 |
| Figure 25 CONCENTRATIONS OF METALS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 82 |
| Figure 26 CONCENTRATION TRENDS OF KEY METALS IN ALL ACTIVE SYSTEM EFFLUENT SAMPLES | 83 |
| Figure 27 SITE LOCATION – SITE 1 & 2 | 84 |
| Figure 28 BEST PRACTICE RIVER RESTORATION CONCEPTUAL ARRANGEMENT – SITE 1 | 85 |
| Figure 29 BEST PRACTICE RIVER RESTORATION CONCEPTUAL ARRANGEMENT – SITE 2 | 86 |
| Figure 30 BEST PRACTICE RIVER RESTORATION TYPICAL SECTION A-A | 87 |
| Figure 31 19 th PERCENTILE FLOWS DIVERTED (SHOWN FOR YEAR 1997) | 88 |

LIST OF APPENDICES

APPENDIX 1 SUMMARY STATISTICS OF KEY ANALYTES FOR EACH TRIAL STATION 90

| APPENDIX 2 CORRELATION CO-EFFICIENTS OF KEY ANALYTES IN EFFLUENT | |
|---|-----|
| SAMPLES | 102 |
| APPENDIX 3 ELEMENTAL COMPOSITION OF SELECTED SAMPLES FROM PASSIVE | |
| SYSTEM TRIALS | 104 |
| APPENDIX 4 SELECTED XRD SAMPLES FROM THE PASSIVE SYSTEM | 106 |
| APPENDIX 5 REVISED DESIGN CRITERIA | 110 |

EXECUTIVE SUMMARY

Syrinx Environmental PL (Syrinx) was engaged in July 2010 by the Department of Environment and Conservation (DEC) on behalf of the Swan River Trust (Trust) to determine the overall feasibility of installing an end-of-catchment treatment system at two sites within Ellen Brook. Both sites are located to the immediate north of West Swan Road Bridge in Belhus, upstream of the confluence with the Swan River.

Swan Canning Water Quality Improvement Plan

The purpose of the end-of-catchment treatment system is to provide nutrient load reductions prior to Ellen Brook discharging to the Swan River. The Swan Canning Water Quality Improvement Plan (SCWQIP) (Swan River Trust, 2009) identifies the Ellen Brook catchment as a key catchment of concern, whereby load reductions of 69% total nitrogen (TN) and 79% total phosphorus (TP) are required to reduce the annual nutrient discharge to the maximum acceptable levels. Modelling of a number of management measures within the Ellen Brook catchment has identified that no individual or combinations of management actions are able to achieve these TN or TP reduction targets (Department of Water, 2010). Additional or alternative management actions are therefore required.

Use of NUA as a nutrient and DOC removal media

Recent advances by the CSIRO into the use of mining by-products as environmental amendments has highlighted the potential to use neutralised used acid (NUA), either singularly or in combination with other amendments (NUA blend), as a nutrient and dissolved organic carbon (DOC) removal media. Preliminary column and turf farm field trials undertaken by CSIRO showed that NUA demonstrated high phosphorus retention capacity and good performance in terms of DOC and nutrient removal from influent water. Two subsequent pilot trials have since been undertaken, PTV1 (in 2010) and PTV2 (in 2011). Both trials utilised NUA blends as a filtration media in active, upward flow column-based "pump and treat" configurations. PTV2 also trialled passive vertical flow configurations.

Feasibility review and alternative scope

The original intention of the Syrinx Stage 2 document was to provide an overall feasibility assessment and conceptual designs incorporating the use of NUA blends within an end-of-catchment arrangement. Whilst all laboratory and pilot scale trials to date have shown that the NUA blend presents a promising nutrient removal media, albeit nutrient removal efficiencies were lower than expected in the pilot trial applications, there are still a number of issues and uncertainties which require resolution prior to the establishment of the overall

feasibility for an end-of-catchment system for Ellen Brook. As a result, an alternative scope for Stage 2 was required to provide a pre-feasibility review. The purpose of this document is to therefore deliver the alternative scope and assess the <u>technical and environmental pre-feasibility</u> of an end-of-catchment treatment system within Ellen Brook utilising NUA blends as a focus, but also recommending other potential amendments that may be suitable for use in this context.

Key issues and uncertainties

Part 2 of this document provides a review of pilot trial (PTV1 and PTV2) outcomes and provides discussion of key issues. Part 3 provides a synthesis of key potential issues (technical/engineering and environmental) and uncertainties from all trials (laboratory, field and pilot) which still need to be addressed. Listed below are potential <u>key issues</u> and uncertainties identified as potentially compromising the effectiveness of an end-of-catchment wetland containing NUA or NUA blends. The following issues/uncertainties require further investigation:

Effects of Low Hydraulic Conductivity of Media

- The hydraulic conductivity of the NUA blend was well below that required to manage the expected flows and ensure optimal contact time.
- Clogging issues (and associated effects on Fe, Mn, Al, Ca and Si chemistry) will need to be carefully addressed in the overall design of any system.

Release of Contaminants

- Initial release (first flush) of major ions, nutrients and metals. This issue would need to be well controlled/managed in the context of an end-of-catchment treatment wetland and/or the development of well understood contingencies associated with direct release into a receiving environment.
- The passive and active systems in PTV2 behaved differently (hydro-dynamically and hydrogeochemically). There needs to be a more thorough understanding of why this is so, especially in the context of achieving steady state conditions, and the implications for long term metals release (especially Mn and Fe) and breakthrough of other elements.

Effects of High pH on Filter and Receiving Environment

The pH levels of NUA blend effluent containing MgO is too high to support plant growth in the filter and therefore having a vegetated biofilter in order to improve the hydraulic properties of the system is not feasible. As such, interventions are required to reduce pH, most likely being the removal of MgO from the blend. Removal of MgO may mean that vegetating the system becomes feasible, subject to further investigation. Note the resultant 'amended blend' would need to be re-investigated to ensure it does not cause other issues.

- The pH levels of NUA blend effluent (including MgO) will impact on the receiving wetland during low flow periods, but are unlikely to have major impacts during high flow as a result of the dilution effect. Further investigations are needed to determine if this is an issue, and identify whether a dedicated polishing basin with an acid dosing facility is required.
- The pH is also a dominant control on metals stability. There needs to be a more thorough understanding pertaining to pH changes (over different time scales) and metals solubility in the context of environmental issues associated with a wetland catchment system or downstream receptor.
- The Sulfide (allied to Ca ion) content of the NUA blend effluent water is high, which can have implications for sulfide generation within the filter and downstream depending on pH and redox status. Therefore, a sulfide management plan may be required.

Uncertainties Due to Limitations of Trial

- The duration of the investigation did not appear long enough to fully observe issues associated with the interaction of metals and mineralisation processes, in particular there were significant differences in trial investigation periods between the passive and the active systems. This makes the comparison of data between the two systems difficult, and potentially misleading as investigation outcomes. Aligned trial times would be necessary to make meaningful commentary on the effectiveness of the systems relative to each other.
- The investigations did not provide an understanding of how the chemistry of the NUA blend filters will respond under seasonally variable conditions (e.g. wetting and drying cycles).
- The investigations did not provide an understanding of the NUA blend replacement requirements/replacement frequency (i.e. cessation of effective nutrient removal).

The above suite of technical and environmental issues need to be viewed in the context of environmental, economic and social risks and a balance needs to be sought based on agreed and appropriate nutrient removal efficiency for the Ellen Brook end-of-catchment treatment system.

Key recommendations

In response to the above issues, key recommendations that should be considered in future stages of the project include:

Effects of low hydraulic conductivity

- Extend duration of current and future pilot trials (and lab trials where applicable) to assess changes in hydraulic conductivity over time. Investigations should be carried out over a minimum duration of 12 months.
- Characterise typical/major causes of clogging (i.e. surface clogging, interstitial clogging, blend composition etc).
- Investigate potential methods to alleviate clogging issues (i.e. mechanical intervention, mechanical mixing, vegetation, pelletisation, fines screening, lower portions of NUA material).

Note that any changes to the NUA blend composition and configuration will require recharacterisation and re-assessment of nutrient and DOC removal efficiencies as well as potential issues.

Effects of High pH on Filter and Receiving Environment

- Resolve issues with hydraulic conductivity in the first instance. If high pH still remains as an issue the following could be undertaken:
 - Omit MgO from NUA blend; and/or
 - Implement additional treatment steps (i.e. HCI dosing) targeted at pH reduction.

Release of Contaminants

- Investigate potential management measures for the first flush issues, such as pretreatment of NUA media.
- Re-characterise NUA blend and identify issues associated preferred arrangement (i.e. post resolution of hydraulic conductivity). Identify whether additional treatment steps or management measures are required within the treatment train (e.g. HCI dosing, humate pre-treatment for DOC).
- Establish trials to assess impacts of long term release of Mn, Fe and potentially Al which may impede on the overall effectiveness of an NUA blend utilised in a treatment train arrangement.

Other recommendations

 Review ANZECC guidelines and identify areas where site specific trigger values may be more appropriate in the context of an end-of-catchment wetland treatment train.

Ellen Brook end-of-catchment wetland

As part of the overall intent for this project, an end-of-catchment wetland is to be incorporated into the overall solution for improving the quality of Ellen Brook water and improving the biodiversity and landscape values of this part of the catchment. Part 4 of this document provides concept designs for an end-of-catchment wetland at the two sites in Belhus. The concept design has been configured in such a way that allows retrofitting at a later date with an amendment (NUA blend or other) filter component.

It is acknowledged that wetlands alone will provide limited nutrient removal function due to the large size of the Ellen Brook catchment (716.4 km²), and the significant annual flows relative to the available wetland treatment area, hence why options for incorporating amendments or other engineering measures are also necessary.

The concepts utilise best practice river restoration principles and incorporate sequences of pools and riffles that would naturally occur along Ellen Brook. Wetlands provide an effluent polishing function for the amendment (i.e. NUA blend) filter to ensure that water is of acceptable quality prior to discharge to Ellen Brook and to provide opportunistic dissolved organic nitrogen removal. A number of other commercially available amendments may also be useful for application in place of, or combination with, the NUA blend filter, such as Phoslock (filterable reactive phosphorus reduction), Zeolite (ammonia and ammonium adsorption) and ViroBond (heavy metal adsorption).

Whilst the concepts can be applied to other sites along Ellen Brook to provide additional water quality improvements and importantly improved habitat and amenity values, it is important to recognise that an end-of-catchment approach should form part of a suite of management actions implemented throughout the Ellen Brook catchment. This will address catchment wide nutrient management issues rather than solely relying on an end-of-catchment solution. Other management actions may include: riparian revegetation, perennial pastures, fertiliser efficiency, land use change controls, fertiliser action plans and soil amendments.

PART 1 INTRODUCTION

1.0 INTRODUCTION

1.1 PROJECT BACKGROUND

Syrinx Environmental PL (Syrinx) was engaged in July 2010 by the Department of Environment and Conservation (DEC) on behalf of the Swan River Trust (Trust) to determine the overall feasibility of installing an end-of-catchment treatment system at two sites within Ellen Brook. Both sites are located to the immediate north of West Swan Bridge Road in Belhus, upstream of the confluence with the Swan River.

The purpose of the end-of-catchment treatment system is to provide nutrient load reductions prior to Ellen Brook discharging to the Swan River. Syrinx was engaged to complete two stages of work. Stage 1 draft report was issued in January 2011 and included: literature and data review; site opportunities and constraints identification; and the development of three conceptual end-of-catchment treatment system designs. Inherent in the reviews and conceptual development was the use of a mining by-product, neutralised used acid (NUA) blended with other amendments, to provide a majority of the nutrient and dissolved organic carbon (DOC) removal function. Due to insufficient data available to draw accurate conclusions on the feasibility of utilising NUA blends within an end-of-catchment arrangement, this document provides an alternative to the original Stage 2 scope of works. The purpose and methodology of this alternative scope is outlined in section 1.3.

Project History

The Swan Canning Water Quality Improvement Plan (SCWQIP), released in December 2009, provides a roadmap for reducing nitrogen and phosphorus nutrient levels within the Swan Canning Catchment through Stream Quality Affecting Rivers and Estuaries (SQUARE) modelling and decision support tools. The SCWQIP identifies Ellen Brook, a 716.4 km² catchment, as a key catchment of concern. While Ellen Brook discharges only 14% (26,750 ML for the period 1997 to 2006) of the total flow from the Swan Canning coastal catchments, it is the greatest nutrient contributor of these catchments to the Swan Canning river system. To give some idea of the severity of the quality issues, modelling indicates that Ellen Brook delivers 71.4 tonnes (28%) of total nitrogen (TN) and 10.04 tonnes (39%) of total phosphorus (TP) to the Swan Canning river system. The SCWQIP identifies that load reductions of 69% TN and 79% TP are required to reduce the annual nutrient discharge to the maximum acceptable levels. SQUARE modelling for a number of management actions has since been undertaken. The modelling has identified that no individual or combinations

of management actions are able to achieve the TN or TP reduction targets as required by the SCWQIP (DoW, 2010; Kelsey *et al*, 2010). Additional or alternative management actions are therefore required.

CSIRO Research

Recent advances by the CSIRO into the use of mining by-products as environmental amendments has highlighted the potential to use NUA, either singularly or in combination with other amendments, as a nutrient and DOC removal media. Extensive research has been undertaken by CSIRO characterising the NUA material and testing of NUA blends in field and pilot scale applications (Wendling *et al*, 2009a; Wendling *et al*, 2009b; Wendling *et al*, 2009c; Wendling *et al*, 2010; Douglas *et al*, 2008; Douglas *et al*, 2011). These trials identified that there was a significant opportunity to use an NUA-based filtration system to remove dissolved phosphorus, DOC and dissolved organic nitrogen (DON) from Ellen Brook waters prior to the confluence with the Swan River. Stage 1 report provides a review of NUA related CSIRO reports completed up to the year 2010.

Syrinx Stage 1 Outcomes

As part of Stage 1 scope Syrinx reviewed the CSIRO research, distilling key uncertainties relevant to the application of the NUA media to Ellen Brook. Briefly, uncertainties extended to: contaminant breakthrough; release of contaminants; increase in salinity; sulfide generation; and toxicological impacts. It was acknowledged that some of these uncertainties could potentially be addressed in the design of the treatment system.

In order to encapsulate potential design implications, a series of design criteria and responding design approaches were developed to inform the development of conceptual designs. Also informing the concepts were the site opportunities and constraints. The resulting concepts identify three potential approaches all of which utilised NUA blend media and wetlands to provide water quality improvement functions. Concept 1 utilised the NUA blend and wetlands in a passive (gravity) configuration, Concept 2 presented an active (pumping) configuration and Concept 3 presented a combined passive/active configuration.

Peer Review

The outcomes of the Syrinx Stage 1 review, and in particular uncertainties and concerns raised by Syrinx regarding the use of the NUA as a treatment media, were peer reviewed by Mike Grace (Director and Associate Professor at Water Studies Centre & School of Chemistry, Monash University, Victoria) who was commissioned by the Trust to provide independent advice. In short, the reviewer concluded that, while notwithstanding the major benefits of NUA as an amendment (primarily in terms of P and DOC removal), there are several issues associated with the use of NUA which may, to a different degree, cause various environmental and/or operational problems. In line with the Stage 1 findings, the

reviewer noted that the major potential concerns for use of NUA amended soils include: the increase in EC/salinity, breakthrough of DOC and ammonia, potential 'whole of effluent' toxicity, pH and operational considerations (wetting/drying). The reviewer also suggested that further testing and modelling of the NUA (or NUA blend) should be undertaken to advance and refine understanding of the performance and behaviour of this amendment, particularly in regards to potential P and N breakthrough, effluent ecotoxicology, and structural changes caused by the operational variations such as wetting and drying.

Pilot Trials

Since completion of Stage 1, two pilot trials have been undertaken and completed. Details of these trials are covered in later sections. The first pilot trial (PTV1) was focussed on a column-based, "pump and treat" filter which could inform potential intervention structures implemented at Ellen Brook. The arrangement of PTV1 included a 12 m long column packed with a mixture of NUA, HIsmelt (HS), calcined magnesia (MgO) and coarse river sand. It was intended that this pipe was placed in a vertical position, however, due to site limitations and technical difficulties an inclination of only 15° was achieved. This resulted in significant slumping and limited interaction between the NUA blend and the Ellen Brook influent. As a consequence, only partial removal of nutrients and DOC occurred. This has emphasised that a range of practical design, operational and maintenance issues must be addressed in order to successfully implement an NUA blend end-of-catchment filtration device.

Upon conclusion of PTV1 it was identified that there was insufficient data to inform the completion of the Stage 2 feasibility study. As a result, a second field scale pilot trial (PTV2) was undertaken to address data gaps present in PTV1 and trial a passive system. The outcomes of PTV2 are discussed within this document in the context of identifying key issues and uncertainties and assessing the feasibility and strategic arrangement of an end-of-catchment treatment system. Generally, results from PTV2 are also inconclusive and determination of a preferred arrangement for an end-of-catchment treatment system cannot be progressed beyond the schematic/conceptual design stage until further investigations are undertaken. Recommendations for these investigations are provided in section 7.1.

1.2 **PROJECT OBJECTIVES**

The overall objective of this project is to ascertain the feasibility of an end-of-catchment treatment system for Ellen Brook.

Broad aims for the end-of-catchment treatment system encompass environmental, social and economic aspects. These aims were first identified in the Stage 1 Syrinx report and are listed below.

- Maximise water quality improvements within lower Ellen Brook and the Swan Canning river system;
- Minimise flood threat to infrastructure and existing land uses (agricultural and residential);
- Protection and enhancement of environmental values including environmental flows, hydrological cycles, biodiversity, ecosystems and habitats;
- Protection and enhancement of cultural and spiritual values: community education, community involvement, European heritage and Aboriginal heritage; and
- Maximise economic efficiency.

1.3 PURPOSE OF THIS DOCUMENT

The purpose of this document is to deliver the alternative <u>Stage 2</u> scope and assess the <u>technical and environmental pre-feasibility</u> of an end-of-catchment treatment system for Ellen Brook. The main objectives of this document are:

- 1. Provide a clear and concise background into the project works completed to date.
- 2. Review field data in the context of an end-of-catchment solution, identifying key issues and uncertainties and their associated implications.
- 3. To recommend appropriate courses of actions for future project direction.

In addition, in order to allow progression of the wetland component of the treatment system, the latter part of this document includes a concept design for an end-of-catchment wetland which can be retrofitted at a later date with a filter component. Associated objectives include:

- 4. Assess feasibility of utilising an NUA blend within a best practice end-ofcatchment treatment system for Ellen Brook.
- 5. Provide high level review of alternative management measures and amendments used in combination with or in lieu of an end-of-catchment NUA filter.

PART 2 PILOT TRIAL OUTCOMES

2.0 OVERVIEW

CSIRO have undertaken extensive laboratory assessment of NUA and NUA blends (Wendling *et al*, 2009a; Wendling *et al*, 2009b; Wendling *et al*, 2009c; Wendling *et al*, 2010; Douglas *et al*, 2008; Douglas *et al*, 2011) which provided a significant insight into the benefits, as well as challenges of using this by-product as a treatment media.

Since late 2010 two pilot trials utilising NUA blends (PTV1 and PTV2) have been undertaken. PTV1 was a joint collaboration between CSIRO and the Trust and was run between 9 September and 3 November 2010. PTV2 was a collaboration between the Trust (implementation and monitoring), Syrinx (conceptual and detailed design), ChemCentre (sample analysis and reporting), CSIRO (NUA blend specifications) and Iluka Resources (supply of NUA material). PTV2 ran between 19 September and 25 November 2011.

The pilot trials were intended to be an intermediate step between the laboratory scale and the full scale implementation. PTV1 outcomes are discussed by Douglas *et al* (2011) and summarised in section 3.0 below. PTV2 outcomes are reviewed in this document (section 4.0) in addition to documents developed by ChemCentre (2012) and CSIRO (Wendling, 2011).

Both PTV1 and PTV2 trials were located in Bullsbrook within Department of Defence owned land leased to livestock graziers (Douglas et al., 2011). Figure 1 (compiled at end of document) shows the site location. Water for both trials was sourced from a fenced off constructed wetland on Bingham Road Creek, a tributary of Ellen Brook.

3.0 PILOT TRIAL 1 (PTV1)

3.1 SYSTEM DESCRIPTION

PTV1 comprised of an upward flow column filter utilising a 12 m long by 0.6 m diameter HDPE pipe placed at a 15° angle. The column was filled with 5 m³ of NUA blend, comprising of NUA (20%), HISmelt (20%), MgO (10%) and washed river sand (50%). Flow rates varied between 0 and 50,000 L/day.

3.2 OUTCOMES

Bromide tracer tests identified that slumping and subsequent formation of preferential flow paths had occurred in the column. This reduced the interaction and contact time between the influent water and NUA blend and as a consequence only partial removal of nutrients and DOC occurred when compared with CSIRO laboratory studies.

For example, CSIRO laboratory studies demonstrated very high and long lasting P retention capacity of NUA material resulting in >99% reduction in PO4-P and TP concentrations in influent waters (Wendling *et al*, 2010). In contrast, in PTV1 percentage of PO₄-P removal was much lower and importantly it rapidly declined over time (initial removal rate was 46% (5,000 L/day) declining to <1% at day 22 (50,000 L/day)).

Similarly, while NUA was shown to have good retention capacity for DOC and nitrogen in the laboratory study, only marginal removal for TN and DOC was achieved in PTV1 (~10% removal for TN and 10- 20% for DOC at (<20,000 L/day) and less than 10% at higher flows).

Like PTV2 (see section below for details), high levels of pH and EC were observed in the PTV1 effluent; the influent pH varied from 6.5 to 7.5 and the effluent pH attained a maximum value of 9.5 to 10, which was considered too high for discharge to aquatic receptors.

4.0 PILOT TRIAL 2 (PTV2)

Two arrangements were trialled in PTV2, including a passive system utilising a gravity fed vertical flow filter and an active system utilising an upward flow column filter. A brief description of each arrangement is provided below. ChemCentre (2012) have developed a comprehensive document outlining the PTV2 system description, sampling methodology and sample analysis. This document should be referred to for any further information.

4.1 PASSIVE SYSTEM

4.1.1 System Description

PTV2 trialled four vertical flow <u>passive systems</u> (PS1, PS2, PS3 and PS4). Figure 2 shows the configuration for all passive systems, comprising of a 1.2 m high by 1.83 m wide fibreglass tank filled, from bottom to top, with blue metal aggregate (150 mm), coarse river sand (100 mm) and NUA blend (400 mm). The key difference in the systems was variations in the NUA blend, whereby two replicates of each blend were trialled, including:

 PS1 and PS2: NUA (25%), coarse river sand (60%), granular activated carbon (10%) and calcined magnesia (5%). PS3 and PS4: NUA (40%), coarse river sand (45%), granular activated carbon (10%) and calcined magnesia (5%).

Water pumped from Bingham Wetland was equally distributed to each tank via slotted distribution pipes. The emergency outlet pipe maintained a 500 mm depth head across the NUA blend surface, allowing vertical flow of influent water (NFSIN) through the NUA blend. The treated water was collected via slotted subsoil drainage pipes located within the aggregate at the base of the tank.

Monitoring for physical, chemical and physiochemical parameters was undertaken by the Trust, with samples collected from the outlet point at each tank typically every two to five days from the 19th September to 25th November 2011 (69 days).

4.1.2 Physical Outcomes

Flow rates

Flow rate data provided by the Trust showed rapid flow rate decline from all passive systems throughout PTV2 trial period. Figure 3 shows that an initial flow rate above 1000 L/hr was sustained for the first three days of the trial. By day nine, outflows were reduced to just below 500 L/hr in PS2, PS3 and PS4, while flows in PS1 were reduced to 818 L/hr. Flow reduction continued rapidly in all passive systems until day 15 to approximately 200 L/hr, representing a flow reduction of 80% in 15 days of operation. After 50 days (7 weeks) of operation flows were reduced by more than 90% of the original rate, with a minimum flow rate of 10 L/hr observed. Flow rates and reduction patterns within this period appeared consistent across all NUA blends, except when mechanically disturbed.

In an attempt to re-establish original flow rates, PS1 and PS3 were mechanically disturbed to allow the creation of preferential flow paths. On days 53, 60 and 69 PS1 and PS3 were probed approximately 250 times on each occurrence with a 15 mm steel bar to create preferential flow paths. PS2 and PS4 remained unchanged.

Following the first mechanical intervention, flows rapidly recovered to near initial conditions (947 L/hr) in PS1 (25% NUA) and to approximately 50% of initial conditions (486 L/hr) in PS3 (40% NUA). The re-establishment of flows was short-lived and within a week flows were reduced to 62 L/hr and 108 L/hr in PS1 and PS3 respectively. The second mechanical intervention resulted in higher flows being achieved, but again flow recoveries were short-lived (four days). The higher initial flow rates may be attributed to preferential flow paths still present from the first intervention. Both interventions highlighted that PS1 had consistently higher flow rates than PS3. Considering that 57% of NUA is composed of particles < 63µm (Wendling, 2009b), this could be attributed to the lower portion of NUA material in PS1.

Insufficient data exists for the third intervention as the site was demobilised immediately following mechanical intervention.

Hydraulic conductivity

Based on the above flow rates, the hydraulic conductivity (k_s) for a range of flow rates experienced during PTV2 were calculated and are shown in Figure 3 on the secondary axis.

Figure 3 highlights that all passive systems had an initial k_s value of ~220 mm/hr, reflecting a sandy loam soil type (Engineers Australia, 2006). This initial k_s value is lower than expected when viewed in light of CSIRO data, which establishes the NUA (unblended) saturated hydraulic conductivity at 324 mm/hr (Wendling, 2009b). As the Stage 1 concepts assume the CSIRO k_s value the sizing of the NUA components within these concepts may no longer be applicable. The data indicates that assessment of hydraulic conductivity of any NUA blend should be undertaken over a longer period (i.e. 12 months at a minimum) to take into account physical and chemical changes in the system.

Nevertheless, the initial k_s shows amenable application to a passive filtration system if retained at a constant rate (i.e. 220 mm/hr). However, maintenance of the k_s at this rate was short-lived (three days) and over the duration of PTV2 the k_s value dropped rapidly over a fortnight to a rate of between 2 to 4 mm/hr, indicating systemic clogging. This latter rate reflects a heavy to medium clay and would not be suitable in a passive filtration application without intervention/s to address clogging issues (see section 4.1.4).

Similar trends of initial rapid decline in k_s have been observed in biofilter bench trials undertaken by the Monash University Facility for Advancing Water Biofiltration (FAWB). FAWB bench trials utilising a sandy loam vertical flow stormwater filter observed a rapid initial decline from an uncompacted rate of 300 mm/hr dropping to ~20 mm/hr. This decline occurred over a period of 4 to 6 months, after which the k_s steadily recovered over a 12 month period to 50 to 100% of the initial k_s value (Lewis *et al*, 2008; Hatt *et al*, 2009). The recovery was attributed to the establishment of vegetation which assisted in the maintenance of the k_s value through the creation of macropores due to root growth and senescence (Lewis *et al*, 2008). Furthermore, a survey of 37 in-situ biofilters situated in Melbourne, Sydney and Brisbane found that many of the biofilters have a k_s below 50 mm/hr, 44% between 50 and 200 mm/hr and 17% above 200 mm/hr (Le Coustumer, 2008). Note that the FAWB guidelines recommend a k_s value of between 100 to 300 mm/hr to ensure maintenance of the hydraulic performance of the system.

Contact time

The contact times within the NUA passive filters (25% NUA blend and 40% NUA blend) were determined using flow and hydraulic conductivity data presented in Figure 3. Table 1 shows

that the design contact time of 1 hour was achieved in both NUA blend configurations at a flow rate of ~400-500 L/hr, however, this flow rate was not maintained throughout the trial period. Overall, contact times were similar for both configurations, with the 25% blend (PS1 and PS2) achieving slightly shorter contact times for a given flow rate. In line with the flow data, an initial contact time of 26 minutes achieved ($k_s = 220$ mm/hr), increasing rapidly over the duration of the trial to >45 hours.

| No. days observed above % | Flow Rate, Q (L/hr) | System Hydraulic Conductivity, k _s (mm/hr) | Contact time 40% NUA blend (hours) | Contact time 25% NUA blend (hours) |
|---------------------------------|------------------------|--|--|--|
| 4.9% | 1028.6 | 221 | 0.46 | 0.42 |
| 12.7% | 1000 | 215 | 0.47 | 0.43 |
| 14.7% | 900 | 193 | 0.52 | 0.48 |
| 16.7% | 800 | 172 | 0.59 | 0.54 |
| 16.7% | 700 | 150 | 0.67 | 0.62 |
| 16.7% | 600 | 129 | 0.79 | 0.72 |
| 17.6% | 500 | 107 | 0.94 | 0.87 |
| 23.5% | 400 | 86 | 1.18 | 1.08 |
| 23.5% | 300 | 64 | 1.57 | 1.44 |
| 29.4% | 200 | 43 | 2.36 | 2.16 |
| 47.1% | 100 | 21 | 4.72 | 4.33 |
| 64.7% | 50 | 11 | 9.45 | 8.66 |
| 82.4% | 20 | 4 | 23.62 | 21.65 |
| 100.0% | 10 | 2 | 47.24 | 43.29 |

| Table 1 | PTV2 | passive | system | flow, | hydraulic | conductivity | and | contact | time | for | 40% |
|---------|-------|---------|--------|-------|-----------|--------------|-----|---------|------|-----|-----|
| and 25% | NUA I | blends | | | | | | | | | |

4.1.3 Chemical Outcomes

This section aims to provide a high-level overview of key components of the major ion, physio-chemical, nutrient and trace metal characteristics of PTV2 passive system, with emphasis on those variables that have been considered potentially problematic in past investigations. The data used in this section included water quality data, solid phase mineralogical data and wet chemistry NUA blend data taken from within cores of the passive system.

A complete analysis of all key analytes has been undertaken by the ChemCentre (2012). Furthermore, CSIRO (Wendling, 2011) have identified the key mechanisms via which nutrient attenuation is expected to be achieved with PTV2.

Major Ions

Assessment of major ion chemistry variability within the passive treatment systems is presented in Figure 4, Figure 5 and Figure 6. Assessment of major ion variability provides insight into the rate and duration via which the treatment system achieves equilibrium with respect to input water (NSFIN) and mineralisation - demineralisation processes within the treatment cell. Given the relatively limited temporal duration of the investigation, it was necessary to make the assumption that when an equilibrium, or steady state occurs, outputs from the treatment system will be dominated by inputs into the treatment system (as opposed to disequilibria reactions within the system). This assumption provides a guide to predictability of effluent quality (i.e. out-flowing water from the treatment cells) that without data obtained from a longer term investigation is necessary.

From Figure 4 (which includes two graphical representations of water chemistry; a Piper Diagram (above) and a Schoeller Diagram (below)) it is apparent that the major ion relationships in effluent water vary significantly over the duration experiment. Concentrations of major ions are present in the effluent water samples due to flushing of the NUA blend filters. Importantly the flushing of major ions is dominant in the initial period of the investigation (the first flush period) which lasts for approximately two weeks. Figure 4 shows that the major constituents of this first flush effluent are Ca and SO₄, with Mg also a less dominant contributor to effluent water chemistry. The extent of this period is seen in Figure 5, which shows concentrations of Ca and SO₄ in the effluent water over the duration of the investigation. Given the presence of gypsum in the NUA blend it is likely that Ca and SO₄ are derived from dissolution of this mineral (or minerals of similar chemistry e.g. bassinite and / or anhydrite). It is probable that Mg is derived from the calcined magnesia.

In alignment with the CSIRO investigations (referred to previously), it appeared that evolution of the NUA filter system was dominated by disequilibrium - equilibrium processes controlled by the initial dissolution of gypsum (which accounts for the high concentrations of Ca and SO_4 in the effluent water). This is highlighted in Figure 6, which shows the major ion constituents of water in samples from the beginning, middle and end of the investigation. In all of the passive system filters it appeared that a steady state occurred over the first month of the investigation, where, either:

- dissolution of gypsum diminishes after the first flush, or
- dissolution of gypsum during the first flush released major ions that sequentially became precipitated as diagenetic minerals elsewhere within the column.

Although understanding the specifics of this diagenetic process is important in understanding the long term fate of key analytes, for this investigation it was sufficient to assume that steady state conditions achieved by the passive systems are important for the attenuation of other analytes of interest in an end-of-catchment wetland design. Given the dominance of sulphate in effluent waters it was important to note that sulfide was present in effluent waters in both the passive and the active systems (Figure 7). Sulfide can potentially form an ecotoxicological (and human health) issue in a gaseous state (as H_2S) and as a mineral where it can help facilitate the formation of acid volatile sulfides (AVS) in anaerobic conditions and acidic environments, which may then impact on other metals. Although AVS minerals are not an issue (per se) they represent a meta-stable mineral that becomes subject to environmental change. As such, sulfide is an important component of the end-of-catchment wetland mineral system, especially as it potentially represents a component of a temporary sink for metals (note release of metals is discussed later in this section) subject to changing seasonal conditions, and in the context of uncertain metals release characteristic of the NUA filters over time.

Physio-chemistry

Figure 8 shows that pH levels in all of the passive systems throughout the experiment were constantly higher than acceptable levels as supported by the ANZECC Freshwater Guidelines (which, although ANZECC guidelines are not being used as management criteria, are a good indicator of acceptable environmental health limits). Elevated pH levels were problematic as pH has significant toxicity related impacts upon aquatic and semi-aquatic biota, and is a major determinant on the speciation of key metals of potential concern.

In all passive system filters pH levels are extremely high (above 10.5 for PS3 and PS4 and above 11 for PS1 and PS2) though they progressively become lower as the passive system filters gradually attained a steady state. In all passive systems filters it appeared that the first flush effect was present and that after approximately two weeks there was a variable, though progressively decreasing trend of pH levels (note this conclusion is supported by a Mann-Kendall Statistic indicating a decreasing trend - Appendix 1). At the cessation of the experiment the pH levels appear (based on observation of the data) to have reached a stable state, with pH for all passive system effluent water ranging between circa 9.7 and 9.95.

From past CSIRO investigations, the use of NUA did not result in exaggerated pH levels in effluent water, whereas the use of calcined magnesia as part of the NUA blend did. It is therefore logical to assume that the calcined magnesia deleteriously impacts upon the effectiveness of the current NUA filter, in the context of the NUA filters forming a part of an end-of-catchment wetland. Even if the pH levels continued to progressively decrease, it would likely take considerable time (based on the decrease in pH in effluent observed during the trial investigation) for the pH of the effluent to stabilise at levels that are acceptable for discharge into aquatic receptors (note this conclusion would require further investigations to quantify).

As identified by previous investigations the relatively high electrical conductivity (EC) in effluent water was also considered potentially problematic in the context of an end-ofcatchment wetland setting. Importantly in the passive system filters (as opposed to the active system filters, see section 4.2) the EC levels (which at the beginning of the experiment range from approximately 2,600 uS/cm to 2,900 uS/cm) appear to parallel Ca and SO₄ concentrations, and after the first flush the effluent EC achieved a steady state. As such, it appeared that the issue with EC was dominant during the first flush, after which it exhibited similar levels to the Ellen Brook water (NFSIN) used. Interestingly, at the cessation of the investigation, there was no apparent difference in the EC of effluent from the passive systems filters with difference in EC at the end of the trial, it was not possible to conclude that the filters with the 25% NUA resulted in lower EC than those with 40% NUA. However, as we consider EC content to parallel gypsum dissolution, it is logical to conclude that lower gypsum content will result in lower EC in effluent water, potentially due to the dynamics of gypsum dissolution during the first flush of the system.

In general, dissolved oxygen (DO) was highly variable within the effluent water and to an extent followed the trend of DO within the Ellen Brook influent (NFSIN) water (although always lower). Given the presence of sulfide in the effluent water it can be assumed that generation of anaerobic conditions in the passive system occurs. However, as there were no clear relationships between sulfide and DO observed in the data there are no ways to use either parameter relative to the other to assess potential impacts on downstream receiving environments.

<u>Nutrients</u>

Nutrients assessed included total phosphorus (TP), soluble reactive phosphorus (PO₄), total nitrogen (TN), organic nitrogen (Org_N), nitrate (NO₃) and ammonia (NH₃). In the Ellen Brook system phosphorus is present due to up-stream agricultural land uses (and other anthropogenic runoff), whilst nitrogen is present (dominantly as dissolved organic nitrogen) due to agricultural land uses in addition to (anecdotally) past wetland draining activities that have resulted in release of organic nitrogen into the system. Both P and N represent potential issues (depending on concentration and speciation) in the context of an end-of-catchment wetland treatment system. Figure 9, Figure 10, Figure 11 and Figure 12 highlight key characteristics and trends exhibited by nutrients throughout the investigation in passive system effluent relative to Ellen Brook water.

Assessment of the effluent water has yielded the following key conclusions:

 Figure 9 shows that there were significant concentrations of nutrients in the Ellen Brook (NFSIN) water and effluent. In general, the Ellen Brook water contained higher concentrations of DOC, TN and N_org, whilst effluent water contained higher concentrations of NO₃ and NH₃ than the Ellen Brook water. Figure 9 shows that the concentrations of TN and Org_N are very similar in most samples, which is supported by statistical analysis that shows a strong correlation between the two variable $(r^2=0.86)$.

- In particular, TP dominantly exhibited a lower concentration in effluent water than Ellen Brook water, whilst the concentrations of TN and Org_N were not universally lower in effluent water relative to Ellen Brook water. This suggests the NUA filters were more effective in attenuating phosphorus than nitrogen, which is subject to speciation changes (in particular the formation of NO₃ and to a lesser degree NH₃).
- Figure 10 and Figure 11 show that there was a very strong relationship between total organic carbon, DOC and N (organic nitrogen) which suggests that most N existed in conjunction with dissolved organic acids naturally present in the Ellen Brook water a conclusion also revealed in Figure 9, where the concentrations of most TN and Org_N in water samples is very similar.
- Although there was a relatively strong correlation between TP and total organic carbon (Appendix 2) it was not clear whether P (which is known to speciate with some organic compounds) occurs solely in conjunction with an organic acid (as per N).
- P attenuation definitely occurred within the passive system (Figure 12), with Fe and AI potentially representing diagenetic sinks within the NUA filters (Figure 10). However, it was not apparent whether phosphorus became integrated into other, potentially more stable mineral species (such as hydroxyapatite), as has been suggested by past investigations (Wendling et al, 2010). Given the stability of trace metals within the filters (including, potentially Fe, Mn and AI that can form surface bound hydroxides) this may represent a long term issue for the attenuation of P, in particular if pH fluctuations result in Fe, Mn and/or AI speciation changes.

Based on the above it appears that the NUA material was effective for the removal of P, though not as effective as CSIRO laboratory trials which demonstrated >99% TP removal (Wendling *et al*, 2010). This may be due to differences in the diagenetic formation of gypsum and like minerals (and may be a result of prolonged contact time), though there is not enough pertinent data to draw more thorough conclusions than this. It was observed in PTV2 that the NUA blend was also less effective for the removal of N. Given the dominant speciation of N in the Ellen Brook system (i.e. dissolved organic form) it is possible that a substrate that targets removal of DOC (such as organic matter containing weak acids such as fulvic and humic acids) may be a more effective mechanism to also remove N from the water (due to the strong relationship between DOC and DON discussed earlier). As the effectiveness of this process will be constrained by the relationship between the type of organic acid and the type of organic substrate it may be worth undertaking further investigations characterising the nature of the organic acids present in the Ellen Brook water.

<u>Metals</u>

As a mining by-product, the NUA blend is characterised by metal contents that are significantly higher than naturally occurring non-mineralised geologic materials (Appendix 3 and 4).

Past investigations (laboratory and PTV1) have recognised that key metals (Ca, Co, Cu, Fe, Mg, Mn and Ni) in effluent samples potentially constitute issues with respect to:

- Ecotoxicological impacts on flora and fauna in wetland environments,
- Ecotoxicological issues on flora and fauna in downstream river / creek environments,

Analysis of PTV2 samples has revealed that other metals were also present as potential metals of concern. The full list assessed in this report includes the following:

- Aluminium (Al)
- Caesium (Cs),
- Chromium, in particular Hexavalent Chromium (Cr VI),
- Cobalt (Co),
- Copper (Cu),
- Iron (Fe),
- Lead (Pb),
- Manganese (Mn),
- Strontium (Sr),
- Uranium (U), and
- Zinc (Zn)

A detailed interpretation of each of the metals will be presented in a separate ChemCentre report (2012). This current section aims to identify those key characteristics, nominally concentrations of metals (Figure 13) and trends of metals in passive system effluent (Figure 14) that are relevant to the overall feasibility of an end-of-catchment wetland system. These identified issues are incorporated in later sections into an issues matrix (Table 3) that is intended to help inform steps required to manage these issues.

Figure 13 highlights the concentrations of all metals that have previously been noted as "of concern". In assessing concentrations in passive system effluent samples relative to Ellen Brook water it appeared that the metals that may pose a concern, and should be better understood in the context of the issues they may pose in an end-of-catchment wetland system, include:

- Co
- Cr VI

- Cu
- Sr
- Mn

The time series plots of these metals along with Fe, AI and U are shown in Figure 14.

In general the metals that attained a steady state in effluent samples included CrVI, AI, Sr and to an extent Fe. As such it will typically be within the first flush effluent (i.e. first two weeks of operation) that these metals may constitute an issue for receiving environments. In general, Fe, Mn and AI may also represent metals that are implicated in clogging processes and further understanding of the biogeochemistry of these metals should be acquired.

Metals which exhibited increasing concentration trends as the investigation continued included: Mn, Co, Cu, Pb and U (note Pb is not included in Figure 14). To ascertain the degree of release of these metals and potential impacts on receiving environments further investigations will be required. In particular understanding the long term fate of Mn (Mn oxides and oxyhydroxides are known as effective scavengers of other trace metals) in seasonally variable conditions (including redox variability as well as exaggerated pH conditions) will be important to address potential metals release characteristics to downstream receiving environments. This is highlighted in Figure 15 which shows the concentrations of Co, Cu, Mn, Pb and U in effluent water samples from PS3 and AS1OUT. It is clear that there was a relationship between Mn and the other metals, suggesting that the Mn (and the minerals that Mn was associated with) had a strong control on the solubility of the other metals.

4.1.4 Discussion of Passive System Trial

This section presents a broad discussion on key generic outcomes of the passive system trial and environmental and technical implications. A more detailed issues matrix, in the context of an end-of-catchment wetland is presented in Table 3 and discussed further in section 6.0.

Environmental implications

Review of PTV2 chemical and physiochemical outcomes identifies that NUA blends constitute a useful amendment for P removal though less efficient for N removal. For an end-of-catchment application a number of issues need to be addressed and further assessed, in particular initial release of *some* ions and high effluent pH. Implications/issues include:

Significant concentration of analytes are present in effluent samples during the <u>first</u> <u>flush</u> (approximately two weeks after trial initiation) and techniques to address appropriate management of these analytes during the first flush will be necessary.

The first flush effluent is dominated by Ca and SO_4 , which also constitutes the high electrical conductivity of the water samples.

- High pH is problematic as it potentially impacts upon the speciation of metals and key minerals, is toxic to a range of flora and fauna and is difficult to biologically neutralise in an end-of-catchment arrangement. To address this issue it will be necessary to either remove the factor that is resulting in the high pH (which is considered to be the calcined magnesia in the NUA blend) or dose the effluent with HCl (or another acid) post its exit from the NUA filters.
- Nutrient removal occurs for both P (for which the passive system appears efficient) and N (for which the passive system appears less efficient). However, effluent water samples in the passive system have higher concentrations of NO₃ and NH₄ than influent (NFSIN) water. Implications of this speciation change may need to be better understood in terms of an end-of-catchment wetland receiving environment (note these higher concentrations are not necessarily a problem for wetland receiving environments, though excess nutrients can lead to enhanced eutrophic conditions).
- <u>Electrical Conductivity</u>, which is predominantly related to Ca and SO₄ ions, is high and may result in excessive stress to flora and fauna of downstream receiving environments. Excessive salts may also form diagenetic mineral crusts in wetlands, and excessive sulphate poses the risk of sulfide formation under anoxic conditions.
- Long term release of Mn (and potentially Fe) via diagenetic reactions impacting on oxides and oxyhydroxides is an issue that will require further investigation. It appears that the Mn (and potentially Fe) minerals present in the NUA blend have an impact upon the release of other metals (notably Co, Cu, Pb and U). Although these metals exhibit relatively low concentrations in the effluent water, and therefore may or may not pose an issue to downstream receiving environments, it is necessary to understand the magnitude of the metals release (which will require a longer investigation time) to appreciate the severity, or otherwise, of any downstream issue. The circumstances under which Mn may pose an ecotoxicological issue will also need to be assessed in the context of the downstream environment (in particular with respect to redox and pH variability). The issue of metals (and other rock forming minerals) forming a clogging problem is dealt with below.

Technical implications

Without mechanical intervention the passive system would, over time, treat only a small portion (i.e. <1%) of total influent for an extended contact time, with the majority of flows (99%) bypassing the system. This has implications on the treatment efficiency, scalability and ongoing management of the system. Furthermore, the prolonged contact time likely alters the chemical evolution of the passive system and potentially the efficiency via which nutrients are attenuated. In order to deliver a system which is scalable to an end-of-

catchment application and provide meaningful P removal, <u>ongoing maintenance of the</u> required hydraulic conductivity is therefore essential.

Rapid declines in the flow rate and hydraulic conductivity indicate systemic <u>clogging</u>. Deductively, the likely cause of clogging is attributed to a combination of surface and interstitial clogging of the NUA blend filter. Clogging within the subsoil drainage system is considered unlikely based on two observations. Firstly, mechanical intervention saw the recovery of the flow rate to initial conditions. Secondly, subsoil pipe flushing did not result in sediment discharge from the subsoil drains or outlet pipes.

<u>Surface clogging</u> is likely to be a result of sediment deposition and TSS accumulation on the NUA blend filter surface. Although TSS concentrations in influent water (NSFIN) was low (~5 mg/L), the high inflow volume of >1000 l/hr equates to a potential TSS load of 120 g/day, or 45 g/m²/day, for each passive system. Note that these values should be used as a preliminary guide as the volume of TSS discharged via the high flow bypass is unknown. Current recommendations for vertical flow sand subsurface flow wetlands suggest a maximum TSS loading of 5 g/m²/day (Kadlec & Wallace, 2009). The NUA column trials conducted by Wendling *et al.* (2009) and Wendling *et al.* (2010) used flows of 0.2mL/min and 1.0mL/min, respectively. These flows are much lower than the ones trialled in this experiment.

Interstitial clogging is likely to result from changes in physical and chemical characteristics of the system. Generally, use of a silty/clay material in a filter arrangement can substantially reduce the hydraulic conductivity of the media via migration of fines into pore spaces and a subsequent decrease in the filters void ratio. FAWB guidelines for biofilters recommend a filter material containing less than 3% (W/W) silt/clay (<50µm). Considering that CSIRO (2012) particle size distribution analysis shows the total percentage of particles below this size is 7% (PS1 and PS2) and 9.5% (PS3 and 4), interstitial clogging could be attributed to the proportion of fines in the blend. Furthermore, biofilm accumulation throughout the filter media and the overall compaction of the media under a hydraulic loading (500 mm head) will result in a drop of the k_s value. It was observed that in all passive systems the filter had compressed by approximately 50 to 100 mm at the conclusion of the trial.

Precipitation of Fe, AI and Mn as oxide and hydroxide minerals may also contribute to interstitial clogging. Throughout PTV2 it was observed that dissolved Fe was consistently reduced from an average of 0.96 mg/L (NFSIN) to ~0.25 mg/L (PS1, PS2, PS3 and PS4). This suggests precipitation of more than 70% (~0.71 mg/L) of the influent (NFSIN) Fe. This is supported by CSIRO (Douglas *et al.* 2008) XRD analysis during the turf trials that shows Fe oxides/hydroxides forming a coating around quartz grains. Considering that low concentrations of Fe (<0.2 mg/L) is known to cause clogging in other water related infrastructure (i.e. scheme, groundwater and irrigation), the potential influent concentration of 0.7 mg/L has the potential to be a contributor to interstitial clogging. Diagenetic alterations

affecting Si, Ca, Fe, Mn and potentially AI may also contribute to mineralisation and precipitation issues within the NUA filter.

<u>Improvements in hydraulic conductivity</u> and prevention of clogging are therefore key in the long term success of the passive system. Several interventions could be applied to deliver improvements:

- Pre-treatment. Removal of fine to coarse sediment from influent water prior to conveyance to passive NUA blend filtration system.
- Decreasing NUA content and increasing coarse sand content. This may reduce P removal efficiencies, require ongoing mechanical intervention and could result in more frequent replacement of NUA blend filter.
- Pelletisation of NUA. Increases the void ratio, however lifespan of pellet form is unknown. Requires additional processing either by Iluka or an alternative party which may be difficult to execute.
- Vegetation with rushes, sedges, shrubs and trees to create macropores. As the vegetation is sensitive to high pH, the MgO material will need to be omitted from the blend. Additional longer term research (>12 months) is required to ascertain plant establishment within an NUA blend media under stabilised hydraulic conditions.
- Regular mechanical intervention occurring fortnightly or monthly.

Resolution of clogging issues and maintenance of an appropriate hydraulic conductivity will likely present a technically feasible NUA blend based arrangement that can be applied to an end-of-catchment treatment system, subject to more detailed hydraulic modelling.

4.2 ACTIVE SYSTEM

4.2.1 System Description

The <u>active system</u> comprised two replicates (AS1 and AS2) of a three column pressurised upward flow filtration system (refer Figure 16 for drawings). The columns were fabricated from HDPE PN16 pipe, with each column measuring 2 m long by 0.5 m internal diameter and placed in an upright vertical position. Blue metal aggregate (10 to 20 mm) was placed within the base of each column to cover the inlet (~200 mm depth) and prevent blockages. A 40% NUA blend consistent with PS3 and PS4 above was packed on top of the aggregate to the height of the column (~1.7 m).

Three columns were paced in series to increase contact time with the NUA blend. The position of the column in the series is named in ascending alphabetical order, AS1A refers to the first column, AS1B the second and AS1C the third. An inlet near the base of each of the first columns (AS1A and AS2A) receives influent water (NFSIN) pumped water from Bingham

Wetland. This water flows in an upward direction through the NUA blend and is discharged via an outlet at the top of the columns, moving under pressure to successive columns via a 50 mm HDPE pipe. A manifold/high flow bypass allowed the isolation of columns should maintenance be required. The pump comprised of a 5.5 kW Regent Pump operating at 45 m of head and 3 L/s volumetric flow.

Monitoring for physical, chemical and physiochemical parameters was undertaken by the Trust, with samples collected from the outlet for each system (AS1 and AS2) typically every two to five days and from the outlets AS1A, AS1B, AS2A and AS2B every seven to ten days. Delays in the system operation meant that the trial ran for a shorter duration than the passive system, commencing on 13th October and operating until 25th November 2011 (45 days).

In order to prevent total suspended solids (TSS) and fines from moving through and discharging from the system, a filter device was placed between the column and each outlet. Originally, the filter comprised a 90 micron geotextile clamped between the flange with the aid of two gaskets. On the 10th November, 28 days after the commencement of the trial, this was changed to metal mesh filters due to blockage issues. The latter comprised a 100 micron mesh sandwiched between supporting coarse mesh. These filters were installed on all AS1 columns and AS2B and AS2C. AS2A had only coarse mesh, then a 50µm inline sock filter.

4.2.2 Physical Outcomes

Flow rates

Based on the concept drawings provided in Figure 16, the design flow rate for the active system was set at 0.16 L/s or 576 L/hr to achieve a contact time of 1 hour. Figure 17 shows the observed flow rates throughout PTV2. The data highlights that the design flow rate was not achieved nor maintained throughout the trial period.

Variable outflows in AS1 were observed, with flows maintained below 50 L/hr in the first week of operation and increasing to 272 L/hr in a single event approximately 10 days after monitoring commenced. For the remainder of the trial (31 days), AS1 outflows continued to fluctuate, ranging between 20 L/hr and 122 L/hr. Outflows from AS2 were less variable and ranged between 10 L/hr to 80 L/hr for the duration of the trial. When reviewing individual columns it is evident that flows are being constricted in AS1B and AS2B, with higher flow rates consistently observed from AS1A and AS2A sampling points.

Flow impedances are likely the result of the NUA blend porosity and/or the capacity of the pump. Neither the engagement of the high flow bypass shortly after the commencement of the trial or alteration of the geofabric (90 μ m) to the metal mesh screens (100 μ m) appeared to alter the flow rates from AS1OUT and AS2OUT.

Contact time

Table 2 shows the NUA blend contact time within the active system for a range of flow rates. Note that the contact time shown is the total contact time of all three columns in series (i.e. outflows from AS1 and AS2) and differs from the design contact due to design variations upon implementation (e.g. volume and compaction of NUA). From the flow (Figure 17) and contact data it is evident that AS1 contact time varied between 2 and 23 hrs and averaged 7.2 hrs at 64 L/hr. AS2 contact time varied between 46.3 hrs and 5.8 hrs and averaged 10 hrs at 46 L/hr. The design contact time was therefore exceeded, on average, by 7 to 10 hours.

| No. days observed above % | Flow Rate, Q (L/hr) | Contact time, (mins) | Contact time, (hours) |
|---------------------------------|------------------------|-------------------------|--------------------------|
| 0.0% | 500 | 56 | 0.9 |
| 0.0% | 400 | 69 | 1.2 |
| 0.0% | 300 | 93 | 1.5 |
| 3.3% | 200 | 139 | 2.3 |
| 10.0% | 100 | 278 | 4.6 |
| 13.3% | 80 | 347 | 5.8 |
| 30.0% | 60 | 463 | 7.7 |
| 56.7% | 40 | 694 | 11.6 |
| 90.0% | 20 | 1389 | 23.1 |
| 100.0% | 10 | 2777 | 46.3 |
| 100.0% | 5 | 5554 | 92.6 |

Table 2 PTV2 Active system contact time for active system 1 (AS1) and active system 2(AS2)

4.2.3 Chemical Outcomes

This section aims to provide a high-level overview of key components of the major ion, physio-chemical, nutrient and trace metal characteristics of the active system trials (using the same broad methodology as the appreciation of the passive system effluent data) within PTV2, with emphasis on those variables that have been considered potentially problematic in past investigations.

Major lons

From Figure 18 (which is layed out in the same format as Figure 4 with the Piper on top and the Schoeller on the bottom), it was apparent that the major ion relationships in effluent water did not vary as significantly over time as in the passive system effluent. The degree of this variability (as concentrations of major ions) is also seen in Figure 18, which, like the

passive system, shows significant concentrations of major ions in the effluent water that were not originally present in Ellen Brook water.

As per the passive system the dominant major ions within the active system effluent were Ca and SO₄. However, unlike the passive system it was apparent that the concentrations of key major ions (in particular Ca and SO₄) did not decrease as much over time when the system was subjected to Ellen Brook water (Figure 19). This was observed diagrammatically in specific water samples taken during the start, middle and end of the evaluation (Figure 20), which suggests that the active system did not attain the same steady state (relative to the Ellen Brook water) over the duration of the investigation.

Physio-chemistry

From Figure 21 it is evident that the pH of the active system effluent remains high throughout the investigation period. This is similar to the passive system, suggesting a similar generation mechanism (namely the calcined magnesia).

The pH levels observed within the effluent of the active system are more variable (Figure 21) than the pH levels observed in the effluent of the passive system. This suggests that there may be other factors which affect pH levels (such as the mineral dissolution / precipitation of Ca dominated minerals) than solely the presence of calcined magnesia.

Unlike the passive system, EC levels do not approximate Ellen Brook EC levels after a few weeks. As per the dominant major ions (in particular Ca and SO₄), EC levels do not attain a steady state relative to the low levels observed in the Ellen Brook water.

Figure 21 reveals that the concentrations of DO were variable and that there were no clear relationships between DO content of the Ellen Brook water and DO content of the effluent. However, this may be an artefact caused by the sampling methodology, such as the introduction of oxygen into effluent samples during the sampling process (i.e. at the sample outlet the pressure head within the active systems may have forced water to run through the sample tap which may have introduced oxygen into the sample *pers. comm.* A. Hams).

Nutrients

Using a similar rationale for interpreting the nutrient data from the passive system, the following key conclusions (typically highlighted in Figure 22) can be drawn from assessment of the effluent data from the active system:

• The active systems are efficient at removal of phosphorus in both measured forms though there was less data compared with the passive system trial due to the length of the respective trials.

- TP and PO4 were efficiently attenuated by the active system, and were apparently constrained (to some degree see Figure 23) by the same relationships that controlled nutrients in the passive systems. Like the passive system the same uncertainties exist for the long term fate of phosphorus attenuation. For example, given the long term stability of trace metals within the filters (including, potentially Mn, Fe and Al that typically form as surface bound hydroxides) this may represent a long term concern for the attenuation of phosphorus, in particular if pH fluctuations occur.
- There were significant concentrations of nutrients in the Ellen Brook influent (NSFIN) water, and with the exception of NO₃ and NH₃ all other species (with minor exceptions pertaining to TN) had equal or lower concentrations than the Ellen Brook water.
- The active system effluent samples had a greater variance with respect to dissolved organic carbon, TN and Org_N content (Figure 24), and may be (given the uncertainties in interpretation generated through having less data than the passive system) considered more effective at attenuating these analytes. This may be due (anecdotally) to different flow mechanisms within the two trial systems, though such an interpretation cannot be verified with the data available.
- The active system effluent contains substantially greater concentrations of NO₃ than the passive system effluent, and typically the NO₃ occured in higher concentrations than in the Ellen Brook water.

<u>Metals</u>

Using a similar rationale for interpreting metals data from the passive system, the following key conclusions can be drawn from assessment of the metals data (Figure 25 and Figure 26) from the effluent of the active system (note the ChemCentre (2012) report will provide a more thorough review of observed trends):

- Concentrations of AI, Fe and Mn were initially very low in effluent samples at the beginning of the investigation, yet concentrations rose on day 30 (approximately) of the trial, which suggests a perturbation (and potentially release of TSS) of the system of some sort.
- Cr, U and Sr concentrations were higher in effluent water or equal to concentrations in Ellen Brook water throughout the duration of the investigation.
- Mn and Co concentrations were higher in effluent water than Ellen Brook water as a result of rising concentrations, though this only occurred in two samples towards the end of the trial period in AS1A and AS2A.
- Sr and Cr(VI) and to an extent U had concentrations in effluent that were higher than the metals concentrations in Ellen Brook water due to a first flush release.

Interpretation of the data shows that in general metals attenuation by the active systems was relatively efficient. However, key issues that limit the ability to thoroughly interpret the data (especially in relation to the passive system trials data) include:

- the shorter duration of the investigation, and the lack of observable trend data, and
- the implications on metals mobility associated with not achieving steady state conditions (as occurred in the passive system).

4.2.4 Discussion

Environmental implications

The active system didn't achieve a steady state (with respect to major ions, pH, EC and some metals) which suggests that the first flush management period will be prolonged relative to the passive system first flush management period. Importantly, Cr(VI) is one of the metals that was present in effluent water during a prolonged first flush period.

Whilst the active system showed good removal efficiency for TP and TN and was amenable to act as an amendment, the increased release of NO_3 when compared to the passive system was considered an issue that would need further investigation in the context of an end-of-catchment wetland system.

Technical implications

PTV2 highlighted the technical difficulties in utilising NUA in an active arrangement. Technical difficulties which need to be overcome include: hydraulic conductivity (filter media specification and proportion of fines), contact time, high head conditions, low pump rates, capacity to retain filter media in columns and outlet filter specifications.

The low flow rates observed in the active systems have implications on the systems scalability and treatment efficiency. Scaling up the system to an end-of-catchment application would present serious economic implications, particularly the capital and operating expenditure associated with high head pumps (see section 8.3). Furthermore, the active system would require additional end of line treatment steps to prevent NUA blend particulates exiting the system and discharging directly to Ellen Brook. Considering the composition of NUA used in PTV2 (89% is < 50µm), such end of column/outlet filtration systems would need to target very fine particulates.

Whilst reconfiguration of the active system would likely result in a technically feasible approach, the economic practicalities of operating such a system bring into question the long term treatment effectiveness of the system (i.e. \$/kg TP removed).

PART 3 END-OF-CATCHMENT TREATMENT SYSTEM PRE-FEASIBILITY ASSESSMENT

5.0 PURPOSE OF PRE-FEASIBILITY ASSESSMENT

This section presents a technical and environmental pre-feasibility assessment. Note that due to insufficient information it is not the intention to provide a full feasibility at this stage. Rather, the purpose of this section is to identify issues and define areas which require resolution before a full feasibility can be progressed.

6.0 ISSUES & UNCERTAINTIES

This section aims to summarise all key issues and/or uncertainties identified in the Stage 1 Syrinx report in light of the peer review conducted by Associate Professor Mike Grace and outcomes from PTV1 and PTV2. Table 3 synthesises the relevant issues and uncertainties which still need to be addressed in the context of the use of an NUA blend within an end-ofcatchment treatment system in Ellen Brook.

The argument that a majority of these issues can be managed through dilution requires further investigation, particularly considering the hydraulic efficiency of an end-of-catchment treatment system. Section 8.5 provides discussion on water quantity modelling, identifying that treatment of Ellen Brook flows will occur during both low and high flow periods. Furthermore, during some low flow periods, a large proportion of Ellen Brook flow (i.e. up to 100%) could be diverted to the treatment system.

Ultimately, addressing the identified issues will require additional laboratory and field scale trials as the current data is inconclusive. Section 7.1 presents a range of recommendations for additional trials.
Table 3 NUA issues matrix

| | Issue Identified | | Imp | olications | Ро | otentia |
|-------------------|---------------------------------|---|-----|---|----|------------------------------------|
| | Manganese | Soluble Mn release observed in CSIRO column trials (4 mg/L). Particulate release in PTV2 (active system) likely related to TSS release from the columns. | • | Potential long term release may cause a range of unacceptable environmental impacts. Potential particulate Mn release from the passive system arrangement if periodically flooded and active system if fines filter is omitted. Potential -speciation changes of Mn downstream depending on temperature, pH and redox conditions. | • | Furt |
| | Sulphate | Sulphate release observed CSIRO column trials and PTV2. PTV2 – initial release from passive system, ongoing release from active system. | • | Increase in EC which could be detrimental to a fresh water system and may result in microbial and plant decline or deaths. Potential sulfide generation where oxygen levels are low. Can cause toxicity to plant roots and aquatic organisms. | • | Ens aero |
| (| Sulfide | Sulfide release in PTV2 active system and to a lesser extent in passive system. | • | Possible gas release may cause health issues to human receptors. Potential to help the formation of acid volatile sulfide in anoxic conditions. | | |
| er Quality) | Calcium | High soluble and total calcium concentrations in the PTV2 active system | • | Potential $CaCO_3$ precipitation with decreasing pH, possible smothering of downstream benthic and littoral habitats and potential to cause clogging of filter media. | | |
| nvironmental (Wat | рН | High pH (>9) observed throughout PTV1 and PTV2 Likely relationship between pH and MgO. | • | High pH can: affect aquatic life (flora and fauna) downstream of the NUA filter both in current and ecologically restored (i.e. end-of-catchment wetland) ecosystem. potentially impact metal speciation in receiving environments. | • | Inve MgC If M che a de |
| Ē | | | | potentially impact upon integrity of steel and concrete infrastructure. | | |
| | Electrical Conductivity (EC) | High EC levels in PTV1 and PTV2 PTV2 – high levels initially in the passive system and maintained throughout in the active system. | • | EC can significantly impact health of aquatic receiving environments. | • | Inve Bett and |
| | Copper | PTV2 passive system – although in very low concentrations (Max = 0.005mg/L), an increasing concentration trend was observed. | • | Potential to cause a range of unacceptable environmental impacts. | • | Furt cop Inve |
| | Cobalt | PTV2 passive and active system - although in very low concentrations (Max = 0.0006mg/L in active system and 0.0021mg/L in passive), an increasing concentration trend was observed. | • | Potential to cause a range of unacceptable environmental impacts. Impacts have not yet been determined due to lack of data. | • | Furt cob Inve |
| | Chromium VI | Initial release of chromium VI in PTV2 passive system and active systems | • | Cr VI is potentially toxic to aquatic organisms and human receptors. | • | Con for r Inve |

al future investigations/Suggested actions

ther research to investigate long term release of Mn.

sure that receiving system, post NUA filter is kept robic.

estigate if the pH issue is solved by the removal of O from the filter blend.

IgO is retained investigate cost effective options (e.g. emical dosing) for lowering pH to acceptable levels in edicated polishing unit.

estigate lower proportion of NUA in the filter blend.

ter assess relationship between gypsum dissolution I concomitant EC in effluent.

ther research to investigate long term release of oper from NUA.

estigate lower proportion of NUA in the filter blend.

ther research to investigate long term release of balt from NUA.

estigate lower proportion of NUA in the filter blend.

nfirm if recirculation of initial "flush" of effluent allows released chromium to be retained in the filter.

estigate lower proportion of NUA in the filter blend.

| | Issue Identified | | Implications | Pc | otentia |
|----------|-----------------------|--|---|----|--------------------------|
| | Caesium | Soluble and total caesium release in the PTV2 active system upon first flush and typically throughout. | Possible environmental impacts have not yet been determined. Potential to cause a range of unacceptable environmental impacts. | • | Furt caes |
| | Strontium | High in active system throughout and especially in first flush. Initial release of strontium in passive system. | Potential to cause a range of unacceptable environmental impacts. Impacts have not yet been determined due to lack of data. | • | Furt stroi |
| | | | Require management of first flush conditions over a longer period in the active system. | | |
| | DOC removal | Lower than anticipated DOC attenuation throughout PTV2 in the passive system, with the exception of first | Implies that DON will not be attenuated as efficiently in the Active system due to the less efficient attenuation of DOC. | • | Furt at hi |
| | | flush (average of 19% removal in both 25% and 40% NUA blend) but high (average of 60% removal) in the active system. | | • | Furt type |
| | DON removal | During the PTV2, DON attenuation was low in the Passive system but high in the active system. | Low DON removal not expected. DON breakthrough occurring earlier than initially thought. | • | Furt remo |
| | Ecotoxicology | Swan-Canning species (freshwater copepod, Macrocyclops albidus, and western pygmy perch Edelia vittata) have not been tested. | Potential ecotoxicology to Swan-Canning species that were not tested. | • | Furt spec |
| | Surface clogging | TSS accumulation on the NUA filter surface creating a layer of fines at the filter surface. Although TSS | Decrease in hydraulic conductivity value (k_s) at the surface, resulting in: | | Furt |
| | | concentrations are low, loads are high because of the high flows applied. | Bypassing of NUA filter (i.e. small percentage of flows treated) | | effe Pre- |
| | | | High contact time Requirement for intervention to maintain appropriate k value | | |
| ical) | | | \sim Requirement for intervention to maintain appropriate k_s value | | |
| olog | Interstitial clogging | Align percentage of lines in NOA (57% of particles <63µm and 72% of particles <125µm) | Compaction leads to reduced hydraulic conductivity. Iron and aluminium precipitation is one likely cause of interstitial | • | be u |
| chn | | Biofilm accumulation | clogging. | | mor sett |
| ring (Te | | Filter compaction/settling. Filter media compaction/settling in the order of 50-100mm was observed in the passive system. | | | con Pre |
| Enginee | | Iron precipitation as FeOH₃ in the filter medium. High removal of Fe (76% removal of soluble Fe in the passive system and higher in the Active system during PTV2). | | • | Inve |
| | | Aluminium precipitation as AIOOH in the filter medium. High removal of AI (86% removal of soluble AI in the passive system during PTV2). | | | |
| | | Interstitial clogging due to mineralisation through hydroxyapatite ± other mineral phases | | | |

I future investigations/Suggested actions

ther research to investigate long term release of sium from NUA.

ther research to investigate long term release of ntium from NUA.

ther research to investigate long term DOC removal igher flow rates and limited contact time.

her research into most effective organic substrate to attenuate DOC in the treatment train

ther research to investigate DON (and related DOC) oval at higher flow rates.

ther research to investigate chronic toxicity to local cies.

ther lab scale research to verify relationship between vs, influent TSS, surface clogging and assess cost activeness of maintenance frequency.

-treatment to remove TSS.

o scale assessment of hydraulic conductivity should undertaken over a significant duration of time (i.e. 12 nths minimum) and measured post initial filter tling/compaction/clogging to reflect normal operating inditions.

e-treatment of iron, aluminium prior to NUA filter

estigate ways to increase K in NUA blend:

- o Reduce quantity of NUA added.
- o NUA pelletisation.
- Screening and removal of particles <125µm prior to installation.
- o In-situ mechanical intervention.
- o In-situ biological intervention (vegetation).

| Issue Identified | | Implications | Potential |
|--------------------------------|--|--|--|
| Filter media Specifications | Quantity of fines due to NUA is high (25% NUA blend contains 7% of fines. 40% NUA blend contains 9.5% of fines). This is much higher than a range of guidelines for similar applications (e.g exceeds FAWB biofilter guidelines -3% particles <50µm; exceeds the Danish wastewater vertical flow wetland filter media guidelines for (Max allowed is 0.5% particles <125µm). (Danish guidelines for vertical flow wetlands treating wastewater, Brix and Arias, 2005). | System clogging – the composition of NUA blend is potentially a cause of system clogging. To comply with FAWB guidelines, the maximum permissible proportion of NUA in any filter blend, assuming that other materials (e.g. sand, activated carbon, etc) are free of fines, is 5.2%. To comply with the Danish guidelines for vertical flow wetlands, the maximum permissible proportion of NUA in any filter blend is 0.7%. Note that although VF wetlands are designed to treat continuous flows, intermittent dosing is usually recommended to allow resting of the bed and prevent clogging. It is important to note that bioretention systems are designed to treat stormwater, ie. stochastic events, not continuous flows. A continuous flow system is likely to clog even when FAWB Guidelines are met. | Investand toget minin asses to ag |
| NUA loss | Fine particles of NUA were flushed from the filter medium in the active system during PTV2. | TSS and turbidity impact in receiving waters. Uncontrolled release on NUA material directly into Ellen Brook and receiving environment – unknown consequences. | Investors Continue Flood Fine Disret |

I future investigations/Suggested actions

estigate if incorporating lower percentages of NUA higher percentages of coarse sand in the blend ether with regular intervention/vegetation help imise (postpone) clogging. Trials are needed to ess what is an acceptable NUA content and/or how ggregate NUA to avoid clogging.

estigate alternative filter arrangement which nsiders: ntainment of NUA within a passive system during oding

e particulate filtration post active system

regard active system.

6.1 POTENTIAL ISSUES & RISKS

Listed below are potential <u>key</u> issues and risks identified as potentially compromising the effectiveness of an end-of-catchment wetland containing NUA/NUA blends as part of the treatment train. The following requires further investigation:

Effects of Low Hydraulic Conductivity of Media

- The hydraulic conductivity of the NUA blend was well below that required to manage the expected flows and ensure optimal contact time.
- Clogging issues (and associated effects on Fe, Mn, Al, Ca and Si chemistry) will need to be carefully addressed in the overall design of any system.

Release of Potential Contaminants

- Initial release (first flush) of major ions, nutrients (in particular NO₃ and NH₄) and metals. This issue would need to be well controlled/managed in the context of an end-of-catchment wetland and/or the development of well understood contingencies associated with direct release into a receiving environment.
- The passive and active systems in PTV2 behaved differently (hydro-dynamically and hydrogeochemically). There needs to be a more thorough understanding of why this is so, especially in the context of achieving steady state conditions, and the implications for long term metals release (especially Mn and Fe and potentially AI) and breakthrough of other elements.

Effects of High pH on Filter and Receiving Environment

- The pH levels of NUA blend effluent containing MgO is too high to support plant growth in the filter and therefore having a vegetated biofilter in order to improve the hydraulic properties of the system is not feasible. As such, interventions are required to reduce pH, most likely being the removal of MgO from the blend. Removal of MgO may mean that vegetating the system becomes feasible, subject to further investigation. Note the resultant 'amended blend' would need to be re-investigated to ensure it does not cause other issues.
- The pH levels of NUA blend effluent (including MgO) will impact on the receiving wetland during low flow periods, but are unlikely to have major impacts during high flow as a result of the dilution effect. Further investigations are needed to determine if this is an issue, and identify whether a dedicated polishing basin with an acid dosing facility is required.
- The pH is also a dominant control on metals stability. There needs to be a more thorough understanding pertaining to pH changes (over different time scales) and

metals solubility in the context of environmental issues associated with a wetland catchment system or downstream receptor.

 The sulphate (allied to Ca ion) content of the NUA blend effluent water is high, which can have implications for sulfide generation within the filter and downstream depending on pH and redox status. Therefore, a sulfide management plan may be required.

Uncertainties Due to Limitations of Trial

- The duration of the investigation did not appear long enough to fully observe issues associated with the interaction of metals and mineralisation processes, in particular there were differences in trial investigation periods/durations between the passive and the active systems. This makes the comparison of data between the two systems difficult, and potentially misleading as investigation outcomes. Aligned trial times would be necessary to make meaningful commentary on the effectiveness of the systems relative to each other.
- The investigations did not provide an understanding of how the chemistry of the NUA blend filters will respond under seasonally variable conditions (e.g. wetting and drying cycles).
- The investigations did not provide an understanding of the NUA blend replacement requirements/replacement frequency (i.e. cessation of effective nutrient removal).

The above suite of technical and environmental issues need to be viewed in the context of environmental, economic and social risks and a balance needs to be sought based on agreed and appropriate nutrient removal efficiency for the Ellen Brook end-of-catchment treatment system.

7.0 IMPLICATIONS FOR DESIGN OF AN END-OF-CATCHMENT TREATMENT SYSTEM

Generally, there are still too many uncertainties to ascertain a preferred arrangement of NUA blend in an end-of-catchment treatment train. Further trials need to be conducted to investigate hydraulic conductivity, NUA volume in blend, contact time, pH changes over time (including implications of removal of MgO), the attainment of steady state conditions and first flush management strategies.

Notwithstanding these knowledge gaps, certain design criteria can now be set to allow progression of a conceptual level system design, in particular, the wetland component of the treatment system. This is addressed in section 8.0.

7.1 KEY RECOMMENDATIONS

Effects of low hydraulic conductivity

- Extend duration of current and future pilot trials (and lab trials where applicable) to assess changes in hydraulic conductivity over time. Investigations should be carried out over a minimum duration of 12 months.
- Characterise typical/major causes of clogging (i.e. surface clogging, interstitial clogging, blend composition etc).
- Investigate potential methods to alleviate clogging issues (i.e. mechanical intervention, mechanical mixing, vegetation, pelletisation, fines screening, lower portions of NUA material).

Note that any changes to the NUA blend composition and configuration will require recharacterisation and re-assessment of nutrient and DOC removal efficiencies as well as potential issues.

Effects of High pH on Filter and Receiving Environment

- Resolve issues with hydraulic conductivity in the first instance. If high pH still remains as an issue the following could be undertaken:
 - Omit MgO from NUA blend; and/or
 - Implement additional treatment steps (i.e. HCl dosing) targeted at pH reduction.

Release of Contaminants

- Investigate potential management measures for the first flush issues, such as pretreatment of NUA media.
- Re-characterise NUA blend and identify issues associated preferred arrangement (i.e. post resolution of hydraulic conductivity). Identify whether additional treatment steps or management measures are required within the treatment train (e.g. HCI dosing, humate pre-treatment for DOC).
- Establish trials to assess impacts of long term release of Mn, Fe and potentially Al which may impede on the overall effectiveness of an NUA blend utilised in a treatment train arrangement.

Other recommendations

 Review ANZECC guidelines and identify areas where site specific trigger values may be more appropriate in the context of an end-of-catchment wetland treatment train.

PART 4 CONCEPT DESIGN

8.0 END-OF-CATCHMENT WETLAND TREATMENT SYSTEM

As part of the overall intent for this project, an end-of-catchment wetland treatment system is to be incorporated into the overall solution for improving the quality of Ellen Brook water and improving the biodiversity and landscape values of this part of the catchment. It is acknowledged that wetlands alone will provide limited nutrient removal function due to the large size of the Ellen Brook catchment (716.4 km²), and the significant annual flows relative to the available wetland treatment area, hence why options for incorporating amendments or other engineering measures are also necessary. Given that the progress with nutrient filter blends/amendments is still at the trial stage, this section addresses a wetland concept design that can be built and then effectively 'retrofitted' with additional off-line components when the integration of amendments have been better resolved.

This section aims to present a <u>best practice approach to river restoration</u> which incorporates off-line wetlands and can be <u>retrofitted</u> with an NUA blend filtration system or other nutrient amendment product to provide enhanced nutrient removal. Best practice principles as applied to this project incorporate the following:

- 1. Replicating nature in the location and arrangement of constructed measures.
- 2. Flow velocity reduction.
- 3. Stream bank and bed protection and repair.
- 4. Surface erosion and sediment transport reduction.
- 5. Replacing, protecting and rehabilitating fringing vegetation.

This approach will provide an improvement to the existing site conditions. Flora surveys for Site 1 and 2 and identify that no Threatened Ecological Communities are present within the sites and that generally the native vegetation is in poor – very poor condition (Connell, 2010). Similarly, fauna surveys recorded a depauperate fauna and this was reflected in its degraded habitats, low quantity and quality of complexes and small size of the fragmented remnants (Prefumo, 2011).

Concepts presented in this section have been developed for both Site 1 and 2 (see Figure 27 for site location and Figure 29 for conceptual drawings). Ultimately these concepts can be applied to other sites along Ellen Brook to provide additional water quality improvements and importantly improved habitat and amenity values. This will act as an extension of broader rehabilitation projects currently being undertaken within Ellen Brook.

8.1 DESIGN CRITERIA

In light of the pilot trial outcomes several amendments have been made to the existing design criteria identified in Stage 1 of this project. Criteria review and resulting modifications were co-ordinated with the Project Working Group (PWG) at a meeting held at the Trust on the 21 December 2011. Appendix 5 presents the revised Design Criteria and Design Approach framework. Generally, the revisions extend to:

- Recognising that site specific water quality guidelines may be more appropriate and should be used in addition to/in place of ANZECC criteria. Appropriate site specific trigger values require review within the PWG and development in future stages of work.
- Utilising wetlands to provide enhanced TN reductions for the 'treatable' flows to reduce reliance on an NUA blend based system. PTV2 data highlighted that, in a passive configuration, TN reductions are three fold lower than expected, whereby 20% TN reduction was achieved rather than the 60% identified in Stage 1. It was therefore identified that wetlands, rather than NUA, are required to provide enhanced nitrogen reductions.
- Allowing for the abstraction of water from within the channel to divert to a separate NUA or similar treatment module, and no in-channel use of NUA.
- Maintenance of hydraulic capacity and conveyance of the existing site to a level that protects existing infrastructure and land uses rather than to predevelopment conditions. The maintenance of predevelopment conditions is not possible in the likely instance where on-site storage (i.e. weirs) is required.
- Aboriginal heritage site identification shall take place following conceptual design works, rather than prior to the commencement of such works, at the request of the Aboriginal consultants.

8.2 SYSTEM DESCRIPTION

Figure 28 and Figure 29 presents conceptual arrangements for best practice river restoration within Sites 1 and 2. Three distinct components are identified within each concept: riffles, pools and floodplain depressions (in effect, surface flow off-line wetlands). These components are arranged to form a treatment train for treatment efficiency. Sequences of riffles and pools mimicking natural streams make up the first steps of the treatment train and deliver important habitat creation, oxygenation, sedimentation and storage function. Retrofit of the aforementioned pools with an off-take allows the conveyance of Ellen Brook water to an off-line NUA blend filtration system for enhanced P removal. Unvegetated and vegetated off-line wetlands form the final step of the treatment train, polishing NUA effluent and enabling opportunistic N removal prior to discharge to Ellen Brook.

8.2.1 Riffles

Reinstatement of riffles within Ellen Brook provides important ecological functions (aquatic fauna habitat, oxygenation) in addition to opportunities for flow control and resultant sedimentation and sets the water depth in the pools. In this case, shallow rock riffles are proposed in strategic locations along straight reaches/meander inflection points. The distance between riffles has been calculated using the rule of thumb principal that the length of the pool riffle sequence is on average six times the bankfull width of the stream (Penn, 1999).

In order to maintain the water level in the pools, the core of the riffle will comprise of a 2 meter high clay bund which will act as a water level control structure. The bund will have an upstream batter no more than 1 in 4 m, a downstream batter of 1 in 20 m configured to allow fish passage. Geotextile and gravel/sand bedding will extend over the bund to bankfull levels to allow the keying in of well graded angular rocks and minimise disturbance and potential erosion of existing Bassendean Sand site soil.

Modifications to the existing channel batters will be required in some areas to allow the placement of riffles and implementation of stable banks. As the existing bank is an inherently unstable incised channel within Site 1, and some portions of Site 2, re-grading at a 1 in 6 slope and revegetation is considered appropriate. Areas vulnerable to erosion may require additional soft engineering works such as large woody debris and/or jutematting/brushmattressing.

8.2.2 Ephemeral Pools

The pools perform two important functions. Firstly, they slow down the water velocity and allow the coarse to medium sized sediments to drop out of suspension and settle. Secondly, they provide an important storage function, allowing abstraction points for an NUA blend filter system.

The location of the pools is focused in areas where they would likely naturally occur, mainly in areas of existing meander bends. The depth and surface area of the pool is controlled by the elevation of the downstream riffle and clay bund combination. In this case, the depth of the pool will range from 0 m (upstream) to 2 m (downstream) high. The surface area of the pool will generally extend upstream to the next riffle and, with bank re-grading, extend across to the existing floodplain in some areas.

As shown in Table 4, assuming an average water depth of 1 m and total surface area of 3.44 ha, the total storage capacity provided within pools in Site 1 and 2 is approximately 34.4 ML. This capacity provides storage for approximately 19% (5.07 GL) of average annual (1997) Ellen Brook flows assuming water is turned over/treated in a 24-hour

period. Provision of this storage volume provides ample opportunity to treat a significant portion of Ellen Brook flows through an NUA blend should the site be retrofitted in the future. For example, the pools could be connected to a passive filter arrangement via a passive (channel) or pumped conveyance system or to an active system via a pipe and pump arrangement.

| | Surface area (m ²) | Ave. depth (m) | Volume (m³) |
|--------|--------------------------------|----------------|-------------|
| Site 1 | 17,676 | 1.0 | 17,676 |
| Site 2 | 16,679 | 1.0 | 16,679 |
| Total | 34,355 | - | 34,355 |

Table 4 Site 1 and Site 2 pool surface area and volume

All pools will be ephemeral, impounding water during low flow periods, becoming dry for parts of the year and overtopping the riffle bund during high flows. This represents an improvement of existing conditions particularly for habitat creation when combined with revegetation. Revegetation provides enhanced habitat amenity, particularly for the western swamp tortoise, addresses potential erosion issues and provides shade. Shade, together with the tannin water are important considerations in reducing algal bloom occurrences.

Considering that clogging presents real issues which may compromise the long term treatment effectiveness of any end-of-catchment filter (passive or active), settling out of sediments prior to any off-line filter is essential. Section 8.6.1 provides an assessment on the sedimentation capability. Additional structural measures may be required within the pools to assist with enhanced sedimentation and precipitation of some metals (for instance Fe and Mn).

8.2.3 Surface Flow Wetlands

Surface flow wetlands are intended to mimic natural floodplain depression, and are to be located at the terminal end of the NUA blend filter (see section below). They are intended to receive and polish effluent and provide opportunistic nutrient removal, (primarily N), prior to discharge to Ellen Brook.

Similar to the pools, the wetlands are positioned in the floodway. The shape and extent of each wetland is confined by the site constraints, particularly the topography, hydrology and infrastructure protection. Wetlands are to be located such that the required grade ensures that a free flowing system can be achieved. Whilst this provides a best practice approach and efficient hydraulic design, it is not an ideal arrangement as it means that the wetlands will be subject to periodic flooding. Bunding will therefore be required around the wetland perimeter to prevent interaction with Ellen Brook water during an average year. As a result, during a critical storm event greater than 1 year ARI, the bunds and performance of the

wetland may be compromised. Further investigations are therefore be required once the preferred NUA blend is determine to assess the effect of wetland flooding and implications of precipitate mobilisation.

Within Site 1 and 2 two types of wetlands will be present:

- 1. <u>Unvegetated open water bodies</u>- located immediately after the NUA blend filter to polish effluent and precipitate metals prior to discharging to a vegetated wetland. If the present blend of media (i.e with MgO) is used in the final design, then the effluent from the NUA blend filter will be highly alkaline, and above the threshold level for the majority of wetland plant species. Consequently there will be minimal vegetation establishment in this wetland. Dependant on the pH buffering capacity of the wetlands, additional measures may be required to lower the pH such as the removal of MgO from the blend or chemical (HCI) dosing.
- <u>Vegetated surface flow wetlands -</u> the vegetated surface flow wetlands are to be densely planted, variable in depth (average 0.4 m) and comprise of aerobic and anaerobic zones.

Table 5 shows the surface area and volume for wetlands identified in the concepts. Assuming a nominal water depth of 0.4 m and a total surface area of 6.07 ha, the total storage capacity provided by the wetlands in both sites is approximately 24.3 ML. All wetland areas are to be lined with clay to avoid interaction with the groundwater and maximise detention.

| | Surface area (m ²) | Ave. depth (m) | Volume (m ³) |
|--------|--------------------------------|----------------|--------------------------|
| Site 1 | 35443 | 0.4 | 14,177 |
| Site 2 | 25242 | 0.4 | 10,097 |
| Total | 60,685 | - | 24,274 |

Table 5 Site 1 and Site 2 wetlands surface area and volume

Because the wetlands are arranged in series, discharge of water to each downstream pool will duplicate treatment (i.e. treated water could be abstracted from the downstream pool and treated multiple times). A high flow bypass is therefore required within each wetland to bypass treated water around the downstream treatment systems, discharging to Ellen Brook. Technical resolution of wetland hydraulics will be required in the future stages of work.

8.3 INTEGRATION OF NUA BLEND FILTER

As there needs to be resolution of the issues and uncertainties outlined in section 6.0, the integration of the NUA blend within an end-of-catchment treatment system can only be described conceptually.

Integration of the NUA filter blend within a best practice river restoration would preferably comprise of a passive arrangement due to technical and environmental issues in addition to economic issues. Preliminary scaling assessment shows that when scaling up the PTV2 active system in an end-of-catchment application, 580 active systems in a three column series arrangement are required. This assumes a 1 hour contact time, 500 L/hr flow rate (Table 2), and a sustainable diversion rate of 7 ML/day (refer water quantity section 8.5). The capital purchase of the column systems, together with the capital and operational costs associated with the pumps would likely present an economic constraint for the use of the active system. Comparatively, scaling up of the passive system assuming a conservative long term hydraulic conductivity of 50 mm/hr (assumes intervention) would require an NUA blend surface area of ~5,900 m².

As per Stage 1, Concept 2, the passive arrangement could comprise a vertical flow filter, with a set filter depth and head. Modifications to the original concepts developed in Stage 1 are required to address clogging issues and maintain an appropriate hydraulic conductivity. Implementation of clogging interventions (section 4.1.3) would likely deliver a more cost effective approach when compared to the active system, particularly for ongoing operational costs.

8.4 DOMINANT PROCESSES

Dominant physical, chemical and biological processes for the conceptual arrangements are synthesised in Table 6 below. Generally, the system operates in a treatment train configuration whereby riffles and pools slow the water down and allow settling out of sediments prior to influent conveyance to an NUA blend filter. The NUA blend filter provides enhanced P removal and some degree of N removal but the effluent requires post treatment to neutralise pH and remove metals, which can occur in a dedicated polishing unit. Once pH has been adjusted (if required), polished flows receive further biological treatment and opportunistic N removal is provided within the wetlands prior to discharging to Ellen Brook. Potential operational issues and serviceability requirements are also indicated in Table 7.

| Table 6 Best practice river | restoration and end-of-c | atchment treatment s | ystem dominant processes |
|-----------------------------|--------------------------|----------------------|--------------------------|
| | | | |

| | 1 | 2 | 3 | 4 | 5 | 6 |
|-------------------------------------|--|--|--|--|---|--|
| | River | Ephemeral pools and riffles | NUA filter | Unvegetated wetland | Vegetated wetland | River |
| Purpose | Intake of high nutrient (DON, DOC) water to be treated | Detention (24 hours) for eventual distribution to NUA filter Removal of sediments prior to NUA filter to reduce surface clogging Removal of contaminants associated with sediments Precipitation of Fe (aerators) to reduce interstitial clogging | Phosphorus removal Some DON removal Some DOC removal | Neutralisation of pH Removal of metals | Ammonification, nitrification and denitrificiation processes Nitrogen removal organic and inorganic nitrogen DOC removal Habitat creation Environmental restoration | Discharge of treated effluent to Ellen Brook |
| Dominant physical processes | Conveyance of Ellen Brook water to Swan River. Seasonal flows. 26.75 GL/yr average annual flow volume. | Settling of coarse to medium-sized sediments (>125 µm). | Conveyance of water across NUA filter Formation of 500 mm depth head Vertical flow of water through NUA blend Conveyance of effluent via subsoil drains to a polishing system (4) P adsorption | Dosing required to adjust pH rapidly (e.g HCI dosing) Flocculation of metals likely to occur | Filtration through organic substrate and macrophytes. Settling of fines Evapotranspiration Accretion | Discharge of treated effluent to Ellen Brook flows. Dilution of effluent via mixing (in high flow conditions) |
| Dominant chemical processes | Ion-exchange (??) Oxidation and reduction reactions | Potential removal of contaminants (metals) associated with settling of fine to coarse sediment Potential precipitation of Fe | P precipitation Metal precipitation Metal solubilisation | Reduction of pH Precipitation of metals | Reduction of pH Precipitation of metals Sulphate reduction Elemental cycling | Oxidation and reduction reactions |
| Dominant biological processes | RespirationPhotosynthesis | RespirationPhotosynthesis | Microbially mediated oxidation and reduction reactions | Microbially mediated oxidation and reduction reactions (minor, due to short retention time) | Microbial and plant growth and chemical uptake Microbial Nutrient transformation: Ammonification, Nitrification, Denitrification Respiration and photosynthesis | RespirationPhotosynthesis |
| Potential issues | Flooding | Re-suspension of fines during high flows Fauna passage Infrastructure protection Algae proliferation | Hydraulic constraints: surface and interstitial clogging. Initial release of metals and long term release of metals High pH High EC | Flows may be too high for full pH adjustment to occur (inc. flocculation process) Over or under dosing of acid if dosing system becomes faulty. | Potential smothering via precipitation of metals (Fe and Mn) on wetland surface High or low pH entering the wetland in case of a faulty dosing system | Concentrated effluent at discharge point. No mixing at low flow conditions |

ELLEN BROOK End-of-catchment treatment system

| | 1 | 2 | 3 | 4 | 5 | 6 |
|----------------|-------|---|---|--|--|---|
| | River | Ephemeral pools and riffles | NUA filter | Unvegetated wetland | Vegetated wetland | River |
| | | | Note that the high pH and EC may not be an issue with the removal of MgO from the NUA blend | | | |
| Serviceability | • N/A | Moderate. Removal of accumulated sediment (> 10% pool volume) | Poor if vegetated (i.e. will not be able to remove/scrape accumulated sediments from surface) | High degree of serviceability necessary. Can be controlled through constructed dosing unit. High degree of control to ensure proper dosing. | Moderate. Weeding, erosion control, scour protection. Weeding and supplementary planting required | N/A - monitoring of effluent required |

ELLEN BROOK End-of-catchment treatment system

8.5 WATER QUANTITY

Water quantity modelling presented in Stage 1 was revisited based on the new, best practice river restoration concepts presented in this document. Assuming that the pools have 34.4 ML total storage, modelling shows that approximately 19% of all Ellen Brook average annual flows (1997) can be diverted to an NUA blend filter assuming the water is turned over/treated in a 24-hour period. This sets the flow rate to approximately 400 L/s, with higher flow rates achievable during high flow periods.

Figure 31 shows the diversion of 19% of the flows, highlighting that for most months of the year, excluding August and September, a large proportion of average daily Ellen Brook flow can be diverted to the NUA blend filter. Reliance on a dilution factor is therefore inappropriate and wetlands become essential for effluent polishing to an acceptable standard for discharge. As a result, the <u>diversion rate to an NUA blend filter is inherently controlled by the treatment capability and volumetric capacity of the wetlands and not the storage capacity of the pools.</u>

Assuming a total vegetated and unvegetated wetland surface area of 6 ha and a standard 72-hour detention time, the <u>maximum diversion rate to the wetlands is set at 7 ML/day or 81 L/s.</u> Optimisation is therefore required to achieve meaningful TP reductions and adequate wetland polishing/retention time. Note that a 72 hour retention time cannot reduce pH from 11 to background levels and MgO will either need to be omitted from the blend or a dosing system (e.g. HCI) will need to be integrated within the treatment train prior to effluent entering the wetland.

8.6 TREATMENT EFFICIENCY

8.6.1 Total Suspended Solids

TSS reduction is achieved within the pools through processes of temporary detention and reduction of flow velocities. Assessment of sediment capture efficiency was undertaken using the Fair and Geyer (1954) expression (Equation 1) to determine if the pools were adequately sized to target medium and coarse sediments.

$$R = 1 - \left(1 + \frac{1}{n} \frac{v_s}{Q/A}\right)^{-n}$$
 Equation 1

Where *R* represents the fraction of target sediment removed;

 v_s = settling velocity of target sediment (m/s);

Q / A = rate of applied flow (m3/s) divided by pool surface area (m2);

n = turbulence or short-circuiting parameter.

Assumptions included a target sediment size of >125 μ m (i.e. medium to coarse sediment) with a settling velocity of 11 mm/s operating at the 1 year ARI peak discharge of 14 m3/s. Calculations indicated that the pools are generally oversized and provide excellent sedimentation function, typically removing target sediment at 85% efficiency in the smallest pool (~4000 m²) and 93% in the largest (~7000 m²). Further calculations indicate a minimum removal rate of 50% for fine silt. Considering contaminant association with particulates, there is expected to be some particulate contaminant removal achieved within the pools. However, as a majority of N and P is in dissolved form significant nutrient reductions are unlikely.

8.6.2 Nutrients

As the preferred blend and contact time have not been ascertained, nutrient reduction modelling provided in this section is intended as a preliminary estimate only.

Based on the outcomes of water quantity modelling, TP and TN removal modelling was undertaken for a range of diversion rates between 7 ML/day to 35 ML/day. PTV2 nutrient removal efficiencies for a <u>passive</u> NUA blend arrangement were assumed, delivering maximum removal efficiencies of 86% for TP and 20% for TN (and DON). Note that the removal efficiencies for TN are significantly lower than those used Stage 1, and the long term N removal capacity of the passive system is currently unknown and requires further assessment.

Wetland nutrient removal efficiencies were calculated using Kadlec and Knight (1996) first order decay modelling assuming a K value of 18 m/year. Further assumptions included a maximum 6 ha wetland surface area and no groundwater interaction.

Table 7 shows the achievable TP reductions. With a sustainable diversion rate of 7 ML/day (i.e. 72-hour wetland retention time) a total TP reduction of 4.7% is achieved. Enhanced TP removal is achieved if the wetland detention time is compromised (i.e. < 72-hours). For example, a 35 ML/day diversion rate provides a 17.1% TP reduction. Additional investigations are required to optimise detention time and ensure sufficient polishing.

| | | | N | UA | Wetland | | Total | |
|-------------------------------|------------------|------------------------------|--------|----------------|---------|----------------|--------|----------------|
| Diversion Rate (ML/day) | GL/yr treated | %total flow (26.76 GL) | Tonnes | % reduction | Tonnes | % reduction | Tonnes | % reduction |
| 7 | 1.28 | 4.78% | 0.41 | 4.1% | 0.06 | 0.6% | 0.47 | 4.7% |
| 10 | 1.77 | 6.61% | 0.57 | 5.7% | 0.06 | 0.6% | 0.63 | 6.3% |
| 15 | 2.53 | 9.45% | 0.82 | 8.1% | 0.06 | 0.6% | 0.88 | 8.7% |
| 20 | 3.24 | 12.11% | 1.05 | 10.4% | 0.06 | 0.6% | 1.11 | 11.0% |
| 25 | 3.91 | 14.61% | 1.26 | 12.6% | 0.06 | 0.6% | 1.32 | 13.2% |
| 30 | 4.54 | 16.97% | 1.46 | 14.6% | 0.06 | 0.6% | 1.52 | 15.2% |
| 35 | 5.14 | 19.21% | 1.66 | 16.5% | 0.06 | 0.6% | 1.72 | 17.1% |

Table 7 Total phosphorus removal rates for passive NUA blend filter and end-ofcatchment wetland

Table 8 shows the achievable TN reductions. A 2.6% reduction was achieved for the 7 ML/day diversion increasing to 5.4% for 35 ML/day diversion. Note that diversion rates greater than 15 ML/day will compromise the ability for the wetland to reduce TN as a function of the reduced detention time. Optimising the detention time in the wetland will deliver limited benefits for TN removal and if enhanced TN removal is sought additional treatment train components will be required.

| Table 8 Total nitrogen removal rates for passive NUA blend filter and end-of-catchmer | It |
|---|----|
| wetland | |

| | | | N | IUA | We | tland | Total | | |
|-----------|---------|-------------|--------|-----------|--------|-----------|--------|-----------|--|
| Diversion | GL/vr | %total | | 9/ | | 0/_ | | 0/_ | |
| Rate | treated | flow (26.76 | Tonnes | reduction | Tonnes | reduction | Tonnes | reduction | |
| (ML/day) | | GL) | | | | | | | |
| 7 | 1.28 | 4.78% | 0.68 | 1.0% | 1.15 | 1.6% | 1.8 | 2.6% | |
| 10 | 1.77 | 6.61% | 0.94 | 1.3% | 1.22 | 1.7% | 2.2 | 3.0% | |
| 15 | 2.53 | 9.45% | 1.35 | 1.9% | 1.22 | 1.7% | 2.6 | 3.6% | |
| 20 | 3.24 | 12.11% | 1.73 | 2.4% | 1.20 | 1.7% | 2.9 | 4.1% | |
| 25 | 3.91 | 14.61% | 2.09 | 2.9% | 1.18 | 1.7% | 3.3 | 4.6% | |
| 30 | 4.54 | 16.97% | 2.42 | 3.4% | 1.15 | 1.6% | 3.6 | 5.0% | |
| 35 | 5.14 | 19.21% | 2.74 | 3.8% | 1.12 | 1.6% | 3.9 | 5.4% | |

8.7 OTHER NUTRIENT MANAGEMENT MEASURES

A number of other <u>commercially</u> available amendments may also be useful for application in place of, or combination with, the NUA blend filter. For example, PhoslockTM could be integrated with the end-of-catchment treatment train to deliver enhanced P removal. Local studies have shown >90% filterable reactive phosphorus reductions as a result of PhoslockTM application (Douglas *et al*, 1999). Similarly, Zeolite (ammonium adsorption) and ViroBond (heavy metal adsorption) could be integrated at particular stages of the treatment train where

appropriate. A brief literature review was conducted on the above amendments to identify the dominant processes (Table 9).

| | Phoslock™ | Zeolite | ViroBond |
|--------------------------------------|--|--|--|
| Purpose | Dissolved P removal Sediment derived P removal (prevents P release) | Ammonia (NH3) and ammonium (NH4+) removal | Copper removalChromium removal |
| Possible location/ application | Slurry/ dripper application within sedimentation pools | Filtration through granules/powder within wetlands. | Downstream of NUA filter in polishing basin. |
| Dominant chemical processes | P adsorption | NH3 and NH4+ adsorption | Heavy metal adsorption |
| Potential issues | Loss of Phoslock via flushing downstream during high flow events. Wetting/drying cycles – affect on P adsorption Reduction of pool storage capacity due to sediment accumulation | Low removal efficiencies in high flows/low contact time. Blanket application over wetlands may modify benthic environment and biological N and P removal. | Loss of ViroBond downstream during high flow events could modify benthic environment and biological N and P removal in wetlands. |
| Serviceability | Low to moderate depending on dripper/spray application and sediment removal from pools. | Low to moderate depending on replacement frequency. | Low to moderate depending on replacement frequency. |

| Table 9 Alternative com | mercially available am | nendments dominant processes |
|-------------------------|------------------------|------------------------------|
|-------------------------|------------------------|------------------------------|

CSIRO (Wendling *et al*, 2009a) research into a range of mining and industrial by-products for reuse as environmental amendments highlights potential use of other, non-commercially available amendments. It should be noted that the CSIRO research identified NUA as a preferred amendment and additional research would need to be undertaken for other non-commercial amendments.

Ultimately, as stipulated within the design criteria (Appendix 5), the end-of-catchment treatment system should form part of a suite of management actions implemented throughout the Ellen Brook catchment to address catchment wide nutrient management issues rather than solely relying on an end-of-catchment solution. Other management actions may include:

riparian revegetation, perennial pastures, fertiliser efficiency, landuse change controls, fertiliser action plans and soil amendments.

REFERENCES

9.0 **BIBLIOGRAPHY**

Archer, N. A., Quniton, J. N., & Hess, T. M. (2002). *Below ground relationships of soil texture, roots and hydraulic conductivity in two-phase mosaic vegetation in South-east Spain.* Journal of Arid Envrionments, Vol. 52, p 535-553.

Bouwer, H. (2002). *Artifical recharge of groundwater: hydrogeology and engineering.* Hydrogeology Journal, Vol. 10, p 121-142.

Bratieres, K., Fletcher, T., Deletic, A., Somes, N., & Woodcock, T. (2010). *Hydraulic and pollutant treatment performance of sand based filters*. Lyon, France: 7th Annual International Conference on Sustainable Techniques and Strategies in Urban Water Management.

Bratieres, K., Fletcher, T., Deletic, N., Somes, N., & Woodcock, T. (2010). *Hydraulic and pollutant treatment performance of sand based biofilters.* Lyon, France: 7th International Conference on Sustainable Techniques and Strategies in Urban Water Management.

ChemCentre. (2012). *Nutrient Filter Pilot Trial Ellen Brook.* Perth, Western Australia: ChemCentre for the Swan River Trust.

Connell, D. S. (2010). *Flora and vegetation survey, Lots 81 and 10865, Belhus.* Perth: Dr Stephen Connel for the Swan River Trust.

CSIRO Particle Analysis Service. (2012). NUA PTv2 PSD. Perth, Western Australia: CSIRO.

Department of Water and Swan River Trust. (2007). *Structural controls, Stormwater Management Manual for Western Australia.* Perth, Western Australia: Department of Water and Swan River Trust.

Department of Water. (2010). Scenario modelling for local water quality improvement plans in selected catchments of the Swan-Canning Estuary. Perth: Department of Water Water Science Branch Technical Series.

Douglas, G. B., Adeney, J. A., & Robb, M. (1999). *A novel technique for reducing bioavailable phosphorus in water and sediments.* Perth: CSIRO Land and Water Division ad Water and Rivers Commission.

Douglas, G., Shackleton, M., Wendling, L., & Klauber, C. (2011). *Investigation of an NUA-based filtration system for nutrient and dissolved organic carbon removal from Ellen Brook.* Perth: CSIRO National Research Flagships: Light Metals. Douglas, G., Wendling, L., Adney, J., Johnston, K., & Coleman, S. (2008). *Investigation of Trace Element and Radionuclide mobility in Amended Soils (Use of Neutralised Used Acid in Turf Farm Applications) Results from the Bullsbrook Turf Farm, WA.* CSIRO Water for a Healthy Country Flagship Report.

Engineers Australia. (2006). *Australian Runoff Quality - A guide to water sensitive urban design.* Crows Nest, New South Wales: Engineers Media.

Hatt, B., Fletcher, T. D., & Deletic, A. (2009). *Hydrologic and pollutant removal performance of stormwater biofiltration systems at the field scale.* Journal of Hydrology 365(3-4): 310-321.

Kadlec, R. H., & Wallace, S. D. (2009). *Treatment Wetlands: Second Edition.* Boca Raton, Florida: CRC Press.

Kelsey, P., Hall, J., Kitsios, A., Quinton, B., & Shakya, D. (2010). *Hydrological and nutrient modelling of the Swan-Canning coastal catchments.* Perth, Western Australia: Department of Water Water Science technical series.

Langergraber, G., Haberl, R., Laber, J., & Pressi, A. (2003). *Evaluation of substrate clogging processes in vertical flow constructed wetlands.* Water Science and Technology, 2003, Vol. 48(5), p 25-34.

Le Coustumer, S., Fletcher, T. D., Deletic, A., & Potter, M. (2008). *Hydraulic performance of biofilter systems for stormwater management: lessons from a field study.* Melbourne, Australia: FAWB.

Le Coustumer, S., Fletcher, T. D., Deletic, A., & Potter, M. (2008a). *Hydraulic performance of biofilter systems form stormwater management: lessons from a field study.* Melbourne: Monash University, Facility for Advancing Water Biofiltration.

Le Coustumer, S., Fletcher, T., Deletic, A., & Barraud, S. (2008). *Influence of time and design on the hydraulic performance of biofiltration systems for stormwater management.* Edinburgh, Scotland: 11th International Conference on Urban Drainage,.

Lewis, J. F., Hatt, B. E., Deletic, A., & Fletcher, T. D. (2008). *The impact of vegetation on the hydraulic conductivity of stormwater biofiltration systems.* Edinburgh, Scotland: 11th International Conference on Urban Drainage.

Melbourne Water. (2005). *WSUD Engineering Procedures: Stormwater.* Melbourne, Victoria: CSIRO Publishing.

Penn, L. J. (1999). *Managing our Rivers: A guide to the nature and management of the streams of south-west Western Australia.* Perth, Western Australia: Water and Rivers Commission.

Prefumo, J. (2011). *Swan River Trust Ellen Brook Fauna Assessment Report.* Perth: The Frog Doctor for Swan River Trust.

Swan River Trust. (2009). Swan Canning Water Quality Improvement Plan. Perth: Swan River Trust.

Wendling, L. A., & Douglas, G. B. (2009). *A review of mining and industrial by-product reuse as environmental amendments.* Perth: CSIRO Water for a Healthy Country series.

Wendling, L. (2011). *Geochemical modelling_SRT field trial 2011.* Perth, Western Australia: CSIRO.

Wendling, L., & Douglas, G. (2009a). *A Review of Mining and Industrial By-Product Reuse as Environmental Amendments.* CSIRO Water for a Health Country Flagship Report.

Wendling, L., Douglas, G., & Coleman, S. (2009b). *Characterisation of mining and industrial by-products with potential for use as environmental amendments.* CSIRO: Water for a Healthy Coountry National Research Flagship Report series.

Wendling, L., Douglas, G., Colemand, S., Yuan, Z., & Klauber, C. (2010). *Evaluation of Mining By-Products for the Removal of Nutrients and DOC from Ellen Brook Waters.* CSIRO Water for a Health Country Flagship Report series.

Wendling, L., Douglas, G., Petrone, K., & Coleman, S. (2009c). Best Management Practices: Investigation of Mineral-Based By-Products for the Attenuation of Nutrients and DOC in Surface WAters from the Swan Coastal Plain. CSIRO Water for a Healthy Country Flagship Report series.





DESCRIPTION: PTV1 & PTV2 Site Location



 PROJECT:
 Ellen Brook 1012
 FIGURE #: 1

 CLIENT:
 Swan River Trust
 DATE:
 23/01/12


























































| CLIENT : | SWAN RIVER TRUST | DRAWING : | SCHEMATIC DESIGN | DATE : | 18.01.2012 | |
|----------------|--|-------------------|------------------|----------|--------------|------------------|
| PROJECT : | FEASIBILITY STUDY & DESIGN FOR AN END OF CATCHMENT WETLAND TREATMENT SYSTEM - ELLEN BROOK | DRAWING NUMBER : | FIGURE 28 | SCALE : | 1:3,000 @ A2 | SYKINA |
| PROJECT NUMBER | : 1012 | DRAWING REFERENCE | : C10 | DRAWN BY | KG | environmental pl |



| CLIENT : | SWAN RIVER TRUST | DRAWING : | SCHEMATIC DESIGN | DATE : | 18.01.2012 | |
|------------------|--|-------------------|------------------|------------|--------------|------------------|
| PROJECT : | FEASIBILITY STUDY & DESIGN FOR AN END OF CATCHMENT WETLAND TREATMENT SYSTEM - ELLEN BROOK | DRAWING NUMBER : | FIGURE 29 | SCALE : | 1:2,500 @ A2 | SYKIN |
| PROJECT NUMBER : | 1012 | DRAWING REFERENCE | : C10 | DRAWN BY : | EB | environmental pl |



| CLIENT : | SWAN RIVER TRUST | DRAWING : | SCHEMATIC DESIGN | DATE : | 18.01.2012 | |
|----------------|--|-------------------|------------------|----------|------------|------------------|
| PROJECT : | FEASIBILITY STUDY & DESIGN FOR AN END OF CATCHMENT WETLAND TREATMENT SYSTEM - ELLEN BROOK | DRAWING NUMBER : | FIGURE 30 | SCALE : | NTS | SYRINA |
| PROJECT NUMBER | : 1012 | DRAWING REFERENCE | : C10 | DRAWN BY | KG | environmental pl |





APPENDIX 1 SUMMARY STATISTICS OF KEY ANALYTES FOR EACH TRIAL STATION

STATION NFSIN

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | Ν | Mann Kendall Statistic indicating |
|-------------------|----------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|-----------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | D# | increasing or decreasing trend |
| Temperature | °C | 14.33 | 29.27 | 14.94 | 4.99 | 25 | 19.8 | 3.496 | 6.992 | 12.22 | 17.66 | 0.008 | 0 | 0 | 164 |
| pH (field) | | 6.66 | 7.41 | 0.75 | 0.18 | 26 | 7 | 0.1597 | 0.3194 | 0.0255 | 2.28 | 0.00754 | 0 | 0 | -20 |
| DO | mg/L | 30.6 | 93.1 | 62.5 | 15.9 | 25 | 75.9 | 13.4 | 26.8 | 179.8 | 17.66 | 0.008 | 0 | 0 | -112 |
| TOC | mg/L | 55 | 67 | 12 | 5 | 24 | 60.5 | 2.99 | 5.98 | 8.95 | 4.95 | 0.0085 | 0 | 0 | -66 |
| TSS | mg/L | 1 | 8 | 7 | 2 | 24 | 4.65 | 1.75 | 3.5 | 3.06 | 36.24 | 0.00907 | 4 | 1 | 16 |
| El. Cond. | uS/cm | 455 | 569 | 114 | 22.75 | 26 | 497.4 | 20.94 | 41.88 | 438.7 | 4.21 | 0.00754 | 0 | 0 | -7 |
| Са | mg/L | 15.5 | 27.2 | 11.7 | 3.5 | 22 | 19.86 | 2.48 | 4.96 | 6.14 | 12.48 | 0.0097 | 0 | 0 | 80 |
| Mg | mg/L | 7.3 | 11.1 | 3.8 | 1.1 | 22 | 9.22 | 0.839 | 1.678 | 0.703 | 9.1 | 0.0097 | 0 | 0 | 50 |
| Na | mg/L | 46.1 | 69.5 | 23.4 | 9.33 | 22 | 56.2 | 6.4 | 12.8 | 40.95 | 11.38 | 0.0097 | 0 | 0 | 47 |
| К | mg/L | 7.3 | 11.5 | 4.2 | 1.405 | 22 | 9.04 | 0.99 | 1.98 | 0.98 | 10.95 | 0.0097 | 0 | 0 | 98 |
| CI | mg/L | 95 | 119 | 24 | 6 | 25 | 106 | 5.99 | 11.98 | 35.8 | 5.65 | 0.008 | 0 | 0 | 103 |
| Measured Alkalini | ity mg/L | 30 | 65 | 35 | 4 | 25 | 41.2 | 7.15 | 14.3 | 51.1 | 17.36 | 0.008 | 0 | 0 | 189 |
| SO4 | mg/L | 13.6 | 24.2 | 10.6 | 4.5 | 25 | 19.7 | 2.81 | 5.62 | 7.9 | 14.26 | 0.008 | 0 | 0 | -186 |
| F | mg/L | 0.05 | 0.24 | 0.19 | 0.03 | 25 | 0.0862 | 0.0546 | 0.1092 | 0.002976 | 49.6 | 0.0131 | 28 | 7 | -26 |
| SiO2 | mg/L | 3.7 | 13 | 9.3 | 4.4 | 25 | 7.95 | 2.74 | 5.48 | 7.5 | 34.46 | 0.008 | 0 | 0 | -1 |
| Sr | mg/L | 0.012 | 0.14 | 0.128 | 0.0175 | 22 | 0.1062 | 0.0241 | 0.0482 | 0.000581 | 22.7 | 0.0097 | 0 | 0 | 45 |
| Sulfide | mg/L | 0.06 | 3.5 | 3.44 | 0.39 | 25 | 0.2866 | 1.044 | 2.088 | 1.09 | 147.2 | 0.0316 | 60 | 15 | -10 |
| DOC | mg/L | 55 | 68 | 13 | 4.25 | 24 | 60.8 | 3.14 | 6.28 | 9.85 | 5.17 | 0.0085 | 0 | 0 | -45 |
| TN tot | mg/L | 2.2 | 3.3 | 1.1 | 0.4 | 25 | 2.67 | 0.29 | 0.58 | 0.084 | 10.86 | 0.008 | 0 | 0 | -56 |
| N_org | mg/L | 2 | 3.1 | 1.1 | 0.4 | 25 | 2.51 | 0.2914 | 0.5828 | 0.085 | 11.62 | 0.008 | 0 | 0 | -31 |
| NH3 | mg/L | 0.02 | 0.26 | 0.24 | 0.1 | 25 | 0.0726 | 0.0746 | 0.1492 | 0.00557 | 70.8 | 0.0274 | 56 | 14 | -18 |
| NO3 | mg/L | 0.01 | 0.05 | 0.04 | 0.025 | 25 | 0.0436 | 0.0175 | 0.035 | 0.0003067 | 75.1 | 0.068 | 76 | 19 | -2 |
| TP tot | mg/L | 0.66 | 1.1 | 0.44 | 0.12 | 25 | 0.848 | 0.0975 | 0.195 | 0.0095 | 11.5 | 0.008 | 0 | 0 | 51 |
| TP | mg/L | 0.2 | 0.83 | 0.63 | 0.25 | 25 | 0.574 | 0.172 | 0.344 | 0.0296 | 29.94 | 0.008 | 0 | 0 | -11 |
| Cr_VI | mg/L | N/A | N/A | N/A | 0 | 25 | < 0.0050 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 25 | 0 |
| Cesium | mg/L | 0.0001 | 0.0001 | 0 | 0 | 21 | 5.24E-05 | 0 | 0 | N/A | N/A | 1 | 95 | 20 | 0 |
| Aluminum | mg/L | 0.2 | 0.39 | 0.19 | 0.07 | 22 | 0.304 | 0.051 | 0.102 | 0.002597 | 16.76 | 0.0097 | 0 | 0 | -97 |
| Cobalt | mg/L | 0.0003 | 0.0004 | 0.0001 | 0.0001 | 21 | 0.000367 | 4.83E-05 | 9.66E-05 | 0 | 13.17 | 0.0104 | 0 | 0 | 16 |
| Chromium | mg/L | 0.0009 | 0.0012 | 0.0003 | 0.0001 | 22 | 0.001077 | 9.22E-05 | 0.000184 | 8.5E-09 | 8.56 | 0.0097 | 0 | 0 | -33 |
| Copper | mg/L | 0.0005 | 0.0021 | 0.0016 | 0.0003 | 21 | 0.000945 | 0.000337 | 0.000674 | 1.136E-07 | 34.04 | 0.01118 | 5 | 1 | -60 |
| Iron | mg/L | 0.81 | 1.2 | 0.39 | 0.115 | 22 | 0.964 | 0.111 | 0.222 | 0.01233 | 11.52 | 0.0097 | 0 | 0 | 37 |
| Manganese | mg/L | 0.01 | 0.061 | 0.051 | 0.0045 | 22 | 0.0155 | 0.01044 | 0.02088 | 0.000109 | 67.4 | 0.0097 | 0 | 0 | 43 |
| Molibdenum | mg/L | N/A | N/A | N/A | 0 | 21 | <0.0010 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 21 | 0 |
| Nickel | mg/L | 0.001 | 0.001 | 0 | 0 | 21 | 0.000571 | 0 | 0 | 0 | N/A | 0.1925 | 86 | 18 | 0 |
| Lead | mg/L | 0.0002 | 0.0006 | 0.0004 | 0.0001 | 21 | 0.000295 | 0.000102 | 0.000205 | 1.048E-08 | 34.7 | 0.0104 | 0 | 0 | -48 |
| Tin | mg/L | 0.0001 | 0.0007 | 0.0006 | 0.0003 | 21 | 0.000233 | 0.000186 | 0.000371 | 3.44E-08 | 67.1 | 0.01427 | 19 | 4 | 8 |
| Thorium | mg/L | 0.0002 | 0.0003 | 0.0001 | 0.0001 | 21 | 0.000243 | 5.07E-05 | 0.000101 | 0 | 20.9 | 0.0104 | 0 | 0 | 22 |
| Uranium | mg/L | N/A | N/A | N/A | 0 | 21 | <0.00010 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 21 | 0 |
| Vanadium | mg/L | 0.0016 | 0.0023 | 0.0007 | 0.0003 | 21 | 0.001952 | 0.000199 | 0.000398 | 3.96E-08 | 10.2 | 0.0104 | 0 | 0 | -102 |
| Zinc | mg/L | 0.005 | 0.015 | 0.01 | 0.002 | 22 | 0.00877 | 0.002202 | 0.004404 | 4.85E-06 | 25.1 | 0.0097 | 0 | 0 | -22 |

STATION AS1AOUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|------------------|---------------------------------------|----------------|----------------|----------------|-----------------|-----------|------------|------------------|------------|-----------------|--------------|----------|------------|--------|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 22 | 27.5 | 5.51 | 0.21 | 5 | 24.05 | 2.055 | 4.11 | 4.225 | 8.55 | 0.0894 | 0 | 0 | 0 |
| pH (field) | | 8.25 | 9.75 | 1.5 | 0.95 | 6 | 8.95 | 0.632 | 1.264 | 0.4 | 7.07 | 0.068 | 0 | 0 | -13 |
| DO | mg/L | 42.7 | 66.1 | 23.4 | 8.4 | 5 | 52.1 | 9.06 | 18.12 | 82 | 17.4 | 0.0894 | 0 | 0 | -2 |
| TOC | mg/L | 2.1 | 48 | 45.9 | 33.8 | 5 | 27.06 | 21.25 | 42.5 | 451.7 | 78.5 | 0.0894 | 0 | 0 | 6 |
| TSS | mg/L | 1 | 500 | 499 | 193 | 4 | 182.5 | 221.5 | 443 | 49045.7 | 121.3 | 0.125 | 0 | 0 | 4 |
| El. Cond. | uS/cm | 1320 | 2800 | 1480 | 437.5 | 6 | 2368.3 | 564 | 1128 | 318136.7 | 23.8 | 0.068 | 0 | 0 | -7 |
| Ca | mg/L | 486 | 617 | 131 | 65.5 | 3 | 567.3 | 71 | 142 | 5042.3 | 12.52 | 0.1925 | 0 | 0 | -3 |
| Mg | mg/L | 13 | 40.7 | 27.7 | 13.85 | 3 | 30.7 | 15.37 | 30.74 | 236.3 | 50.1 | 0.1925 | 0 | 0 | -1 |
| Na | mg/L | 49.1 | 62.6 | 13.5 | 6.75 | 3 | 54 | 7.45 | 14.9 | 55.5 | 13.78 | 0.1925 | 0 | 0 | 1 |
| К | mg/L | 9.95 | 10.2 | 0.25 | 0.125 | 3 | 10.08 | 0.1258 | 0.2516 | 0.01583 | 1.248 | 0.1925 | 0 | 0 | -1 |
| CI | mg/L | 97 | 116 | 19 | 10 | 5 | 106.2 | 7.7 | 15.4 | 59.2 | 7.24 | 0.0894 | 0 | 0 | 2 |
| Measured Alkalin | ity mg/L | 15 | 59 | 44 | 36 | 5 | 39.2 | 21 | 42 | 440.7 | 53.6 | 0.0894 | 0 | 0 | 8 |
| SO4 | mg/L | 427 | 1670 | 1243 | 330 | 5 | 1265.4 | 499 | 998 | 248985.8 | 39.4 | 0.0894 | 0 | 0 | -8 |
| F | mg/L | 0.15 | 0.47 | 0.32 | 0.26 | 5 | 0.3 | 0.1528 | 0.3056 | 0.02335 | 50.9 | 0.0894 | 0 | 0 | -6 |
| SiO2 | ma/L | 1.1 | 7.5 | 6.4 | 5.3 | 5 | 4.38 | 3 | 6 | 8.99 | 68.4 | 0.0894 | 0 | 0 | 6 |
| Sr | ma/L | 1.8 | 8.6 | 6.8 | 3.4 | 3 | 5.67 | 3.495 | 6.99 | 12.21 | 61.7 | 0.1925 | 0 | 0 | -1 |
| Sulfide | ma/L | 0.01 | 2.8 | 2.79 | 1.395 | 5 | 0.565 | 1.973 | 3.946 | 3.89 | 140.4 | 0.3536 | 60 | 3 | -1 |
| DOC | ma/l | 3.1 | 44 | 40.9 | 33.3 | 5 | 26.16 | 19.6 | 39.2 | 384.4 | 75 | 0.0894 | 0 | 0 | 6 |
| TN tot | ma/l | 0.37 | 2.5 | 2.13 | 1.21 | 5 | 1.512 | 0.893 | 1.786 | 0.798 | 59.1 | 0.0894 | 0 | 0 | 6 |
| N ora | ma/l | 0.12 | 2.4 | 2.28 | 1.55 | 5 | 1.314 | 0.988 | 1.976 | 0.976 | 75.2 | 0.0894 | 0 | 0 | 6 |
| NH3 | ma/l | 0.02 | 0.29 | 0.27 | 0.22 | 5 | 0.13 | 0.1294 | 0.2588 | 0.01675 | 99.6 | 0.0894 | 0 | 0 | -4 |
| NO3 | ma/l | 0.02 | 0.28 | 0.26 | 0.065 | 5 | 0.069 | 0.13 | 0.26 | 0.0169 | 152.9 | 0.125 | 20 | 1 | -3 |
| TP tot | ma/l | 0.02 | 0.17 | 0.15 | 0.105 | 5 | 0.081 | 0.0716 | 0.1432 | 0.00513 | 71.6 | 0.125 | 20 | 1 | 4 |
| TP | ma/l | 0.01 | 0.06 | 0.05 | 0.025 | 5 | 0.024 | 0.02517 | 0.05034 | 0.000633 | 68.6 | 0 1925 | 40 | 2 | 3 |
| Cr VI | ma/l | 0.015 | 0.027 | 0.012 | 0.006 | 5 | 0.0099 | 0.00849 | 0.01698 | 0.000072 | 40.4 | 0.3536 | 60 | 3 | -1 |
| <u>Cesium</u> | mg/L | 0.0001 | 0.0003 | 0.0002 | 0.0001 | 3 | 0.000233 | 0.000116 | 0.000231 | 1 333E-08 | 49.5 | 0 1925 | 0 | 0 | -2 |
| Aluminum | mg/L | 0.0001 | 0.032 | 0.027 | 0.0001 | 3 | 0.01467 | 0.01504 | 0.03008 | 0.0002263 | 102.6 | 0.1925 | 0 | 0 | |
| Cobalt | mg/L | 0.0005 | 0.0002 | 0.021 | 0.0100 | 3 | 0.0002 | 0.01001 | 0.00000 | N/A | N/A | 1 | 67 | 2 | |
| Chromium | mg/L | 0.0005 | 0.028 | 0.0275 | 0.01375 | 3 | 0.01583 | 0.01402 | 0.02804 | 0.0001966 | 88.6 | 0 1925 | 0 | 0 | -3 |
| Conner | mg/L | 0.0003 | 0.0008 | 0.0005 | 0.00025 | 3 | 0.000467 | 0.000289 | 0.000577 | 8 33E-08 | 61.9 | 0.1925 | 0 | 0 | -2 |
| Iron | mg/L | 0.0000 | 0.0000 | 0.0000 | 0.00020 | <u> </u> | 0.000407 | 0.000200 | 0.000077 | 0.002 00 N/A | N/A | 1 | 67 | 2 | 2 |
| Manganese | mg/L | 0.11 | 0.11 | 0 | 0 | 3 | 0.0000 | 0 | 0 | N/A | Ν/Δ | 1 | 67 | 2 | 0 |
| Malibdopum | mg/L | 0.04 | 0.04 | 0.002 | 0 001 | 3 | 0.01307 | 0.001/11/ | 0 002828 | 0.000002 | 35.36 | 0 3536 | 33 | 1 | 1 |
| Nickol | mg/L | 0.003 | 0.003 | 0.002 | 0.001 | 3 | 0.002000 | 0.001414 | 0.002020 | 0.000002 N/A | 55.50 N/A | 0.0000 | 67 | 2 | |
| | mg/L | 0.001 | 0.001 | 0 | 0 | 3 | 0.000007 | 0 | 0 | N/A | | 1 | 67 | 2 | 0 |
| Tin | mg/L | 0.0009 | 0.0009 | 0 0004 | 0 0002 | 3 | 0.000333 | 0 000283 | 0 000566 | | 04.3 | 0 3536 | 33 | 2 1 | |
| Thorium | ma/L | 0.0001 NI/A | 0.0003 NI/A | 0.0004 NI/A | 0.0002 | <u>ວ</u> | | 0.000203 NI/A | | | 94.3 NI/A | 0.3530 | 100 | ו 2 | -1 |
| | m m m m m m m m m m m m m m m m m m m | | | IN/A | | 3 | | IN/A | #VALUE! | IN/A | IN/A | IN/A | 100 | د ۱ | 0 |
| Vanadium | mg/L | 0.0003 | 0.0009 | 0.0006 | 0.0003 | 3 | 0.000417 | 0.000424 | 0.000648 | U NI/A | /U./ | 0.3330 | 33 | 1 | I |
| | mg/L | 0.0008 | 0.0008 | 0 000 | | 3 | 0.0003 | 0 001 | 0 000 | IN/A | | 0 4005 | 67 | 2 | 0 |
| ZINC | mg/L | 0.01 | 0.012 | 0.002 | 0.001 | 3 | 0.011 | 0.001 | 0.002 | 0.000001 | 9.1 | 0.1925 | 0 | 0 | -1 |

STATION AS1BOUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent ND | Mann Kendall Statistic indicating |
|---------------------|-------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|-----------|-------------|----------|--------------|-----------------------------------|
| | _ | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects # | increasing or decreasing trend |
| Temperature | °C | 22.34 | 30.8 | 8.46 | 1.595 | 6 | 25.2 | 2.95 | 5.9 | 8.72 | 11.72 | 0.068 | 0 0 | 5 |
| pH (field) | | 8.8 | 9.89 | 1.09 | 0.285 | 7 | 9.5 | 0.3616 | 0.7232 | 0.1308 | 3.8 | 0.054 | 0 0 | -9 |
| DO | mg/L | 25 | 36.4 | 11.4 | 6.75 | 6 | 30.6 | 4.74 | 9.48 | 22.45 | 15.5 | 0.068 | 0 0 | 4 |
| ТОС | mg/L | 1.2 | 25 | 23.8 | 13.4 | 5 | 14.96 | 9.87 | 19.74 | 97.3 | 66 | 0.0894 | 0 0 | 4 |
| TSS | mg/L | 7 | 180 | 173 | 86.5 | 4 | 48.9 | 99.6 | 199.2 | 9919 | 153.2 | 0.1925 | 25 1 | -1 |
| El. Cond. | uS/cm | 2190 | 2860 | 670 | 275 | 7 | 2578.6 | 231.1 | 462.2 | 53414.3 | 8.96 | 0.054 | 0 0 | -17 |
| Са | mg/L | 470 | 630 | 160 | 80 | 3 | 553.7 | 80.3 | 160.6 | 6440.3 | 14.5 | 0.1925 | 0 0 | -1 |
| Mg | mg/L | 14.7 | 67.3 | 52.6 | 26.3 | 3 | 36.9 | 27.24 | 54.48 | 742.1 | 73.8 | 0.1925 | 0 0 | -1 |
| Na | mg/L | 50.4 | 63.8 | 13.4 | 6.7 | 3 | 55.2 | 7.46 | 14.92 | 55.7 | 13.52 | 0.1925 | 0 0 | 3 |
| К | mg/L | 9.21 | 12.3 | 3.09 | 1.545 | 3 | 10.54 | 1.59 | 3.18 | 2.53 | 15.1 | 0.1925 | 0 0 | -1 |
| CI | mg/L | 100 | 116 | 16 | 8 | 5 | 108 | 6.44 | 12.88 | 41.5 | 5.96 | 0.0894 | 0 0 | 6 |
| Measured Alkalinity | /mg/L | 15 | 43 | 28 | 15 | 5 | 30.4 | 11.35 | 22.7 | 128.8 | 37.3 | 0.0894 | 0 0 | 4 |
| SO4 | mg/L | 1180 | 1830 | 650 | 240 | 5 | 1516 | 248.6 | 497.2 | 61780 | 16.4 | 0.0894 | 0 0 | -10 |
| F | mg/L | 0.23 | 0.62 | 0.39 | 0.1 | 5 | 0.336 | 0.1647 | 0.3294 | 0.02713 | 49 | 0.0894 | 0 0 | -6 |
| SiO2 | mg/L | 1 | 4.1 | 3.1 | 1 | 5 | 2.46 | 1.16 | 2.32 | 1.348 | 47.2 | 0.0894 | 0 0 | 4 |
| Sr | mg/L | 1.9 | 10 | 8.1 | 4.05 | 3 | 4.8 | 4.51 | 9.02 | 20.37 | 94 | 0.1925 | 0 0 | -3 |
| Sulfide | mg/L | 0.1 | 2.2 | 2.1 | 0.93 | 5 | 0.873 | 0.888 | 1.776 | 0.788 | 81.5 | 0.125 | 20 1 | -4 |
| DOC | mg/L | 1.4 | 28 | 26.6 | 14 | 5 | 16.08 | 10.77 | 21.54 | 116 | 67 | 0.0894 | 0 0 | 4 |
| TN_tot | mg/L | 0.72 | 1.4 | 0.68 | 0.55 | 5 | 1.022 | 0.313 | 0.626 | 0.098 | 30.63 | 0.0894 | 0 0 | -4 |
| N_org | mg/L | 0.02 | 0.83 | 0.81 | 0.31 | 5 | 0.472 | 0.314 | 0.628 | 0.0985 | 66.5 | 0.0894 | 0 0 | 8 |
| NH3 | mg/L | 0.05 | 0.29 | 0.24 | 0.08 | 5 | 0.134 | 0.0953 | 0.1906 | 0.00908 | 71.1 | 0.0894 | 0 0 | -2 |
| NO3 | mg/L | 0.01 | 0.89 | 0.88 | 0.44 | 5 | 0.188 | 0.502 | 1.004 | 0.2524 | 162.1 | 0.1925 | 40 2 | -3 |
| TP_tot | mg/L | 0.07 | 0.07 | 0 | 0 | 5 | 0.018 | 0 | 0 | N/A | N/A | 1 | 80 4 | 0 |
| TP | mg/L | 0.01 | 0.01 | 0 | 0 | 5 | 0.006 | 0 | 0 | N/A | N/A | 1 | 80 4 | 0 |
| Cr VI | mg/L | 0.063 | 0.063 | 0 | 0 | 5 | 0.0146 | 0 | 0 | N/A | N/A | 1 | 80 4 | 0 |
| Cesium | mg/L | 0.0001 | 0.0004 | 0.0003 | 0.00015 | 3 | 0.0002333 | 0.0001528 | 0.0003056 | 2.333E-08 | 65.5 | 0.1925 | 0 0 | -3 |
| Aluminum | mg/L | 0.014 | 0.014 | 0 | 0 | 3 | 0.00633 | 0 | 0 | N/A | N/A | 1 | 67 2 | 0 |
| Cobalt | mg/L | 0.0002 | 0.0004 | 0.0002 | 0.0001 | 3 | 0.0002167 | 0.0001414 | 0.0002828 | 0.0000002 | 47.1 | 0.3536 | 33 1 | 1 |
| Chromium | mg/L | 0.0006 | 0.066 | 0.0654 | 0.0327 | 3 | 0.0223 | 0.0462 | 0.0924 | 0.00214 | 138.9 | 0.3536 | 33 1 | -1 |
| Copper | mg/L | 0.0001 | 0.0015 | 0.0014 | 0.0007 | 3 | 0.0009 | 0.000721 | 0.001442 | 0 | 80.1 | 0.1925 | 0 0 | -1 |
| Iron | mg/L | 0.02 | 0.023 | 0.003 | 0.0015 | 3 | 0.01517 | 0.00212 | 0.00424 | 0.0000045 | 9.87 | 0.3536 | 33 1 | -1 |
| Manganese | mg/L | 0.002 | 0.013 | 0.011 | 0.0055 | 3 | 0.00517 | 0.00778 | 0.01556 | 0.0000605 | 103.7 | 0.3536 | 33 1 | 1 |
| Molibdenum | ma/L | 0.002 | 0.005 | 0.003 | 0.0015 | 3 | 0.0025 | 0.00212 | 0.00424 | 0.0000045 | 60.6 | 0.3536 | 33 1 | -1 |
| Nickel | mg/L | 0.002 | 0.002 | 0 | 0 | 3 | 0.001 | 0 | 0 | N/A | N/A | 1 | 67 2 | 0 |
| Lead | ma/L | 0.0001 | 0.0007 | 0.0006 | 0.0003 | 3 | 0.0002833 | 0.000424 | 0.000848 | 0 | 106.1 | 0.3536 | 33 1 | 1 |
| Tin | ma/L | 0.002 | 0.002 | 0 | 0 | 3 | 0.0007 | 0 | 0 | N/A | N/A | 1 | 67 2 | 0 |
| Thorium | ma/L | N/A | N/A | N/A | 0 | 3 | <0.00010 | N/A | #VALUE! | N/A | N/A | N/A | 100 3 | 0 |
| Uranium | ma/L | 0.0006 | 0.0014 | 0.0008 | 0.0004 | 3 | 0.000683 | 0.000566 | 0.001132 | 0.0000032 | 56.6 | 0.3536 | 33 1 | -1 |
| Vanadium | ma/L | 0.0005 | 0.0005 | 0 | 0 | 3 | 0.00035 | 0 | 0 | 0 | N/A | 0.3536 | 33 1 | 0 |
| Zinc | mg/L | 0.008 | 0.008 | 0 | 0 | 3 | 0.00433 | 0 | 0 | N/A | N/A | 1 | 67 2 | 0 |

STATION AS1OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent N | Mann Kendall Statistic indicating |
|---------------------|--------|---------|---------|-------------|-----------------|-----------|------------|-----------|------------|---|-------------|----------|---------------|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects D# | increasing or decreasing trend |
| Temperature | °C | 20.55 | 32.3 | 11.77 | 1.297 | 14 | 25.1 | 3.28 | 6.56 | 10.74 | 13.06 | 0.0191 | 0 0 | 25 |
| pH (field) | | 8.97 | 9.84 | 0.87 | 0.25 | 15 | 9.53 | 0.216 | 0.432 | 0.0467 | 2.267 | 0.0172 | 0 0 | 33 |
| DO | mg/L | 26.5 | 52.8 | 26.3 | 9.63 | 14 | 34.9 | 9.65 | 19.3 | 93.2 | 27.64 | 0.0191 | 0 0 | -11 |
| TOC | mg/L | 1.1 | 17 | 15.9 | 9.2 | 14 | 7.13 | 5.36 | 10.72 | 28.7 | 70.1 | 0.02133 | 7 1 | 37 |
| TSS | mg/L | 1 | 40 | 39 | 13 | 13 | 10.15 | 12.08 | 24.16 | 145.9 | 101.4 | 0.0274 | 15 2 | 3 |
| El. Cond. | uS/cm | n 2130 | 3360 | 1230 | 100 | 15 | 2732.7 | 256.8 | 513.6 | 65949.5 | 9.4 | 0.0172 | 0 0 | -80 |
| Са | mg/L | 520 | 645 | 125 | 43.5 | 12 | 592.8 | 33.24 | 66.48 | 1104.7 | 5.61 | 0.02406 | 0 0 | 23 |
| Mg | mg/L | 23.5 | 158 | 134.5 | 36.4 | 12 | 58.5 | 41.6 | 83.2 | 1727.8 | 71.1 | 0.02406 | 0 0 | -42 |
| Na | mg/L | 48.9 | 71.9 | 23 | 4.225 | 12 | 57.5 | 6.6 | 13.2 | 43.55 | 11.47 | 0.02406 | 0 0 | 23 |
| К | ma/L | 8.76 | 44.4 | 35.64 | 1.513 | 12 | 13.72 | 9.95 | 19.9 | 99 | 72.5 | 0.02406 | 0 0 | -19 |
| CI | ma/L | 56 | 116 | 60 | 8.75 | 14 | 102.6 | 15.3 | 30.6 | 234.6 | 14.92 | 0.0191 | 0 0 | 0 |
| Measured Alkalinity | ma/L | 15 | 35 | 20 | 11.5 | 14 | 21.43 | 6.7 | 13.4 | 44.9 | 31.26 | 0.0191 | 0 0 | 22 |
| SO4 | ma/L | 1470 | 2170 | 700 | 145 | 14 | 1675 | 190.2 | 380.4 | 36165.4 | 11.35 | 0.0191 | 0 0 | -59 |
| F | ma/L | 0.25 | 0.69 | 0.44 | 0.205 | 14 | 0.374 | 0.1484 | 0.2968 | 0.02203 | 39.65 | 0.0191 | 0 0 | -67 |
| SiO2 | ma/L | 0.9 | 2.2 | 1.3 | 0.775 | 14 | 1.507 | 0.48 | 0.96 | 0.23 | 31.8 | 0.0191 | 0 0 | 43 |
| Sr | ma/l | 2.5 | 11 | 8.5 | 5.85 | 12 | 6.53 | 3.1 | 6.2 | 9.6 | 47.4 | 0.02406 | 0 0 | -37 |
| Sulfide | ma/l | 0.12 | 1.2 | 1.08 | 0.998 | 14 | 0.291 | 0.545 | 1.09 | 0.2975 | 81.2 | 0.068 | 57 8 | 6 |
| DOC | ma/l | 11 | 16 | 14.9 | 10 43 | 14 | 7.56 | 5 57 | 11 14 | 31.05 | 73.7 | 0.0191 | 0 0 | 49 |
| TN tot | ma/l | 0.29 | 4.5 | 4 21 | 0.27 | 14 | 1 084 | 1 264 | 2 528 | 16 | 116.7 | 0.0191 | 0 0 | -9 |
| N org | ma/l | 0.06 | 0.82 | 0.76 | 0.38 | 14 | 0.3196 | 0 229 | 0 458 | 0 0524 | 66.6 | 0.02133 | 7 1 | |
| NH3 | ma/l | 0.07 | 0.44 | 0.37 | 0.1625 | 14 | 0.2036 | 0.1214 | 0.2428 | 0.01475 | 59.7 | 0.0191 | 0 0 | |
| NO3 | ma/l | 0.01 | 3.9 | 3.89 | 0.43 | 14 | 0.551 | 1.548 | 3.096 | 2,395 | 182.3 | 0.037 | 36 5 | -30 |
| TP tot | ma/l | 0.01 | 0.03 | 0.02 | 0.01 | 14 | 0.00714 | 0 01414 | 0.02828 | 0.0002 | 70.7 | 0.3536 | 86 12 | -1 |
| TP | ma/l | N/A | N/A | N/A | 0.01 | 14 | 0.00821 | N/A | #VALUE! | N/A | N/A | N/A | 100 14 | 0 |
| Cr VI | ma/l | 0.005 | 0.058 | 0.053 | 0 02925 | 14 | 0.0157 | 0.0215 | 0.043 | 0.0004615 | 64.4 | 0.068 | 57 8 | -10 |
| Cesium | ma/l | 0.0002 | 0,0006 | 0.0004 | 0.0001 | 11 | 0.0003 | 0.0001342 | 0.0002684 | 0.0001010 | 44 7 | 0.0274 | 0 0 | -27 |
| Aluminum | ma/l | 0.005 | 0.007 | 0.002 | 0.0015 | 12 | 0.00425 | 0.000894 | 0.001788 | 0 000008 | 14.9 | 0.068 | 50 6 | 8 |
| Cohalt | ma/l | 0.0001 | 0.0003 | 0.002 | 0.001 | 11 | 0.000120 | 0.0000894 | 0.0001788 | 0.00000008 | 55.9 | 0.0894 | 55 6 | 7 |
| Chromium | ma/l | 0.0001 | 0.064 | 0.0608 | 0.0001 | 12 | 0.0001 | 0.0000004 | 0.04654 | 0.0000000000000000000000000000000000000 | 87.1 | 0.0004 | 33 4 | -20 |
| Copper | ma/l | 0.0002 | 0.0008 | 0.0007 | 0.0010 | 11 | 0.0004 | 0.000254 | 0.000508 | 6 44F-08 | 53.1 | 0.037 | 18 2 | -2 |
| Iron | ma/l | 0.0001 | 0.0000 | 0.0007 | 0.0004 | 12 | 0.0004 | 0.000204 | 0.000000 | N/A | N/A | 0.007 | 92 11 | 2 |
| Manganese | mg/L | 0.003 | 0.000 | 0.025 | 0.0125 | 12 | 0.00004 | 0.01365 | 0.0273 | 0.0001863 | 120.4 | 0 1925 | 75 9 | <u></u> |
| Molibdenum | mg/L | 0.002 | 0.027 | 0.020 | 0.0120 | 11 | 0.00021 | 0.01000 | 0.0270 | 0.0001000 | 27.07 | 0.1320 | 10 0 | |
| Nickol | mg/L | 0.002 | 0.003 | 0.003 | 0.0013 | 11 | 0.00575 | 0.00101 | 0.00202 | N/A | N/A | 0.0274 | 0 0 | -15 |
| | mg/L | 0.001 | 0.007 | 0 2000 0 | 0 0003 | 11 | 0.000343 | 0 000258 | 0.000516 | 6.67E-08 | 64.5 | 0 125 | 64 7 | 0 |
| Tin | mg/L | 0.0001 | 0.0007 | 0.0000 | 0.0003 | 11 | 0.0001773 | 0.000230 | 0.000310 | 2 667E 09 | 61.2 | 0.123 | 45 5 | 10 |
| Thorium | mg/L | 0.0001 | 0.0003 | 0.0004 | 0.00025 | 11 | 0.0001002 | 0.0001033 | 0.0003200 | 2.007 L-00 | NI/A | 0.000 | <u>40</u> 0 | -10 |
| | mg/L | 0.0001 | 0.0001 | 0 0017 | 0 0003 | 11 | 0.0000091 | 0 000700 | 0.001/19 | 0 | 106 6 | 0.3330 | 02 9 55 6 | 0 |
| Vanadium | mg/L | 0.0001 | 0.0010 | 0.0017 | 0.0003 | 11 | 0.000202 | 0.000709 | 0.001410 | 0.17E.00 | 20.46 | 0.0094 | 64 7 | -3 |
| Valiauluili Zina | mg/L | 0.0002 | 0.0004 | 0.0002 | 0.000120 | 11 | 0.00013 | 0.000937 | 0.0001914 | 9.17 E-09 | 29.40 | 0.120 | <u> </u> | 5 |
| ZINC | iiig/L | 0.006 | 0.022 | 0.016 | 0.0015 | IZ | 0.00592 | 0.00025 | 0.0125 | 0.0000391 | 0/ | 0.008 | 50 6 | 1 |

STATION AS2AOUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|---------------------|-------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|-----------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 22.57 | 29.16 | 6.59 | 1.723 | 4 | 24.6 | 3.06 | 6.12 | 9.36 | 12.44 | 0.125 | 0 | 0 | 2 |
| pH (field) | | 8.86 | 10.13 | 1.27 | 0.61 | 5 | 9.44 | 0.501 | 1.002 | 0.251 | 5.31 | 0.0894 | 0 | 0 | -8 |
| DO | mg/L | 44.4 | 62.2 | 17.8 | 4.975 | 4 | 55.5 | 7.7 | 15.4 | 59.2 | 13.87 | 0.125 | 0 | 0 | 4 |
| TOC | mg/L | 1.6 | 48 | 46.4 | 28.8 | 4 | 21.68 | 21.43 | 42.86 | 459.2 | 98.9 | 0.125 | 0 | 0 | 4 |
| TSS | mg/L | 1 | 49 | 48 | 24 | 3 | 27 | 24.25 | 48.5 | 588 | 89.8 | 0.1925 | 0 | 0 | 1 |
| El. Cond. | uS/cm | 984 | 2770 | 1786 | 90 | 5 | 2348.8 | 765 | 1530 | 585237.2 | 32.6 | 0.0894 | 0 | 0 | -6 |
| Ca | mg/L | 117 | 612 | 495 | 247.5 | 3 | 446.7 | 285.5 | 571 | 81510.3 | 63.9 | 0.1925 | 0 | 0 | -1 |
| Mg | mg/L | 16.2 | 35.2 | 19 | 9.5 | 3 | 26.8 | 9.69 | 19.38 | 93.9 | 36.15 | 0.1925 | 0 | 0 | -1 |
| Na | mg/L | 49.7 | 61.5 | 11.8 | 5.9 | 3 | 53.7 | 6.76 | 13.52 | 45.6 | 12.58 | 0.1925 | 0 | 0 | 1 |
| К | mg/L | 9.89 | 10.2 | 0.31 | 0.155 | 3 | 10.02 | 0.1626 | 0.3252 | 0.02643 | 1.623 | 0.1925 | 0 | 0 | 1 |
| CI | mg/L | 99 | 115 | 16 | 13 | 4 | 106.5 | 8.19 | 16.38 | 67 | 7.69 | 0.125 | 0 | 0 | 4 |
| Measured Alkalinity | mg/L | 15 | 69 | 54 | 37.5 | 4 | 38 | 26.04 | 52.08 | 678 | 68.5 | 0.125 | 0 | 0 | 4 |
| SO4 | mg/L | 266 | 1610 | 1344 | 396 | 4 | 1254 | 659.7 | 1319.4 | 435264 | 52.6 | 0.125 | 0 | 0 | -5 |
| F | mg/L | 0.14 | 0.44 | 0.3 | 0.135 | 4 | 0.275 | 0.128 | 0.256 | 0.01637 | 46.5 | 0.125 | 0 | 0 | -4 |
| SiO2 | mg/L | 1.1 | 5.9 | 4.8 | 3.825 | 4 | 3.325 | 2.434 | 4.868 | 5.92 | 73.2 | 0.125 | 0 | 0 | 4 |
| Sr | mg/L | 0.5 | 9 | 8.5 | 4.25 | 3 | 5.17 | 4.31 | 8.62 | 18.6 | 83.4 | 0.1925 | 0 | 0 | -1 |
| Sulfide | mg/L | 0.45 | 5.2 | 4.75 | 2.375 | 4 | 1.63 | 2.63 | 5.26 | 6.93 | 121.3 | 0.1925 | 25 | 1 | -1 |
| DOC | mg/L | 2.3 | 48 | 45.7 | 29.7 | 4 | 21.98 | 21.47 | 42.94 | 460.7 | 97.7 | 0.125 | 0 | 0 | 4 |
| TN tot | mg/L | 0.34 | 2 | 1.66 | 0.91 | 4 | 1.12 | 0.732 | 1.464 | 0.535 | 65.3 | 0.125 | 0 | 0 | 4 |
| N org | mg/L | 0.09 | 2 | 1.91 | 0.973 | 4 | 0.958 | 0.831 | 1.662 | 0.691 | 86.8 | 0.125 | 0 | 0 | 4 |
| NH3 | mg/L | 0.04 | 0.25 | 0.21 | 0.18 | 4 | 0.145 | 0.1103 | 0.2206 | 0.01217 | 76.1 | 0.125 | 0 | 0 | -2 |
| NO3 | mg/L | 0.02 | 0.14 | 0.12 | 0.06 | 4 | 0.0513 | 0.0643 | 0.1286 | 0.00413 | 96.4 | 0.1925 | 25 | 1 | -1 |
| TP tot | mg/L | 0.01 | 0.32 | 0.31 | 0.155 | 4 | 0.0938 | 0.171 | 0.342 | 0.02923 | 138.6 | 0.1925 | 25 | 1 | 1 |
| TP | mg/L | 0.01 | 0.24 | 0.23 | 0.115 | 4 | 0.065 | 0.1626 | 0.3252 | 0.02645 | 130.1 | 0.3536 | 50 | 2 | 1 |
| Cr VI | mg/L | 0.022 | 0.025 | 0.003 | 0.0015 | 4 | 0.013 | 0.00212 | 0.00424 | 0.0000045 | 9.03 | 0.3536 | 50 | 2 | -1 |
| Cesium | mg/L | 0.0001 | 0.0003 | 0.0002 | 0.0001 | 3 | 0.0002 | 0.0001 | 0.0002 | 0.0000001 | 50 | 0.1925 | 0 | 0 | -1 |
| Aluminum | mg/L | 0.076 | 0.076 | 0 | 0 | 3 | 0.027 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Cobalt | mg/L | 0.0006 | 0.0006 | 0 | 0 | 3 | 0.000233 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Chromium | mg/L | 0.0009 | 0.027 | 0.0261 | 0.01305 | 3 | 0.0183 | 0.01507 | 0.03014 | 0.000227 | 82.3 | 0.1925 | 0 | 0 | -2 |
| Copper | mg/L | 0.0007 | 0.0016 | 0.0009 | 0.00045 | 3 | 0.000783 | 0.000636 | 0.001272 | 0 | 55.3 | 0.3536 | 33 | 1 | 1 |
| Iron | mg/L | 0.23 | 0.23 | 0 | 0 | 3 | 0.0783 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Manganese | mg/L | 0.011 | 0.011 | 0 | 0 | 3 | 0.004 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Molibdenum | mg/L | 0.003 | 0.005 | 0.002 | 0.001 | 3 | 0.002833 | 0.001414 | 0.002828 | 0.000002 | 35.36 | 0.3536 | 33 | 1 | 1 |
| Nickel | mg/L | 0.002 | 0.002 | 0 | 0 | 3 | 0.001 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Lead | mg/L | 0.0002 | 0.0024 | 0.0022 | 0.0011 | 3 | 0.000883 | 0.001556 | 0.003112 | 0 | 119.7 | 0.3536 | 33 | 1 | -1 |
| Tin | mg/L | 0.0002 | 0.0002 | 0 | 0 | 3 | 0.0001 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Thorium | mg/L | 0.0001 | 0.0001 | 0 | 0 | 3 | 6.67E-05 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Uranium | mg/L | 0.0005 | 0.0005 | 0 | 0 | 3 | 0.0002 | 0 | 01 | N/A | N/A | 1 | 67 | 2 | 0 |
| Vanadium | mg/L | 0.0011 | 0.0011 | 0 | 0 | 3 | 0.0004 | 0 | 01 | N/A | N/A | 1 | 67 | 2 | 0 |
| Zinc | mg/L | 0.046 | 0.046 | 0 | 0 | 3 | 0.017 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |

STATION AS2BOUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|-------------------|---------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|------------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 24 | 29 | 5.02 | 1.998 | 4 | 25.5 | 2.374 | 4.748 | 5.64 | 9.3 | 0.125 | 0 | 0 | 2 |
| pH (field) | | 9.17 | 10.1 | 0.93 | 0.23 | 5 | 9.72 | 0.3474 | 0.6948 | 0.1207 | 3.575 | 0.0894 | 0 | 0 | -8 |
| DO | mg/L | 19.1 | 54.4 | 35.3 | 11.38 | 4 | 32 | 15.47 | 30.94 | 239.4 | 48.3 | 0.125 | 0 | 0 | 4 |
| TOC | mg/L | 3.6 | 32 | 28.4 | 14.2 | 4 | 11.05 | 15.26 | 30.52 | 233 | 104.8 | 0.1925 | 25 | 1 | 3 |
| TSS | mg/L | 5 | 24 | 19 | 9.5 | 3 | 13 | 9.85 | 19.7 | 97 | 75.8 | 0.1925 | 0 | 0 | -1 |
| El. Cond. | uS/cm | 1840 | 2780 | 940 | 110 | 5 | 2552 | 401.1 | 802.2 | 160870 | 15.72 | 0.0894 | 0 | 0 | -6 |
| Ca | mg/L | 374 | 638 | 264 | 132 | 3 | 542 | 146 | 292 | 21312 | 26.93 | 0.1925 | 0 | 0 | -1 |
| Mg | mg/L | 23.1 | 49.4 | 26.3 | 13.15 | 3 | 36 | 13.16 | 26.32 | 173.1 | 36.5 | 0.1925 | 0 | 0 | -3 |
| Na | mg/L | 50.8 | 62.7 | 11.9 | 5.95 | 3 | 55 | 6.68 | 13.36 | 44.6 | 12.14 | 0.1925 | 0 | 0 | 3 |
| К | mg/L | 9.77 | 11.2 | 1.43 | 0.715 | 3 | 10.62 | 0.754 | 1.508 | 0.569 | 7.1 | 0.1925 | 0 | 0 | -1 |
| CI | mg/L | 100 | 113 | 13 | 8.5 | 4 | 106 | 6.06 | 12.12 | 36.7 | 5.71 | 0.125 | 0 | 0 | 4 |
| Measured Alkalini | ty mg/L | 15 | 50 | 35 | 12.5 | 4 | 26.5 | 16 | 32 | 256.3 | 60.4 | 0.125 | 0 | 0 | 6 |
| SO4 | mg/L | 913 | 1710 | 797 | 206.8 | 4 | 1463.3 | 369.6 | 739.2 | 136588.9 | 25.26 | 0.125 | 0 | 0 | -6 |
| F | mg/L | 0.21 | 0.45 | 0.24 | 0.18 | 4 | 0.345 | 0.119 | 0.238 | 0.01417 | 34.5 | 0.125 | 0 | 0 | -6 |
| SiO2 | mg/L | 1 | 3.6 | 2.6 | 1.1 | 4 | 1.85 | 1.207 | 2.414 | 1.457 | 65.2 | 0.125 | 0 | 0 | 6 |
| Sr | mg/L | 1.5 | 9.9 | 8.4 | 4.2 | 3 | 6.03 | 4.24 | 8.48 | 17.97 | 70.3 | 0.1925 | 0 | 0 | -3 |
| Sulfide | mg/L | 0.39 | 4.6 | 4.21 | 2.105 | 4 | 1.386 | 2.386 | 4.772 | 5.69 | 129.2 | 0.1925 | 25 | 1 | -3 |
| DOC | mg/L | 1.3 | 34 | 32.7 | 11.63 | 4 | 11.98 | 15 | 30 | 224.7 | 125.2 | 0.125 | 0 | 0 | 6 |
| TN_tot | mg/L | 0.35 | 1.4 | 1.05 | 0.66 | 4 | 0.905 | 0.481 | 0.962 | 0.2318 | 53.2 | 0.125 | 0 | 0 | 2 |
| N_org | mg/L | 0.17 | 1.3 | 1.13 | 0.365 | 4 | 0.54 | 0.515 | 1.03 | 0.2655 | 95.4 | 0.125 | 0 | 0 | 4 |
| NH3 | mg/L | 0.14 | 0.26 | 0.12 | 0.0525 | 4 | 0.1825 | 0.0544 | 0.1088 | 0.00296 | 29.8 | 0.125 | 0 | 0 | 2 |
| NO3 | mg/L | 0.01 | 0.78 | 0.77 | 0.385 | 4 | 0.2063 | 0.439 | 0.878 | 0.1926 | 160.6 | 0.1925 | 25 | 1 | -1 |
| TP_tot | mg/L | 0.01 | 0.07 | 0.06 | 0.03 | 4 | 0.0225 | 0.0424 | 0.0848 | 0.0018 | 106.1 | 0.3536 | 50 | 2 | 1 |
| TP | mg/L | 0.01 | 0.01 | 0 | 0 | 4 | 0.00625 | 0 | 0 | N/A | N/A | 1 | 75 | 3 | 0 |
| Cr_VI | mg/L | 0.015 | 0.057 | 0.042 | 0.021 | 4 | 0.01925 | 0.0297 | 0.0594 | 0.000882 | 82.5 | 0.3536 | 50 | 2 | -1 |
| Cesium | mg/L | 0.0001 | 0.0003 | 0.0002 | 0.0001 | 3 | 0.000233 | 0.000116 | 0.000231 | 1.333E-08 | 49.5 | 0.1925 | 0 | 0 | -2 |
| Aluminum | mg/L | 0.01 | 0.01 | 0 | 0 | 3 | 0.005 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Cobalt | mg/L | 0.0004 | 0.0004 | 0 | 0 | 3 | 0.000167 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Chromium | mg/L | 0.0006 | 0.063 | 0.0624 | 0.0312 | 3 | 0.0272 | 0.0322 | 0.0644 | 0.001037 | 118.4 | 0.1925 | 0 | 0 | -3 |
| Copper | mg/L | 0.0003 | 0.0017 | 0.0014 | 0.0007 | 3 | 0.000833 | 0.000757 | 0.001514 | 5.73E-07 | 90.9 | 0.1925 | 0 | 0 | 3 |
| Iron | mg/L | 0.028 | 0.028 | 0 | 0 | 3 | 0.011 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Manganese | mg/L | 0.009 | 0.009 | 0 | 0 | 3 | 0.00333 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Molibdenum | mg/L | 0.001 | 0.005 | 0.004 | 0.002 | 3 | 0.003333 | 0.00208 | 0.00416 | 0.00000433 | 62.4 | 0.1925 | 0 | 0 | -3 |
| Nickel | mg/L | 0.002 | 0.002 | 0 | 0 | 3 | 0.001 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Lead | mg/L | 0.0004 | 0.0004 | 0 | 0 | 3 | 0.000167 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Tin | mg/L | 0.0001 | 0.0003 | 0.0002 | 0.0001 | 3 | 0.00015 | 0.000141 | 0.000283 | 0.0000002 | 70.7 | 0.3536 | 33 | 1 | 1 |
| Thorium | mg/L | N/A | N/A | N/A | 0 | 3 | < 0.00010 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 3 | 0 |
| Uranium | mg/L | 0.0008 | 0.0008 | 0 | 0 | 3 | 0.0003 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Vanadium | mg/L | 0.0005 | 0.0005 | 0 | 0 | 3 | 0.0002 | 0 | 0 | N/A | N/A | 1 | 67 | 2 | 0 |
| Zinc | mg/L | 0.006 | 0.011 | 0.005 | 0.0025 | 3 | 0.0065 | 0.003536 | 0.007072 | 0.0000125 | 41.6 | 0.3536 | 33 | 1 | 1 |

STATION AS2OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|---------------------|-------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|-----------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 20.13 | 30.6 | 10.5 | 2.28 | 13 | 24.8 | 2.833 | 5.666 | 8.03 | 11.41 | 0.02133 | 0 | 0 | 30 |
| pH (field) | | 9.08 | 9.96 | 0.88 | 0.26 | 14 | 9.62 | 0.218 | 0.436 | 0.0475 | 2.265 | 0.0191 | 0 | 0 | -3 |
| DO | mg/L | 23.2 | 66.5 | 43.3 | 10.6 | 13 | 37.45 | 12.17 | 24.34 | 148.2 | 32.5 | 0.02133 | 0 | 0 | -12 |
| TOC | mg/L | 1.1 | 20 | 18.9 | 5.35 | 13 | 5.78 | 6.71 | 13.42 | 45.1 | 99.5 | 0.0274 | 15 | 2 | 26 |
| TSS | mg/L | 1 | 39 | 38 | 26 | 12 | 15.38 | 15.3 | 30.6 | 234.2 | 91.5 | 0.0274 | 8 | 1 | 9 |
| El. Cond. | uS/cn | 2380 | 3150 | 770 | 72.5 | 14 | 2720 | 177.5 | 355 | 31492.3 | 6.52 | 0.0191 | 0 | 0 | -64 |
| Ca | mg/L | 525 | 638 | 113 | 58.3 | 12 | 590.3 | 36.14 | 72.28 | 1305.9 | 6.12 | 0.02406 | 0 | 0 | 8 |
| Mg | mg/L | 27.6 | 115 | 87.4 | 28.6 | 12 | 48.8 | 28.55 | 57.1 | 815.1 | 58.5 | 0.02406 | 0 | 0 | -37 |
| Na | mg/L | 50.6 | 74.9 | 24.3 | 8.3 | 12 | 59.2 | 7.54 | 15.08 | 56.8 | 12.73 | 0.02406 | 0 | 0 | 17 |
| К | mg/L | 9.14 | 41.4 | 32.26 | 1.865 | 12 | 13.87 | 9.06 | 18.12 | 82.1 | 65.3 | 0.02406 | 0 | 0 | -23 |
| CI | mg/L | 97 | 142 | 45 | 15 | 13 | 109.8 | 12.44 | 24.88 | 154.8 | 11.33 | 0.02133 | 0 | 0 | 13 |
| Measured Alkalinity | mg/L | 15 | 34 | 19 | 6 | 13 | 20.08 | 6.8 | 13.6 | 46.2 | 33.9 | 0.02133 | 0 | 0 | 19 |
| SO4 | mg/L | 1320 | 1920 | 600 | 150 | 13 | 1611.5 | 154.7 | 309.4 | 23947.4 | 9.6 | 0.02133 | 0 | 0 | -44 |
| F | mg/L | 0.2 | 0.81 | 0.61 | 0.23 | 13 | 0.366 | 0.1817 | 0.3634 | 0.033 | 49.6 | 0.02133 | 0 | 0 | -44 |
| SiO2 | mg/L | 0.8 | 2.7 | 1.9 | 0.5 | 13 | 1.446 | 0.588 | 1.176 | 0.346 | 40.7 | 0.02133 | 0 | 0 | 44 |
| Sr | mg/L | 2.2 | 11 | 8.8 | 2.975 | 12 | 6.63 | 3.003 | 6.006 | 9.02 | 45.3 | 0.02406 | 0 | 0 | -43 |
| Sulfide | mg/L | 0.03 | 2 | 1.97 | 1.41 | 13 | 0.606 | 0.739 | 1.478 | 0.546 | 84.6 | 0.037 | 31 | 4 | -14 |
| DOC | mg/L | 1.1 | 20 | 18.9 | 5.78 | 13 | 6.12 | 6.7 | 13.4 | 44.9 | 101.8 | 0.02406 | 8 | 1 | 33 |
| TN_tot | mg/L | 0.29 | 4.1 | 3.81 | 0.57 | 13 | 1.06 | 1.228 | 2.456 | 1.51 | 115.8 | 0.02133 | 0 | 0 | -3 |
| N_org | mg/L | 0.07 | 1.2 | 1.13 | 0.59 | 13 | 0.3985 | 0.357 | 0.714 | 0.1274 | 89.6 | 0.02133 | 0 | 0 | 21 |
| NH3 | mg/L | 0.03 | 0.38 | 0.35 | 0.11 | 13 | 0.1985 | 0.0979 | 0.1958 | 0.00958 | 49.3 | 0.02133 | 0 | 0 | 17 |
| NO3 | mg/L | 0.01 | 2.8 | 2.79 | 0.61 | 13 | 0.444 | 1.084 | 2.168 | 1.175 | 169.6 | 0.037 | 31 | 4 | -26 |
| TP_tot | mg/L | 0.02 | 0.02 | 0 | 0 | 13 | 0.00615 | 0 | 0 | N/A | N/A | 1 | 92 | 12 | 0 |
| TP | mg/L | N/A | N/A | N/A | 0 | 13 | 0.00846 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 13 | 0 |
| Cr_VI | mg/L | 0.006 | 0.067 | 0.061 | 0.03225 | 13 | 0.0195 | 0.0224 | 0.0448 | 0.000503 | 74.4 | 0.0442 | 38 | 5 | -19 |
| Cesium | mg/L | 0.0002 | 0.0006 | 0.0004 | 0.00005 | 11 | 0.000318 | 0.000125 | 0.00025 | 1.564E-08 | 39.3 | 0.0274 | 0 | 0 | -33 |
| Aluminum | mg/L | 0.005 | 0.01 | 0.005 | 0.0025 | 12 | 0.003625 | 0.002646 | 0.005292 | 0.000007 | 37.8 | 0.1925 | 75 | 9 | 1 |
| Cobalt | mg/L | 0.0001 | 0.0003 | 0.0002 | 0.0001 | 11 | 8.18E-05 | 0.000116 | 0.000231 | 1.333E-08 | 69.3 | 0.1925 | 73 | 8 | 2 |
| Chromium | mg/L | 0.0012 | 0.082 | 0.0808 | 0.0346 | 12 | 0.02344 | 0.0276 | 0.0552 | 0.000763 | 98.3 | 0.0316 | 17 | 2 | -39 |
| Copper | mg/L | 0.0001 | 0.0012 | 0.0011 | 0.0004 | 11 | 0.000327 | 0.000344 | 0.000689 | 1.186E-07 | 88.6 | 0.037 | 18 | 2 | -9 |
| Iron | mg/L | 0.006 | 0.023 | 0.017 | 0.0085 | 12 | 0.0045 | 0.01202 | 0.02404 | 0.0001445 | 82.9 | 0.3536 | 83 | 10 | -1 |
| Manganese | mg/L | 0.002 | 0.021 | 0.019 | 0.0095 | 12 | 0.002333 | 0.01344 | 0.02688 | 0.0001805 | 116.8 | 0.3536 | 83 | 10 | 1 |
| Molibdenum | mg/L | 0.002 | 0.006 | 0.004 | 0.0015 | 11 | 0.00382 | 0.00125 | 0.0025 | 1.564E-06 | 32.75 | 0.0274 | 0 | 0 | -28 |
| Nickel | mg/L | 0.001 | 0.001 | 0 | 0 | 11 | 0.000545 | 0 | 0 | N/A | N/A | 1 | 91 | 10 | 0 |
| Lead | mg/L | 0.0001 | 0.0019 | 0.0018 | 0.000075 | 11 | 0.000286 | 0.000697 | 0.001394 | 4.86E-07 | 144.2 | 0.068 | 45 | 5 | 2 |
| Tin | mg/L | 0.0001 | 0.0007 | 0.0006 | 0.0003 | 11 | 0.000173 | 0.000249 | 0.000498 | 0 | 77.8 | 0.0894 | 55 | 6 | -5 |
| Thorium | mg/L | N/A | N/A | N/A | 0 | 11 | < 0.00010 | N/A | #VALUE! | N/A | N/A | N/A | 100 | 11 | 0 |
| Uranium | mg/L | 0.0004 | 0.0024 | 0.002 | 0.001 | 11 | 0.000296 | 0.001414 | 0.002828 | 0.000002 | 101 | 0.3536 | 82 | 9 | -1 |
| Vanadium | mg/L | 0.0002 | 0.0005 | 0.0003 | 0.00015 | 11 | 0.000127 | 0.000153 | 0.000306 | 2.333E-08 | 45.8 | 0.1925 | 73 | 8 | 3 |
| Zinc | mg/L | 0.005 | 0.006 | 0.001 | 0.00025 | 12 | 0.00358 | 0.0005 | 0.001 | 0.0000025 | 8.7 | 0.125 | 67 | 8 | 3 |

STATION PS1OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent ND | Mann Kendall Statistic indicating |
|---------------|-------------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|------------|-------------|----------|--------------|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects # | increasing or decreasing trend |
| Temperature | °C | 15.85 | 25.9 | 10.05 | 3 | 27 | 20.34 | 2.585 | 5.17 | 6.68 | 12.7 | 0.00713 | 0 0 | 247 |
| pH (field) | | 9.62 | 11.3 | 1.67 | 0.235 | 28 | 10.04 | 0.312 | 0.624 | 0.0974 | 3.11 | 0.00675 | 0 0 | -173 |
| DO | mg/L | 16.5 | 78.8 | 62.3 | 18.8 | 27 | 49.7 | 16.25 | 32.5 | 264 | 32.7 | 0.00713 | 0 0 | -198 |
| TOC | mg/L | 13 | 61 | 48 | 8 | 18 | 50.3 | 10.37 | 20.74 | 107.5 | 20.62 | 0.0131 | 0 0 | -17 |
| TSS | mg/L | 1 | 73 | 72 | 2 | 27 | 4.56 | 15.5 | 31 | 240.4 | 271.3 | 0.0104 | 22 6 | 58 |
| El. Cond. | uS/cm | 563 | 2700 | 2137 | 36.75 | 28 | 745.4 | 442.1 | 884.2 | 195475.1 | 59.3 | 0.00675 | 0 0 | -138 |
| Ca | mg/L | 22.2 | 586 | 563.8 | 8.5 | 21 | 74.9 | 131.6 | 263.2 | 17324.3 | 175.6 | 0.0104 | 0 0 | -136 |
| Mg | mg/L | 4.3 | 25.9 | 21.6 | 5.4 | 21 | 19.67 | 5.2 | 10.4 | 27.04 | 26.43 | 0.0104 | 0 0 | 122 |
| Na | mg/L | 43.8 | 65 | 21.2 | 9.4 | 21 | 55.7 | 6.42 | 12.84 | 41.2 | 11.52 | 0.0104 | 0 0 | 55 |
| K | mg/L | 7.12 | 10.6 | 3.48 | 1.61 | 21 | 8.89 | 1.005 | 2.01 | 1.01 | 11.3 | 0.0104 | 0 0 | 43 |
| CI | mg/L | 95 | 125 | 30 | 13 | 25 | 107.7 | 8.23 | 16.46 | 67.8 | 7.65 | 0.008 | 0 0 | 56 |
| Measured Alka | linity mg/L | 63 | 110 | 47 | 12 | 25 | 86.5 | 12.36 | 24.72 | 152.8 | 14.3 | 0.008 | 0 0 | 213 |
| SO4 | mg/L | 17.1 | 1410 | 1392.9 | 19.5 | 25 | 143.7 | 305.1 | 610.2 | 93095.4 | 212.4 | 0.008 | 0 0 | -262 |
| F | mg/L | 0.05 | 0.32 | 0.27 | 0.09 | 25 | 0.0872 | 0.0964 | 0.1928 | 0.0093 | 74.9 | 0.0172 | 40 10 | -12 |
| SiO2 | mg/L | 2.7 | 7.9 | 5.2 | 1.4 | 25 | 4.12 | 1.42 | 2.84 | 2.02 | 34.5 | 0.008 | 0 0 | -44 |
| Sr | mg/L | 0.13 | 3.6 | 3.47 | 0.04 | 21 | 0.413 | 0.773 | 1.546 | 0.598 | 187.1 | 0.0104 | 0 0 | -99 |
| Sulfide | mg/L | 0.03 | 0.58 | 0.55 | 0.36 | 25 | 0.158 | 0.182 | 0.364 | 0.0331 | 60.8 | 0.02133 | 48 12 | -33 |
| DOC | mg/L | 14 | 62 | 48 | 5.5 | 18 | 50.1 | 10 | 20 | 99.9 | 19.94 | 0.0131 | 0 0 | -29 |
| TN_tot | mg/L | 0.76 | 2.7 | 1.94 | 0.4 | 28 | 2.25 | 0.3655 | 0.731 | 0.1336 | 16.23 | 0.00675 | 0 0 | 97 |
| N_org | mg/L | 0.66 | 2.6 | 1.94 | 0.325 | 28 | 2.077 | 0.345 | 0.69 | 0.1192 | 16.62 | 0.00675 | 0 0 | 109 |
| NH3 | mg/L | 0.02 | 0.16 | 0.14 | 0.07 | 28 | 0.0634 | 0.04585 | 0.0917 | 0.002103 | 55.7 | 0.02133 | 54 15 | 22 |
| NO3 | mg/L | 0.03 | 0.25 | 0.22 | 0.03 | 28 | 0.0625 | 0.0663 | 0.1326 | 0.00439 | 86.1 | 0.02133 | 54 15 | -38 |
| TP_tot | mg/L | 0.05 | 0.36 | 0.31 | 0.1 | 28 | 0.1584 | 0.0956 | 0.1912 | 0.00913 | 58.2 | 0.00713 | 4 1 | 26 |
| TP | mg/L | 0.03 | 0.28 | 0.25 | 0.16 | 28 | 0.113 | 0.0828 | 0.1656 | 0.00686 | 52.9 | 0.01427 | 39 11 | 34 |
| Cr_VI | mg/L | 0.014 | 0.014 | 0 | 0 | 25 | 0.00296 | 0 | 0 | N/A | N/A | 1 | 96 24 | 0 |
| Cesium | mg/L | 0.0001 | 0.0002 | 0.0001 | 0 | 18 | 6.94E-05 | 4.47E-05 | 8.94E-05 | 2E-09 | 37.3 | 0.0894 | 72 13 | -4 |
| Aluminum | mg/L | 0.018 | 0.097 | 0.079 | 0.014 | 21 | 0.0469 | 0.0181 | 0.0362 | 0.000328 | 38.65 | 0.0104 | 0 0 | -39 |
| Cobalt | mg/L | 0.0001 | 0.0011 | 0.001 | 0.000275 | 18 | 0.0005 | 0.000259 | 0.000518 | 6.7E-08 | 51.8 | 0.0131 | 0 0 | 131 |
| Chromium | mg/L | 0.0005 | 0.014 | 0.0135 | 0.001 | 21 | 0.00181 | 0.00296 | 0.00592 | 0.00000877 | 150.1 | 0.01207 | 10 2 | -103 |
| Copper | mg/L | 0.0011 | 0.0033 | 0.0022 | 0.000525 | 18 | 0.00271 | 0.00053 | 0.00106 | 2.81E-07 | 19.55 | 0.0131 | 0 0 | 29 |
| Iron | mg/L | 0.006 | 0.44 | 0.434 | 0.14 | 21 | 0.2417 | 0.1104 | 0.2208 | 0.01218 | 45.7 | 0.0104 | 0 0 | -35 |
| Manganese | mg/L | 0.002 | 0.024 | 0.022 | 0.00425 | 21 | 0.01126 | 0.00538 | 0.01076 | 0.0000289 | 45.6 | 0.01118 | 5 1 | 80 |
| Molibdenum | mg/L | 0.001 | 0.001 | 0 | 0 | 18 | 0.000583 | 0 | 0 | 0 | N/A | 0.1925 | 83 15 | 0 |
| Nickel | mg/L | 0.001 | 0.003 | 0.002 | 0 | 18 | 0.002028 | 0.0006 | 0.0012 | 0.0000036 | 28.34 | 0.01427 | 6 1 | 74 |
| Lead | mg/L | 0.0005 | 0.0021 | 0.0016 | 0.0005 | 18 | 0.000989 | 0.000411 | 0.000823 | 1.693E-07 | 41.6 | 0.0131 | 0 0 | 42 |
| Tin | mg/L | 0.0001 | 0.0005 | 0.0004 | 0.00015 | 18 | 0.000125 | 0.000151 | 0.000302 | 2.286E-08 | 62.3 | 0.054 | 61 11 | -13 |
| Thorium | mg/L | 0.0001 | 0.0004 | 0.0003 | 0.0001 | 18 | 0.000233 | 8.92E-05 | 0.000178 | 7.96E-09 | 34.8 | 0.01563 | 11 2 | 27 |
| Uranium | mg/L | 0.0003 | 0.0028 | 0.0025 | 0.000775 | 18 | 0.00124 | 0.000692 | 0.001384 | 4.79E-07 | 55.9 | 0.0131 | 0 0 | 124 |
| Vanadium | mg/L | 0.0009 | 0.0017 | 0.0008 | 0.0002 | 18 | 0.00145 | 0.000215 | 0.00043 | 4.62E-08 | 14.82 | 0.0131 | 0 0 | 49 |
| Zinc | mg/L | 0.006 | 0.013 | 0.007 | 0.005 | 21 | 0.00431 | 0.00306 | 0.00612 | 0.0000937 | 34.65 | 0.068 | 71 15 | -8 |

STATION PS2OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|--------------------|---------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|-----------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 14.47 | 24.8 | 10.33 | 2.91 | 25 | 19.56 | 2.47 | 4.94 | 6.1 | 12.62 | 0.008 | 0 | 0 | 204 |
| pH (field) | | 9.72 | 11.47 | 1.75 | 0.3 | 26 | 10.17 | 0.38 | 0.76 | 0.1442 | 3.734 | 0.00754 | 0 | 0 | -218 |
| DO | mg/L | 25.2 | 75.9 | 50.7 | 23.3 | 25 | 47.5 | 14.37 | 28.74 | 206.5 | 30.26 | 0.008 | 0 | 0 | -82 |
| TOC | mg/L | 10 | 58 | 48 | 5.25 | 18 | 48.6 | 10.96 | 21.92 | 120.1 | 22.57 | 0.0131 | 0 | 0 | -27 |
| TSS | mg/L | 1 | 2 | 1 | 1 | 24 | 0.938 | 0.48 | 0.96 | 0.2308 | 36.7 | 0.02133 | 46 | 11 | -12 |
| El. Cond. | uS/cm | 584 | 2840 | 2256 | 58.3 | 26 | 802.9 | 542.5 | 1085 | 294324 | 67.6 | 0.00754 | 0 | 0 | -127 |
| Ca | mg/L | 26 | 575 | 549 | 15.3 | 21 | 86.7 | 146.1 | 292.2 | 21331.1 | 168.4 | 0.0104 | 0 | 0 | -134 |
| Mg | mg/L | 2.5 | 28.9 | 26.4 | 4.2 | 21 | 19.8 | 5.86 | 11.72 | 34.36 | 29.6 | 0.0104 | 0 | 0 | 165 |
| Na | mg/L | 46.5 | 70.4 | 23.9 | 8.9 | 21 | 55.9 | 6.25 | 12.5 | 39.1 | 11.2 | 0.0104 | 0 | 0 | 75 |
| K | mg/L | 7.48 | 12.5 | 5.02 | 1.58 | 20 | 9.1 | 1.246 | 2.492 | 1.553 | 13.68 | 0.01118 | 0 | 0 | 32 |
| CI | mg/L | 60 | 148 | 88 | 12.5 | 24 | 108 | 15.5 | 31 | 240.7 | 14.37 | 0.0085 | 0 | 0 | 0 |
| Measured Alkalinit | ty mg/L | 65 | 109 | 44 | 14 | 24 | 89.7 | 12.23 | 24.46 | 149.5 | 13.63 | 0.0085 | 0 | 0 | 228 |
| SO4 | mg/L | 35.1 | 1430 | 1394.9 | 21.7 | 23 | 134.1 | 300.7 | 601.4 | 90428.8 | 224.3 | 0.00907 | 0 | 0 | -160 |
| F | mg/L | 0.05 | 0.31 | 0.26 | 0.0575 | 24 | 0.0729 | 0.0961 | 0.1922 | 0.00924 | 79.6 | 0.02406 | 50 | 12 | -39 |
| SiO2 | mg/L | 2.3 | 7 | 4.7 | 0.425 | 24 | 3.49 | 1.135 | 2.27 | 1.287 | 32.5 | 0.0085 | 0 | 0 | -114 |
| Sr | mg/l | 0.15 | 3.7 | 3.55 | 0.04 | 20 | 0.4775 | 0.856 | 1.712 | 0.733 | 179.3 | 0.01118 | 0 | 0 | -66 |
| Sulfide | mg/L | 0.01 | 0.85 | 0.84 | 0.2425 | 24 | 0.1954 | 0.2656 | 0.5312 | 0.0706 | 68.8 | 0.02406 | 50 | 12 | -21 |
| DOC | mg/L | 10 | 58 | 48 | 4 | 17 | 48.5 | 11.28 | 22.56 | 127.1 | 23.26 | 0.01427 | 0 | 0 | -5 |
| TN_tot | mg/L | 0.6 | 2.6 | 2 | 0.325 | 24 | 2.096 | 0.395 | 0.79 | 0.156 | 18.85 | 0.0085 | 0 | 0 | 3 |
| N_org | mg/L | 0.51 | 2.4 | 1.89 | 0.325 | 24 | 1.91 | 0.369 | 0.738 | 0.136 | 19.33 | 0.0085 | 0 | 0 | 14 |
| NH3 | mg/L | 0.02 | 0.26 | 0.24 | 0.07 | 24 | 0.0606 | 0.0773 | 0.1546 | 0.00598 | 92.8 | 0.037 | 63 | 15 | -3 |
| NO3 | mg/l | 0.06 | 0.19 | 0.13 | 0.08 | 24 | 0.0733 | 0.0455 | 0.091 | 0.00207 | 40.5 | 0.037 | 63 | 15 | 15 |
| TP_tot | mg/L | 0.02 | 0.25 | 0.23 | 0.0675 | 24 | 0.0933 | 0.0531 | 0.1062 | 0.00282 | 52.4 | 0.0097 | 8 | 2 | -139 |
| TP | mg/L | 0.02 | 0.18 | 0.16 | 0.06 | 24 | 0.056 | 0.0546 | 0.1092 | 0.00298 | 81.2 | 0.0274 | 54 | 13 | -8 |
| Cr_VI | mg/L | 0.018 | 0.018 | 0 | 0 | 24 | 0.003146 | 0 | 0 | N/A | N/A | 1 | 96 | 23 | 0 |
| Cesium | mg/L | 0.0001 | 0.0002 | 0.0001 | 0.00005 | 17 | 6.47E-05 | 5.77E-05 | 0.000115 | 3.33E-09 | 43.3 | 0.1925 | 82 | 14 | -2 |
| Aluminum | mg/L | 0.008 | 0.068 | 0.06 | 0.0095 | 20 | 0.03465 | 0.01238 | 0.02476 | 0.0001533 | 35.7 | 0.01118 | 0 | 0 | -26 |
| Cobalt | mg/L | 0.0002 | 0.0009 | 0.0007 | 0.00015 | 17 | 0.000427 | 0.000183 | 0.000365 | 3.33E-08 | 40.6 | 0.01563 | 6 | 1 | 97 |
| Chromium | mg/L | 0.0005 | 0.018 | 0.0175 | 0.001 | 20 | 0.002038 | 0.00407 | 0.00814 | 0.0000166 | 173.1 | 0.01427 | 15 | 3 | -109 |
| Copper | mg/L | 0.001 | 0.0032 | 0.0022 | 0.0005 | 17 | 0.00247 | 0.000538 | 0.001076 | 2.897E-07 | 21.8 | 0.01427 | 0 | 0 | 79 |
| Iron | mg/L | 0.041 | 0.4 | 0.359 | 0.11 | 20 | 0.2112 | 0.0955 | 0.191 | 0.00911 | 43 | 0.01207 | 5 | 1 | -72 |
| Manganese | mg/L | 0.002 | 0.019 | 0.017 | 0.0025 | 20 | 0.01053 | 0.00429 | 0.00858 | 0.0000184 | 38.8 | 0.01207 | 5 | 1 | 16 |
| Molibdenum | mg/L | 0.001 | 0.001 | 0 | 0 | 17 | 0.000529 | 0 | 0 | N/A | N/A | 1 | 94 | 16 | 0 |
| Nickel | mg/L | 0.002 | 0.003 | 0.001 | 0 | 17 | 0.001794 | 0.000267 | 0.000534 | 7.14E-08 | 12.9 | 0.0191 | 18 | 3 | 13 |
| Lead | mg/L | 0.0005 | 0.0027 | 0.0022 | 0.0004 | 17 | 0.0009 | 0.000542 | 0.001084 | 2.94E-07 | 60.2 | 0.01427 | 0 | 0 | 19 |
| Tin | mg/L | 0.0001 | 0.0002 | 0.0001 | 0.00005 | 17 | 6.18E-05 | 7.07E-05 | 0.000141 | 5E-09 | 47.1 | 0.3536 | 88 | 15 | 1 |
| Thorium | mg/L | 0.0002 | 0.0006 | 0.0004 | 0.0001 | 17 | 0.000232 | 0.000107 | 0.000214 | 1.143E-08 | 39.4 | 0.0191 | 18 | 3 | 21 |
| Uranium | ma/L | 0.0003 | 0.0021 | 0.0018 | 0.0005 | 17 | 0.000888 | 0.000487 | 0.000974 | 2.374E-07 | 54.8 | 0.01427 | 0 | 0 | 116 |
| Vanadium | mg/L | 0.0008 | 0.0017 | 0.0009 | 0.0002 | 17 | 0.001318 | 0.000224 | 0.000449 | 5.03E-08 | 17.02 | 0.01427 | 0 | 0 | 34 |
| Zinc | mg/L | 0.005 | 0.009 | 0.004 | 0.0015 | 20 | 0.00445 | 0.001506 | 0.003012 | 2.267E-06 | 23.52 | 0.0316 | 50 | 10 | 3 |

STATION PS3OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent ND | Mann Kendall Statistic indicating |
|------------------|----------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|------------|-------------|----------|--------------|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects # | increasing or decreasing trend |
| Temperature | °C | 15.98 | 25.2 | 9.2 | 3.325 | 27 | 20.17 | 2.5 | 5 | 6.25 | 12.4 | 0.00713 | 0 0 | 234 |
| pH (field) | | 9.45 | 10.55 | 1.1 | 0.235 | 28 | 9.83 | 0.2744 | 0.5488 | 0.0753 | 2.79 | 0.00675 | 0 0 | -201 |
| DO | mg/L | 15.9 | 89.7 | 73.8 | 17.9 | 27 | 47.4 | 16.82 | 33.64 | 283 | 35.5 | 0.00713 | 0 0 | -196 |
| TOC | mg/L | 9 | 55 | 46 | 2.75 | 18 | 46.5 | 14.23 | 28.46 | 202.4 | 30.6 | 0.0131 | 0 0 | 18 |
| TSS | mg/L | 1 | 120 | 119 | 3 | 27 | 6.48 | 27.04 | 54.08 | 731 | 300.4 | 0.01207 | 30 8 | -4 |
| El. Cond. | uS/cm | 554 | 2620 | 2066 | 134.3 | 28 | 862.5 | 613.7 | 1227.4 | 376570.9 | 71.2 | 0.00675 | 0 0 | -231 |
| Ca | mg/L | 23.1 | 563 | 539.9 | 44.2 | 21 | 118.5 | 182.2 | 364.4 | 33205.6 | 153.8 | 0.0104 | 0 0 | -175 |
| Mg | mg/L | 13.6 | 23.5 | 9.9 | 4.1 | 21 | 18.9 | 2.94 | 5.88 | 8.65 | 15.57 | 0.0104 | 0 0 | 123 |
| Na | mg/L | 47.6 | 71.4 | 23.8 | 9.2 | 21 | 56.9 | 6.25 | 12.5 | 39.05 | 10.99 | 0.0104 | 0 0 | 64 |
| К | mg/L | 7.79 | 11.7 | 3.91 | 1.34 | 21 | 9.2 | 0.94 | 1.88 | 0.884 | 10.22 | 0.0104 | 0 0 | 49 |
| CI | mg/L | 96 | 126 | 30 | 12 | 25 | 109.9 | 8.62 | 17.24 | 74.3 | 7.84 | 0.008 | 0 0 | 80 |
| Measured Alkalin | ity mg/L | 30 | 103 | 73 | 12 | 25 | 79.4 | 18.76 | 37.52 | 351.9 | 23.6 | 0.008 | 0 0 | 228 |
| SO4 | mg/L | 15.8 | 1520 | 1504.2 | 75.9 | 25 | 243.2 | 465 | 930 | 216185.1 | 191.2 | 0.008 | 0 0 | -271 |
| F | mg/L | 0.05 | 0.56 | 0.51 | 0.0625 | 25 | 0.131 | 0.133 | 0.266 | 0.01766 | 91.4 | 0.0097 | 12 3 | -10 |
| SiO2 | mg/L | 2.3 | 7.6 | 5.3 | 1.4 | 25 | 4.39 | 1.298 | 2.596 | 1.686 | 29.56 | 0.008 | 0 0 | 43 |
| Sr | ma/L | 0.14 | 5.1 | 4.96 | 0.17 | 21 | 0.729 | 1.338 | 2.676 | 1.79 | 183.6 | 0.0104 | 0 0 | -166 |
| Sulfide | ma/L | 0.01 | 0.93 | 0.92 | 0.2575 | 25 | 0.1526 | 0.338 | 0.676 | 0.1143 | 125.9 | 0.0191 | 44 11 | -15 |
| DOC | ma/L | 8.8 | 58 | 49.2 | 2 | 18 | 47.2 | 14.7 | 29.4 | 215.8 | 31.15 | 0.0131 | 0 0 | 20 |
| TN tot | ma/L | 0.56 | 2.7 | 2.14 | 0.3 | 28 | 2.13 | 0.516 | 1.032 | 0.266 | 24.2 | 0.00675 | 0 0 | 165 |
| N ora | ma/L | 0.45 | 2.4 | 1.95 | 0.225 | 28 | 1.957 | 0.483 | 0.966 | 0.2335 | 24.7 | 0.00675 | 0 0 | 199 |
| NH3 | ma/L | 0.02 | 0.14 | 0.12 | 0.075 | 28 | 0.0555 | 0.0464 | 0.0928 | 0.002156 | 66.3 | 0.0316 | 64 18 | 29 |
| NO3 | ma/L | 0.02 | 0.14 | 0.12 | 0.045 | 28 | 0.0561 | 0.0378 | 0.0756 | 0.001427 | 58.9 | 0.02406 | 57 16 | 2 |
| TP tot | ma/L | 0.01 | 0.3 | 0.29 | 0.06 | 28 | 0.1014 | 0.0871 | 0.1742 | 0.00759 | 80 | 0.00754 | 7 2 | 89 |
| TP | ma/L | 0.04 | 0.24 | 0.2 | 0.17 | 28 | 0.0759 | 0.085 | 0.17 | 0.00723 | 58.4 | 0.037 | 68 19 | 20 |
| Cr VI | ma/L | 0.007 | 0.025 | 0.018 | 0.009 | 25 | 0.00358 | 0.01273 | 0.02546 | 0.000162 | 79.5 | 0.3536 | 92 23 | -1 |
| Cesium | ma/L | 0.0001 | 0.0002 | 0.0001 | 0.000025 | 18 | 6.67E-05 | 0.00005 | 0.0001 | 0 | 40 | 0.125 | 78 14 | -3 |
| Aluminum | ma/l | 0.019 | 0.054 | 0.035 | 0.009 | 21 | 0.0389 | 0.00792 | 0.01584 | 0.0000628 | 20.37 | 0.0104 | 0 0 | -2 |
| Cobalt | ma/l | 0.0001 | 0.0021 | 0.002 | 0.000625 | 18 | 0.000833 | 0.000558 | 0.001116 | 3.12E-07 | 67 | 0.0131 | 0 0 | 142 |
| Chromium | ma/l | 0.0006 | 0.024 | 0.0234 | 0.0007 | 21 | 0.002795 | 0.00514 | 0.01028 | 0.00002645 | 184 | 0.0104 | 0 0 | -137 |
| Copper | ma/l | 0.0008 | 0.0049 | 0.0041 | 0.000975 | 18 | 0.003133 | 0.00117 | 0.00234 | 1.367E-06 | 37.3 | 0.0131 | 0 0 | 111 |
| Iron | ma/l | 0.007 | 0.43 | 0.423 | 0.1 | 21 | 0.221 | 0.112 | 0.224 | 0.01255 | 50.7 | 0.0104 | 0 0 | 34 |
| Manganese | ma/l | 0.008 | 0.06 | 0.052 | 0.00975 | 21 | 0.0231 | 0.01107 | 0.02214 | 0.0001226 | 41.2 | 0.0131 | 14 3 | 95 |
| Molibdenum | ma/l | 0.001 | 0.002 | 0.001 | 0.00025 | 18 | 0.000833 | 0.000463 | 0.000926 | 2.143E-07 | 37 | 0.0442 | 56 10 | 0 |
| Nickel | ma/l | 0.002 | 0.004 | 0.002 | 0.001 | 18 | 0.00236 | 0.000799 | 0.001598 | 6.38E-07 | 29.2 | 0.0172 | 17 3 | 67 |
| Lead | ma/l | 0.0005 | 0.0015 | 0.001 | 0.000275 | 18 | 0.000856 | 0.000255 | 0.00051 | 6.5E-08 | 29.8 | 0.0131 | 0 0 | 57 |
| Tin | ma/l | 0.0001 | 0,0006 | 0.0005 | 0.00025 | 18 | 0.000131 | 0.00019 | 0.00038 | 3 62E-08 | 74 | 0.054 | 61 11 | -2 |
| Thorium | ma/l | 0.0002 | 0.0004 | 0.0002 | 0.0001 | 18 | 0.000236 | 7.04F-05 | 0.000141 | 4.95F-09 | 25.75 | 0.0172 | 17 3 | 24 |
| Uranium | ma/l | 0.0003 | 0.0024 | 0.0021 | 0 000275 | 18 | 0.00124 | 0.000549 | 0.001098 | 3.013E-07 | 44.3 | 0.0131 | | 112 |
| Vanadium | ma/l | 0.0006 | 0.0012 | 0.0006 | 0 0002 | 18 | 0.000989 | 0.000181 | 0.000362 | 3.28F-08 | 18.3 | 0.0131 | | 90 |
| Zinc | ma/l | 0.006 | 0.013 | 0 007 | 0.00325 | 21 | 0.0054 | 0.00246 | 0.00492 | 0.00000604 | 28.6 | 0.0316 | 52 11 | -1 |
| | ling/ L | 0.000 | 5.5.0 | 5.001 | 0.00020 | - 1 | 0.0001 | 0.002.0 | 0.00102 | 2.0000001 | | 0.0010 | 52 11 | I |

STATION PS4OUT

| Parameter | Unit | Minimum | Maximum | Range | Inter Quartile | Number of | Arithmetic | Standard | 2x Std Dev | Variance | Deviation | Skewness | Percent | ND | Mann Kendall Statistic indicating |
|---------------------|--------|---------|---------|-----------|-----------------|-----------|------------|-----------|------------|------------|-------------|----------|------------|----|-----------------------------------|
| | | | | (Max-Min) | Range (Q75-Q25) | Samples | Mean | deviation | | | coefficient | | Nondetects | # | increasing or decreasing trend |
| Temperature | °C | 15.98 | 26.6 | 10.63 | 3.37 | 25 | 20.4 | 2.53 | 5.06 | 6.4 | 12.4 | 0.008 | 0 | 0 | 194 |
| pH (field) | | 9.55 | 10.76 | 1.21 | 0.205 | 26 | 9.85 | 0.239 | 0.478 | 0.0571 | 2.426 | 0.00754 | 0 | 0 | -120 |
| DO | mg/L | 33.9 | 90.2 | 56.3 | 10.7 | 25 | 53.5 | 11.78 | 23.56 | 138.8 | 22 | 0.008 | 0 | 0 | -25 |
| TOC | mg/L | 12 | 59 | 47 | 4.75 | 18 | 50.3 | 11 | 22 | 120.9 | 21.85 | 0.0131 | 0 | 0 | -10 |
| TSS | mg/L | 1 | 9 | 8 | 1 | 24 | 1.52 | 2.18 | 4.36 | 4.76 | 91.5 | 0.02133 | 46 | 11 | -26 |
| El. Cond. | uS/cm | 564 | 2610 | 2046 | 71.3 | 26 | 802.5 | 541.4 | 1082.8 | 293165.5 | 67.5 | 0.00754 | 0 | 0 | -121 |
| Ca | mg/L | 24.1 | 560 | 535.9 | 15.9 | 21 | 92.4 | 155 | 310 | 24025.1 | 167.8 | 0.0104 | 0 | 0 | -160 |
| Mg | mg/L | 10.4 | 27.7 | 17.3 | 5.2 | 21 | 19.14 | 4 | 8 | 15.97 | 20.87 | 0.0104 | 0 | 0 | 170 |
| Na | mg/L | 48 | 68.7 | 20.7 | 6.8 | 21 | 56.7 | 5.93 | 11.86 | 35.2 | 10.47 | 0.0104 | 0 | 0 | 40 |
| К | mg/L | 7.64 | 12.5 | 4.86 | 1.79 | 21 | 9.08 | 1.142 | 2.284 | 1.304 | 12.58 | 0.0104 | 0 | 0 | 30 |
| CI | mg/L | 95 | 129 | 34 | 8 | 25 | 108.4 | 9.11 | 18.22 | 83 | 8.4 | 0.008 | 0 | 0 | 54 |
| Measured Alkalinity | / mg/L | 43 | 113 | 70 | 25 | 25 | 84 | 18.3 | 36.6 | 335.5 | 21.8 | 0.008 | 0 | 0 | 286 |
| SO4 | mg/L | 25.3 | 1390 | 1364.7 | 35 | 25 | 181.1 | 372.6 | 745.2 | 138836.8 | 205.8 | 0.008 | 0 | 0 | -282 |
| F | mg/L | 0.06 | 0.48 | 0.42 | 0.05 | 25 | 0.1198 | 0.1089 | 0.2178 | 0.01186 | 75.9 | 0.01118 | 20 | 5 | -21 |
| SiO2 | mg/L | 2.9 | 8.5 | 5.6 | 0.6 | 25 | 4.26 | 1.347 | 2.694 | 1.814 | 31.6 | 0.008 | 0 | 0 | -138 |
| Sr | mg/L | 0.14 | 4.4 | 4.26 | 0.07 | 21 | 0.521 | 1.005 | 2.01 | 1.01 | 192.7 | 0.0104 | 0 | 0 | -125 |
| Sulfide | mg/L | 0.03 | 0.95 | 0.92 | 0.26 | 25 | 0.134 | 0.3224 | 0.6448 | 0.104 | 127.4 | 0.02133 | 48 | 12 | -34 |
| DOC | mg/L | 11 | 61 | 50 | 3.75 | 18 | 50.7 | 11.46 | 22.92 | 131.4 | 22.6 | 0.0131 | 0 | 0 | 4 |
| TN_tot | mg/L | 0.63 | 3 | 2.37 | 0.2 | 25 | 2.193 | 0.4254 | 0.8508 | 0.181 | 19.4 | 0.008 | 0 | 0 | 42 |
| N_org | mg/L | 0.54 | 2.8 | 2.26 | 0.3 | 25 | 2.006 | 0.402 | 0.804 | 0.1613 | 20.02 | 0.008 | 0 | 0 | 42 |
| NH3 | mg/L | 0.01 | 0.15 | 0.14 | 0.025 | 25 | 0.0482 | 0.0434 | 0.0868 | 0.001886 | 86.8 | 0.0442 | 68 | 17 | -1 |
| NO3 | mg/L | 0.05 | 0.18 | 0.13 | 0.0325 | 25 | 0.082 | 0.03916 | 0.07832 | 0.001533 | 33.56 | 0.02406 | 52 | 13 | 38 |
| TP_tot | mg/L | 0.02 | 0.18 | 0.16 | 0.0725 | 25 | 0.1034 | 0.0451 | 0.0902 | 0.002037 | 42 | 0.0085 | 4 | 1 | -98 |
| TP | mg/L | 0.01 | 0.13 | 0.12 | 0.0775 | 25 | 0.0558 | 0.0458 | 0.0916 | 0.0021 | 69.6 | 0.02406 | 52 | 13 | -3 |
| Cr_VI | mg/L | 0.017 | 0.017 | 0 | 0 | 25 | 0.00308 | 0 | 0 | N/A | N/A | 1 | 96 | 24 | 0 |
| Cesium | mg/L | 0.0001 | 0.0002 | 0.0001 | 0 | 18 | 7.22E-05 | 4.08E-05 | 8.16E-05 | 0 | 35 | 0.068 | 67 | 12 | -5 |
| Aluminum | mg/L | 0.019 | 0.088 | 0.069 | 0.015 | 21 | 0.049 | 0.0162 | 0.0324 | 0.0002626 | 33.04 | 0.0104 | 0 | 0 | -52 |
| Cobalt | mg/L | 0.0001 | 0.0021 | 0.002 | 0.00055 | 18 | 0.000811 | 0.000545 | 0.00109 | 2.975E-07 | 67.2 | 0.0131 | 0 | 0 | 134 |
| Chromium | mg/L | 0.0006 | 0.017 | 0.0164 | 0.00095 | 21 | 0.001998 | 0.00354 | 0.00708 | 0.00001254 | 169.9 | 0.01118 | 5 | 1 | -128 |
| Copper | mg/L | 0.0009 | 0.0044 | 0.0035 | 0.00045 | 18 | 0.003217 | 0.000862 | 0.001724 | 7.43E-07 | 26.8 | 0.0131 | 0 | 0 | 74 |
| Iron | mg/L | 0.009 | 0.45 | 0.441 | 0.16 | 21 | 0.23 | 0.1205 | 0.241 | 0.01452 | 52.4 | 0.0104 | 0 | 0 | -71 |
| Manganese | mg/L | 0.002 | 0.031 | 0.029 | 0.0025 | 21 | 0.0172 | 0.00674 | 0.01348 | 0.0000454 | 37.3 | 0.01118 | 5 | 1 | 77 |
| Molibdenum | mg/L | 0.001 | 0.002 | 0.001 | 0.001 | 18 | 0.00075 | 0.000548 | 0.001096 | 0.000003 | 39.1 | 0.0894 | 72 | 13 | 0 |
| Nickel | mg/L | 0.001 | 0.004 | 0.003 | 0.001 | 18 | 0.002333 | 0.000814 | 0.001628 | 0 | 31.76 | 0.01563 | 11 | 2 | 79 |
| Lead | mg/L | 0.0006 | 0.0015 | 0.0009 | 0.00055 | 18 | 0.000917 | 0.000292 | 0.000583 | 0 | 31.8 | 0.0131 | 0 | 0 | 45 |
| Tin | mg/L | 0.0001 | 0.001 | 0.0009 | 0.0001 | 18 | 0.000119 | 0.000394 | 0.000788 | 0 | 131.2 | 0.0894 | 72 | 13 | -3 |
| Thorium | mg/L | 0.0002 | 0.0004 | 0.0002 | 0 | 18 | 0.000247 | 5.16E-05 | 0.000103 | 0 | 18 | 0.0172 | 17 | 3 | 7 |
| Uranium | mg/L | 0.0005 | 0.0023 | 0.0018 | 0.0004 | 18 | 0.001172 | 0.000487 | 0.000974 | 2.374E-07 | 41.6 | 0.0131 | 0 | 0 | 107 |
| Vanadium | mg/L | 0.0006 | 0.0014 | 0.0008 | 0.000175 | 18 | 0.001122 | 0.00021 | 0.00042 | 4.42E-08 | 18.73 | 0.0131 | 0 | 0 | 76 |
| Zinc | mg/L | 0.005 | 0.009 | 0.004 | 0.0015 | 21 | 0.00369 | 0.001506 | 0.003012 | 2.267E-06 | 22.6 | 0.068 | 71 | 15 | -6 |

APPENDIX 2 CORRELATION CO-EFFICIENTS OF KEY ANALYTES IN EFFLUENT SAMPLES

| | Temp | pH_field | DO | TOC | TSS | Cond | Ca | Mg | Na | K | CI | Meas_Alk | SO4 | F | NO3 | В | Ba | Si | Sr | TP | N_org | DOC | NH3 | CS | AI | Со | Cr | Cu | Fe | Mn | Мо | Ni | Pb | Sn | Th | U | V | Zn |
|----------|------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|----------|--------|--------|--------|---------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|---------|--------|--------|-----------|---------|
| | °C | | mg/L | mg/L | mg/L | uS/cm | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L |
| Temp | 1 | -0.015 | -0.472 | -0.527 | 0.157 | 0.414 | 0.497 | 0.392 | 0.346 | 0.271 | 0.143 | -0.234 | 0.287 | 0.211 | 0.161 | 0.114 | -0.208 | -0.38 | 0.391 | -0.219 | -0.38 | -0.535 | 0.235 | 0.246 | -0.225 | 0.079 | 0.359 | -0.347 | -0.195 | 0.161 | 0.298 | -0.051 | -0.153 | 0.257 | 0.174 | 0.029 | -0.389 | 0.288 |
| pH_field | | 1 | -0.459 | -0.352 | -0.065 | 0.226 | 0.237 | 0.166 | -0.103 | -0.024 | 0.019 | 0.362 | 0.106 | 0.207 | -0.02 | -0.258 | -0.936 | -0.624 | 0.177 | -0.839 | -0.359 | -0.361 | -0.042 | -0.091 | -0.912 | 0.163 | 0.137 | 0.387 | -0.897 | -0.04 | -0.319 | 0.302 | 0.555 | 0.01 | 0.161 | -0.273 | -0.6 | -0.107 |
| DO | | | 1 | 0.48 | -0.075 | -0.255 | -0.326 | -0.419 | -0.183 | -0.073 | 0.024 | -0.075 | -0.246 | -0.117 | -0.049 | 0.118 | 0.562 | 0.613 | -0.386 | 0.515 | 0.377 | 0.496 | -0.355 | -0.3 | 0.607 | -0.28 | -0.303 | -0.081 | 0.481 | -0.363 | -0.576 | -0.205 | -0.045 | -0.0091 | -0.311 | -0.147 | 0.486 | 0.07 |
| тос | | | | 1 | -0.089 | -0.956 | -0.959 | -0.572 | 0.018 | -0.323 | 0.016 | 0.658 | -0.542 | -0.776 | -0.204 | -0.0027 | 0.561 | 0.721 | -0.919 | 0.659 | 0.975 | 0.999 | -0.312 | -0.702 | 0.515 | 0.336 | -0.727 | 0.583 | 0.642 | 0.206 | -0.759 | 0.241 | -0.264 | -0.144 | 0.245 | 0.314 | 0.788 | 0.032 |
| TSS | | | | | 1 | 0.162 | 0.397 | 0.023 | -0.107 | -0.013 | 0.048 | -0.127 | 0.043 | 0.022 | -0.11 | 0.0041 | -0.099 | 0.051 | 0.214 | -0.245 | -0.067 | -0.094 | -0.084 | -0.02 | -0.093 | -0.181 | 0.069 | -0.237 | -0.088 | -0.178 | 0.168 | -0.279 | -0.208 | -0.084 | -0.282 | -0.099 | -0.31 | 0.142 |
| Cond | | | | | | 1 | 0.991 | 0.584 | -0.072 | 0.409 | -0.076 | -0.714 | 0.545 | 0.847 | 0.356 | 0.085 | -0.504 | -0.561 | 0.881 | -0.42 | -0.925 | -0.96 | 0.381 | 0.689 | -0.399 | -0.439 | 0.693 | -0.655 | -0.492 | -0.239 | 0.658 | -0.437 | 0.223 | 0.187 | -0.377 | -0.392 | -0.734 | -0.029 |
| Ca | | | | | | | 1 | 0.504 | -0.085 | 0.322 | -0.079 | -0.726 | 0.535 | 0.795 | 0.256 | 0.098 | -0.482 | -0.567 | 0.86 | -0.427 | -0.933 | -0.961 | 0.294 | 0.569 | -0.367 | -0.446 | 0.651 | -0.68 | -0.451 | -0.223 | 0.649 | -0.441 | 0.173 | 0.163 | -0.397 | -0.443 | -0.724 | -0.014 |
| Mg | | | | | | | | 1 | 0.193 | 0.798 | -0.05 | -0.371 | 0.312 | 0.712 | 0.882 | 0.021 | -0.376 | -0.515 | 0.712 | -0.685 | -0.538 | -0.603 | 0.258 | 0.863 | -0.363 | 0.078 | 0.774 | -0.278 | -0.601 | 0.04 | 0.575 | 0.466 | 0.099 | 0.174 | -0.181 | 0.201 | -0.527 | -0.099 |
| Na | | | | | | | | | 1 | 0.399 | 0.153 | 0.133 | -0.04 | -0.127 | 0.28 | 0.149 | 0.086 | -0.057 | -0.105 | -0.03 | 0.086 | 0.051 | 0.136 | 0.209 | -0.022 | 0.163 | -0.099 | 0.089 | 0.097 | 0.466 | -0.114 | 0.151 | -0.037 | 0.129 | -0.146 | 0.293 | 0.03 | 0.08 |
| К | | | | | | | | | | 1 | 0.102 | -0.234 | 0.17 | 0.559 | 0.88 | 0.114 | -0.113 | -0.207 | 0.399 | -0.233 | -0.248 | -0.361 | -0.054 | 0.727 | -0.124 | -0.072 | 0.491 | -0.231 | -0.074 | 0.276 | 0.163 | 0.241 | 0.16 | 0.207 | -0.244 | 0.231 | -0.271 | -0.069 |
| CI | | | | | | | | | | | 1 | 0.201 | -0.116 | -0.182 | -0.014 | 0.173 | 0.024 | 0.092 | -0.17 | -0.199 | 0.117 | 0.018 | -0.163 | -0.015 | -0.039 | -0.127 | -0.152 | 0.023 | -0.075 | 0.051 | -0.126 | -0.223 | -0.06 | 0.281 | -0.02 | -0.197 | -0.172 | 0.049 |
| Meas_Alk | | | | | | | | | | | | 1 | -0.44 | -0.664 | -0.246 | -0.173 | -0.163 | 0.098 | -0.723 | -0.674 | 0.614 | 0.678 | -0.52 | -0.619 | -0.435 | 0.616 | -0.555 | 0.867 | -0.496 | 0.277 | -0.801 | 0.653 | 0.422 | -0.103 | 0.351 | 0.489 | 0.017 | -0.043 |
| SO4 | | | | | | | | | | | | | 1 | 0.484 | 0.129 | 0.089 | -0.237 | -0.339 | 0.555 | -0.373 | -0.547 | -0.543 | 0.191 | 0.276 | -0.197 | -0.441 | 0.416 | -0.38 | -0.443 | -0.228 | 0.372 | -0.449 | -0.033 | 0.172 | -0.38 | -0.374 | -0.733 | -0.028 |
| F | | | | | | | | | | | | | | 1 | 0.618 | 0.021 | -0.461 | -0.509 | 0.845 | -0.256 | -0.743 | -0.795 | 0.225 | 0.784 | -0.297 | -0.486 | 0.795 | -0.577 | -0.354 | -0.344 | 0.591 | -0.577 | 0.275 | 0.146 | -0.43 | -0.226 | -0.457 | -0.1 |
| NO3 | | | | | | | | | | | | | | | 1 | -0.074 | -0.138 | -0.271 | 0.45 | -0.355 | -0.195 | -0.298 | 0.059 | 0.827 | -0.152 | -0.085 | 0.64 | -0.184 | -0.305 | -0.042 | 0.331 | 0.836 | -0.0081 | 0.294 | -0.362 | 0.2 | 0.141 | -0.188 |
| В | | | | | | | | | | | | | | | | 1 | 0.305 | 0.166 | 0.087 | 0.296 | 0.061 | -0.013 | -0.417 | 0.5 | 0.162 | -0.046 | 0.056 | -0.184 | 0.276 | 0.384 | 1 | 0.02 | -0.12 | 0.313 | -0.088 | 0.113 | 0.126 | -0.055 |
| Ba | | | | | | | | | | | | | | | | | 1 | 0.682 | -0.398 | 0.913 | 0.571 | 0.571 | -0.165 | -0.179 | 0.943 | -0.038 | -0.295 | -0.296 | 0.934 | 0.3 | -0.388 | -0.51 | -0.462 | -0.122 | -0.068 | -0.124 | 0.682 | 0.0052 |
| Si | | | | | | | | | | | | | | | | | | 1 | -0.583 | 0.555 | 0.715 | 0.728 | -0.357 | -0.622 | 0.734 | -0.157 | -0.472 | 0.1 | 0.701 | -0.073 | -0.872 | -0.278 | -0.346 | -0.097 | -0.117 | -0.122 | 0.605 | 0.079 |
| Sr | | | | | | | | | | | | | | | | | | | 1 | -0.417 | -0.865 | -0.917 | 0.364 | 0.782 | -0.303 | -0.417 | 0.86 | -0.632 | -0.367 | -0.222 | 0.916 | -0.436 | 0.129 | 0.094 | -0.339 | -0.292 | -0.674 | -0.079 |
| ТР | | | | | | | | | | | | | | | | | | | | 1 | 0.588 | 0.675 | 0.167 | -0.237 | 0.914 | -0.273 | -0.179 | -0.661 | 0.947 | 0.11 | 1 | -0.337 | -0.655 | -0.066 | -0.236 | -0.29 | 0.788 | -0.109 |
| N_org | | | | | | | | | | | | | | | | | | | | | 1 | 0.971 | -0.434 | -0.576 | 0.551 | 0.315 | -0.635 | 0.541 | 0.655 | 0.201 | -0.717 | 0.207 | -0.188 | -0.123 | 0.248 | 0.384 | 0.814 | 0.056 |
| DOC | | | | | | | | | | | | | | | | | | | | | | 1 | -0.319 | -0.705 | 0.513 | 0.354 | -0.715 | 0.61 | 0.64 | 0.221 | -0.758 | 0.284 | -0.223 | -0.147 | 0.247 | 0.36 | 0.779 | 0.045 |
| NH3 | | | | | | | | | | | | | | | | | | | | | | | 1 | 0.343 | 0.027 | 0.124 | 0.233 | -0.21 | 0.259 | 0.055 | 0.586 | 0.339 | -0.256 | -0.112 | 0.151 | 0.066 | -0.061 | -0.0009 |
| CS | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.305 | -0.378 | 0.76 | -0.499 | -0.335 | -0.421 | 0.643 | -0.458 | -0.043 | -0.0052 | -0.511 | 0.024 | -0.68 | -0.249 |
| AI | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.202 | -0.228 | -0.416 | 0.948 | -0.07 | -0.708 | -0.354 | -0.58 | -0.068 | -0.139 | -0.049 | 0.773 | -0.0066 |
| Co | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.268 | 0.695 | -0.213 | 0.592 | -0.435 | 0.881 | 0.369 | -0.117 | 0.272 | 0.739 | 0.036 | 0.0016 |
| Cr | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.463 | -0.239 | -0.163 | 0.726 | -0.384 | 0.137 | 0.192 | -0.268 | -0.163 | -0.321 | -0.105 |
| Cu | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.428 | 0.435 | -0.66 | 0.707 | 0.36 | -0.238 | 0.33 | 0.519 | -0.039 | -0.077 |
| Fe | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | 0.111 | -0.401 | -0.315 | -0.66 | -0.145 | -0.149 | -0.015 | 0.812 | 0.00082 |
| Mn | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.578 | 0.485 | 0.105 | -0.167 | 0.205 | 0.354 | -0.076 | -0.0011 |
| Мо | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.503 | -0.33 | -0.086 | -0.63 | -0.318 | -0.646 | -0.234 |
| Ni | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | 0.576 | -0.077 | 0.151 | 0.764 | 0.0075 | -0.122 |
| Pb | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | 0.239 | 0.196 | 0.291 | -0.295 | -0.207 |
| Sn | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.196 | 0.095 | -0.16 | -0.097 |
| Th | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | 0.235 | -0.129 | -0.309 |
| U | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | , | 1 | 0.416 | -0.196 |
| ٧ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | -0.0035 |
| Zn | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | · · · · · | 1 |
| As | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | , | |
| Sb | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 1 | | | |

APPENDIX 3 ELEMENTAL COMPOSITION OF SELECTED SAMPLES FROM PASSIVE SYSTEM TRIALS
| TSW Sample ID | Customer Sample ID | Syrinx Code | Depth | Description | Lithium | Beryllium | Boron | Magnesiu m | Sodium | Aluminium | Silicon | Potassium | Phosphoro us | Calcium | Sulfur | Scandium | Titanium | Vanadium | Chromium | Manganes e | Iron | Cobalt | Nickel | Copper | Zinc | Gallium | |
|---------------------|-----------------------|----------------|-------|--|---------------|-----------|----------|---------------|--------------------|--------------------|------------|-----------|-----------------|----------------|-----------|-----------|----------|----------|----------|---------------|----------|-----------|----------|--------|-----------|---------|---------|
| mg/kg | Α | PS4 40% | 17-20 | NUA Blend | 0.467 | 0.128 | 16.250 | 2415 | 66.75 | 825 | 138.5 | 25.6 | 232 | 4430 | 301.5 | 0.935 | 356.770 | 17.690 | 28.330 | 6949.970 | 40950 | 51.000 | 24.391 | 9.485 | 10.283 | 7.500 | |
| | В | PS3 40% | 17-20 | NUA Blend | 0.325 | 0.119 | 23.550 | 5650 | 57.25 | 605 | 162.5 | 20.05 | 232.5 | 3965 | 256 | 0.730 | 326.770 | 14.890 | 23.930 | 5649.970 | 33700 | 42.350 | 20.591 | 7.835 | 8.283 | 6.250 | |
| | с | PS1(1) 25% | 17-20 | NUA Blend | 0.234 | 0.054 | 8.350 | 5000 | 32.8 | 405 | 94.5 | 2.4 | 172 | 2690 | 140.5 | 0.420 | 215.270 | 8.440 | 12.630 | 3019.970 | 19800 | 23.950 | 12.341 | 4.045 | 5.633 | 3.425 | |
| | D | AS1A(1) | 2-4 | Fines at surface | 1.515 | 0.327 | 19.300 | 4390 | 113.25 | 2670 | 472.5 | 151.3 | 361.5 | 83200 | 57500 | 2.170 | 509.270 | 37.140 | 70.380 | 17549.970 | 94700 | 125.500 | 61.491 | 23.085 | 39.833 | 18.900 | |
| | E | AS1A(2) | 17-20 | NUA Blend (high pisolites) | 0.795 | 0.132 | 7.700 | 2440 | 45.75 | 1270 | 253 | 34.45 | 130 | 36200 | 26000 | 1.315 | 564.270 | 24.090 | 32.280 | 7599.970 | 46150 | 54.500 | 26.591 | 10.185 | 13.133 | 8.500 | |
| | F | QC1 (PS4 40%) | 17-20 | NUA Blend | 0.395 | 0.109 | 8.200 | 2350 | 56.25 | 865 | 153.5 | BDL | 220.5 | 4145 | 303 | 0.805 | 367.270 | 17.240 | 26.680 | 6399.970 | 40100 | 47.450 | 21.941 | 8.685 | 9.133 | 7.350 | |
| | G | AS1C(1) | 17-20 | NUA Blend | 0.745 | 0.102 | 6.550 | 2280 | 38.75 | 945 | 202.5 | 42.55 | 94.5 | 36300 | 26150 | 0.930 | 463.770 | 16.590 | 23.130 | 5449.970 | 32550 | 39.650 | 19.341 | 7.235 | 15.133 | 6.050 | |
| | н | AS1A(3) | 55-58 | NUA Blend (transitional to | 0.535 | 0.086 | 2.800 | 4590 | 41.45 | 915 | 146 | 25.9 | 78.5 | 19100 | 12550 | 0.780 | 387.270 | 13.890 | 19.680 | 4629.970 | 29950 | 35.400 | 17.541 | 6.485 | 9.533 | 5.350 | |
| | I | AS1B | 17-20 | NUA Blend | 0.497 | 0.096 | 9.850 | 2060 | 47.75 | 790 | 172.5 | 35.75 | 97.5 | 11200 | 4885 | 0.870 | 477.770 | 17.290 | 26.130 | 6049.970 | 38550 | 44.850 | 20.991 | 8.285 | 9.683 | 6.800 | |
| | J | PS2 25% | 17-20 | NUA Blend | 0.303 | 0.067 | 7.200 | 3005 | 53.25 | 555 | 112 | BDL | 156.5 | 3480 | 194.5 | 0.495 | 300.770 | 10.690 | 16.480 | 3959.970 | 25550 | 29.850 | 14.341 | 5.485 | 6.983 | 4.420 | |
| - | к | PS1(2) 25% | 40-43 | Sands at Base | < 0.0001 | < 0.0001 | BDL | 30.15 | 6.1 | BDL | BDL | 5.7 | BDL | 116 | BDL | -0.174 | 83.270 | 1.160 | 0.550 | 96.470 | 540 | 0.670 | 0.305 | 0.057 | 0.198 | 0.116 | |
| | L | AS1C(3) | 70-73 | Pisolitic rich | 0.650 | 0.102 | 10.000 | 2310 | 59.75 | 1005 | 282 | 51.8 | 105.5 | 39050 | 28900 | 0.895 | 478.770 | 19.740 | 24.530 | 5549.970 | 34500 | 41.550 | 20.191 | 7.535 | 14.683 | 6.150 | |
| | м | AS1C(2) | 62-63 | Plastic Fines / | 1.420 | 0.200 | 12.200 | 3860 | 67.75 | 2520 | 360 | 256.8 | 258.5 | 116300 | 80200 | 1.455 | 619.270 | 26.890 | 40.880 | 10949.970 | 73250 | 90.500 | 45.491 | 16.385 | 21.433 | 13.350 | |
| | DR | Replicate of D | 2-4 | Fines at surface | 1.285 | 0.227 | 0.150 | 4290 | 112.75 | 2680 | 510 | 160.3 | 346.5 | 81650 | 55700 | 1.970 | 564.270 | 38.290 | 61.880 | 15499.970 | 93650 | 112.000 | 52.491 | 20.485 | 35.283 | 17.500 | |
| | | - | | | | | | | | | | | | | | | | | | | | | | | | | |
| TSW Sample ID | Customer Sample ID | Syrinx Code | Depth | Description | Germaniu m | Arsenic | Selenium | Rubidium | Strontium (ICP) | Strontium (AES) | Yttrium | Zirconium | Niobium | Molybdenu m | Ruthenium | Palladium | Silver | Cadmium | Indium | Tin | Antimony | Tellurium | Cesium | Barium | Lanthanum | Cerium | |
| mg/kg | Α | PS4 40% | 17-20 | NUA Blend | 0.165 | 2.530 | 0.308 | 0.118 | 50.453 | 60 | 5.500 | 1.247 | 0.100 | 0.344 | 0.007 | 0.020 | 0.007 | 0.023 | 0.029 | 0.271 | < 0.0001 | 0.009 | 0.011 | 13.097 | 13.450 | 33.650 | |
| | В | PS3 40% | 17-20 | NUA Blend | 0.150 | 2.145 | 0.198 | 0.100 | 40.703 | 47.95 | 4.875 | 1.072 | 0.357 | 0.327 | 0.010 | 0.014 | < 0.0001 | 0.024 | 0.024 | 0.206 | 0.012 | 0.010 | 0.008 | 15.097 | 11.300 | 28.800 | |
| | с | PS1(1) 25% | 17-20 | NUA Blend | 0.086 | 1.185 | 0.086 | 0.079 | 24.353 | 30.3 | 2.765 | 0.677 | 0.029 | 0.181 | 0.013 | 0.009 | < 0.0001 | 0.018 | 0.014 | 0.167 | < 0.0001 | 0.008 | 0.008 | 20.097 | 6.950 | 17.100 | |
| | D | AS1A(1) | 2-4 | Fines at surface | 0.329 | 6.795 | 0.967 | 2.008 | 393.453 | 443 | 14.100 | 3.937 | 0.345 | 1.370 | 0.027 | 0.045 | 0.008 | 0.061 | 0.076 | 0.667 | 0.049 | 0.011 | 0.151 | 10.747 | 27.050 | 72.500 | |
| | E | AS1A(2) | 17-20 | NUA Blend (high pisolites) | 0.158 | 3.600 | 0.357 | 0.578 | 155.953 | 177 | 6.300 | 2.317 | 0.134 | 0.645 | 0.023 | 0.024 | < 0.0001 | 0.027 | 0.037 | 0.402 | 0.016 | < 0.0001 | 0.040 | 6.997 | 12.600 | 33.100 | |
| | F | QC1 (PS4 40%) | 17-20 | NUA Blend | 0.155 | 2.590 | 0.239 | 0.109 | 49.953 | 57.5 | 5.300 | 1.252 | 0.084 | 0.370 | 0.021 | 0.016 | < 0.0001 | 0.022 | 0.029 | 0.239 | 0.007 | < 0.0001 | 0.010 | 11.597 | 13.900 | 34.150 | |
| | G | AS1C(1) | 17-20 | NUA Blend | 0.122 | 2.555 | 0.342 | 0.693 | 148.953 | 172.5 | 4.585 | 1.992 | 0.254 | 0.488 | 0.035 | 0.026 | < 0.0001 | 0.024 | 0.025 | 0.357 | 0.023 | 0.009 | 0.050 | 6.147 | 9.750 | 24.750 | |
| | н | AS1A(3) | 55-58 | NUA Blend (transitional to basal sands | 0.098 | 1.875 | 0.144 | 0.486 | 83.953 | 101 | 4.140 | 1.672 | 0.084 | 0.361 | 0.036 | 0.018 | < 0.0001 | 0.024 | 0.023 | 0.246 | < 0.0001 | < 0.0001 | 0.034 | 4.392 | 8.350 | 21.600 | |
| | I | AS1B | 17-20 | NUA Blend | 0.131 | 2.380 | 0.217 | 0.347 | 69.453 | 82 | 5.200 | 1.727 | 0.105 | 0.472 | 0.041 | 0.019 | < 0.0001 | 0.027 | 0.028 | 0.288 | 0.007 | < 0.0001 | 0.027 | 5.797 | 12.000 | 29.800 | |
| | J | PS2 25% | 17-20 | NUA Blend | 0.108 | 1.550 | 0.063 | 0.120 | 37.253 | 45.5 | 3.835 | 0.962 | 0.000 | 0.221 | 0.036 | 0.010 | < 0.0001 | 0.019 | 0.020 | 0.171 | 0.009 | < 0.0001 | 0.011 | 11.247 | 10.050 | 24.350 | |
| | к | PS1(2) 25% | 40-43 | Sands at Base | < 0.0001 | 0.116 | 0.000 | 0.026 | 1.378 | BDL | 0.259 | 0.178 | 0.000 | 0.008 | 0.028 | < 0.0001 | < 0.0001 | 0.007 | < 0.0001 | 0.039 | < 0.0001 | < 0.0001 | < 0.0001 | 0.421 | 0.293 | 0.680 | |
| | L | AS1C(3) | 70-73 | Pisolitic rich sands | 0.135 | 3.060 | 0.285 | 0.673 | 157.453 | 184 | 4.785 | 1.982 | 0.096 | 0.472 | 0.035 | 0.022 | < 0.0001 | 0.027 | 0.027 | 0.294 | 0.019 | 0.007 | 0.051 | 6.347 | 10.450 | 26.700 | |
| | м | AS1C(2) | 62-63 | Plastic Fines / Clays | 0.209 | 4.905 | 0.792 | 3.878 | 499.953 | 570 | 10.550 | 3.662 | 0.362 | 0.416 | 0.054 | 0.055 | 0.015 | 0.050 | 0.045 | 0.757 | 0.066 | 0.012 | 0.244 | 15.647 | 23.800 | 61.500 | |
| | DR | Replicate of D | 2-4 | Fines at surface | 0.278 | 7.245 | 0.792 | 2.108 | 392.453 | 435.5 | 13.600 | 4.582 | 0.217 | 2.185 | 0.068 | 0.053 | 0.012 | 0.079 | 0.077 | 0.817 | 0.028 | 0.014 | 0.151 | 13.447 | 25.200 | 68.000 | |
| TSW | | | | | | | | | | | . . | | | | | | | | | | | | | | | | |
| Sample ID | Sample ID | Syrinx Code | Depth | Description | ium | m | Europium | Samarium | m | Terbium | m | Holmium | Erbium | Thulium | Ytterbium | Lutetium | Hafnium | Tantalum | Tungsten | Platinum | Gold | Mercury | Thallium | Lead | Bismuth | Thorium | Uranium |
| mg/kg | Α | PS4 40% | 17-20 | NUA Blend | 4.415 | 13.550 | 0.206 | 2.710 | 2.675 | 0.267 | 1.415 | 0.220 | 0.620 | 0.084 | 0.510 | 0.075 | 0.040 | < 0.0001 | 0.000 | 0.001 | < 0.0001 | 0.000 | 0.017 | 5.653 | 0.013 | 23.700 | 1.020 |
| | В | PS3 40% | 17-20 | NUA Blend | 3.800 | 11.400 | 0.174 | 2.350 | 2.725 | 0.236 | 1.265 | 0.200 | 0.550 | 0.074 | 0.464 | 0.066 | 0.035 | < 0.0001 | 0.000 | 0.001 | < 0.0001 | 0.000 | 0.013 | 5.003 | 0.011 | 19.800 | 0.855 |
| | с | PS1(1) 25% | 17-20 | NUA Blend | 2.165 | 6.600 | 0.105 | 1.370 | 1.400 | 0.135 | 0.685 | 0.113 | 0.311 | 0.040 | 0.254 | 0.036 | 0.021 | < 0.0001 | 0.000 | < 0.0001 | < 0.0001 | 0.000 | 0.010 | 3.058 | 0.009 | 10.950 | 0.451 |
| | D | AS1A(1) | 2-4 | Fines at surface | 9.300 | 28.500 | 0.484 | 6.000 | 5.750 | 0.605 | 3.245 | 0.555 | 1.520 | 0.206 | 1.290 | 0.192 | 0.120 | 0.020 | 0.213 | 0.001 | < 0.0001 | 0.000 | 0.053 | 15.903 | 0.027 | 57.000 | 3.330 |
| | E | AS1A(2) | 17-20 | NUA Blend (high pisolites) | 4.275 | 13.200 | 0.223 | 2.745 | 2.575 | 0.281 | 1.455 | 0.245 | 0.675 | 0.092 | 0.575 | 0.085 | 0.069 | 0.007 | 0.000 | < 0.0001 | < 0.0001 | 0.000 | 0.026 | 7.903 | 0.013 | 27.450 | 1.525 |
| | F | QC1 (PS4 40%) | 17-20 | NUA Blend | 4.370 | 13.550 | 0.202 | 2.760 | 2.695 | 0.273 | 1.400 | 0.214 | 0.600 | 0.083 | 0.570 | 0.073 | 0.038 | < 0.0001 | 0.000 | < 0.0001 | < 0.0001 | 0.000 | 0.017 | 5.553 | 0.010 | 25.200 | 1.075 |
| | G | AS1C(1) | 17-20 | NUA Blend | 3.180 | 9.650 | 0.159 | 2.015 | 2.005 | 0.196 | 1.080 | 0.183 | 0.500 | 0.069 | 0.438 | 0.062 | 0.074 | < 0.0001 | 0.001 | < 0.0001 | < 0.0001 | 0.000 | 0.021 | 5.403 | 0.010 | 19.300 | 1.070 |
| | н | AS1A(3) | 55-58 | NUA Blend (transitional to <u>basal sa</u> nds | 2.790 | 8.500 | 0.139 | 1.795 | 1.740 | 0.178 | 0.950 | 0.160 | 0.451 | 0.060 | 0.382 | 0.056 | 0.045 | < 0.0001 | 0.000 | < 0.0001 | 0.006 | 0.000 | 0.020 | 5.053 | 0.017 | 17.100 | 0.980 |
| | I | AS1B | 17-20 | NUA Blend | 3.835 | 11.750 | 0.184 | 2.375 | 2.440 | 0.240 | 1.270 | 0.208 | 0.590 | 0.079 | 0.490 | 0.070 | 0.052 | < 0.0001 | 0.000 | < 0.0001 | < 0.0001 | 0.000 | 0.021 | 5.703 | 0.012 | 23.000 | 1.340 |
| | J | PS2 25% | 17-20 | NUA Blend | 3.075 | 9.600 | 0.135 | 1.940 | 1.930 | 0.186 | 0.965 | 0.151 | 0.403 | 0.053 | 0.335 | 0.048 | 0.029 | < 0.0001 | 0.000 | < 0.0001 | < 0.0001 | < 0.0001 | 0.014 | 4.873 | 0.012 | 15.350 | 0.675 |
| | к | PS1(2) 25% | 40-43 | Sands at Base | 0.079 | 0.244 | < 0.0001 | 0.053 | 0.060 | 0.008 | 0.045 | 0.009 | 0.028 | < 0.0001 | 0.025 | < 0.0001 | < 0.0001 | < 0.0001 | < 0.0001 | < 0.0001 | < 0.0001 | 0.000 | < 0.0001 | 0.170 | 0.008 | 0.416 | 0.028 |
| | L | AS1C(3) | 70-73 | Pisolitic rich sands | 3.455 | 10.500 | 0.165 | 2.160 | 2.115 | 0.217 | 1.150 | 0.188 | 0.525 | 0.072 | 0.439 | 0.067 | 0.052 | 0.007 | 0.000 | < 0.0001 | < 0.0001 | 0.000 | 0.019 | 5.603 | 0.013 | 20.650 | 1.125 |
| | м | AS1C(2) | 62-63 | Plastic Fines / Clays | 7.750 | 23.850 | 0.403 | 4.925 | 4.745 | 0.491 | 2.650 | 0.435 | 1.190 | 0.156 | 0.945 | 0.136 | 0.177 | 0.011 | 0.000 | 0.000 | 0.015 | 0.015 | 0.053 | 14.203 | 0.012 | 39.000 | 3.075 |
| | DR | Replicate of D | 2-4 | Fines at surface | 8.800 | 27.450 | 0.450 | 5.650 | 5.300 | 0.570 | 3.085 | 0.525 | 1.490 | 0.198 | 1.240 | 0.188 | 0.125 | 0.015 | 0.112 | < 0.0001 | 0.010 | 0.000 | 0.054 | 15.603 | 0.026 | 57.000 | 3.275 |

APPENDIX 4 SELECTED XRD SAMPLES FROM THE PASSIVE SYSTEM



Centre for Materials Research

Consultancy for:

Edward Oldmeadow Syrinx 12 Monger Street, Perth, WA 6000

Title: Quantitative Phase Abundance Analysis by XRD

Date: 9th January 2012

Authors: Dr Catherine Kealley, Dr Robert Hart and Prof Arie van Riessen Centre for Materials Research Curtin University GPO Box U1987, Perth, WA 6845 AUSTRALIA

Disclaimer

This report has been undertaken solely for Edward Oldmeadow, Syrinx. No responsibility is accepted to any third party who may come into possession of this report in whatever manner and who may use of rely on the whole or any part of this report. If any such third party attempts to rely on any information contained in this report such party should obtain independent advice in relation to such information.

Curtinnovation

Telephone +61 8 9266 7090 Or visit cmr.curtin.edu.au

Curtin University is a trademark of Curtin University of Technology. CRICOS Provider Code 00301J (WA)

Page 1/3

Centre for Materials Research

Figure 1



Results

 Add-012-0490 (1) - Guark Low Strong - Y, 141,13 % - d x by: 1, - WL: 1,5406 - Hexagonal - a 4,91427 - c 5,40580 - alpha 90,000 - beta 90,000 - gamma 120,000 - pamma 90,000 - pamm Selected 2-theta region showing phase identification in the "NUA ASIA 1-3" sample.

Table 1 Phase abundance

| | NUA ASIA 1-3 (weight %) | NUA ASIA 2-3 (weight %) |
|---------------------|----------------------------|----------------------------|
| Gypsum | 47(1) | 60(1) |
| Quartz | 38(1) | 26(1) |
| Magnetite | 4.7(8) | 4.0(8) |
| Amorphous Component | 10(1) | 10(1) |

Notes:

- 1. Values in parentheses are the estimated standard deviation of the least significant figure displayed to the left in the table.
- 2. The fluorite phase identified in Figure 1 is the internal standard. This has not been included in the phase abundance calculations.

The phases present include:

- ➢ Gypsum (Ca[SO₄][H₂O]₂) [PDF# 00-033-0311]
- Quartz (SiO₂) [PDF# 00-033-1161]
- Magnetite (Fe_{2.9}O₄) [PDF# 00-086-1334]
- The amorphous content could include scattering from any non-crystalline material, as well as the differences between the experimental and the calculated data.

Summary

A number of crystalline phases have been identified in the sample, and the abundance of each phase listed in Table 1. The gypsum phase has a large amount of preferred orientation. There are a few small peaks that have not been assigned to a phase – if elemental composition (eg. XRF or EDS) is undertaken, it may be possible to identify the phase(s) associated with these peaks.

APPENDIX 5 REVISED DESIGN CRITERIA

Water Quality

- Maintain, and where possible improve, water quality within Ellen Brook. Investigation into site specific trigger values for the biological and ecological receptors of Ellen Brook is required.
- NUA blends or alternative amendments shall be utilised to provide a <u>majority</u> of TP reductions.
- Wetlands shall be located at the terminal end of the any filtration system to polish flows, primarily for treatment of TN, prior to discharge.
- Disturbance to existing site soils shall be minimised. Sediment and erosion controls shall be implemented.
- The end-of-catchment treatment system shall form part of a suite of management actions (treatment train) implemented within the Ellen Brook catchment. Other management actions may include: riparian revegetation, perennial pastures, fertiliser efficiency, landuse change controls, fertiliser action plans and soil amendments.

Water Quantity

- Treatment systems shall not permanently abstract water from Ellen Brook.
 Systems such as aquifer recharge and/or land disposal shall not be utilised for nutrient reductions.
- Hydraulic capacity and conveyance of the existing site shall be maintained to a level that protects existing infrastructure and land uses (i.e. residential, agricultural).

Ecological Protection

- Stream morphology shall be maintained to existing conditions to protect environmental flows and existing habitat.
- Riparian and wetland revegetation works shall be integrated with existing significant vegetation. Revegetation works shall be implemented throughout the site to intercept surface runoff and perched groundwater flows, control potential weed spread and enhance habitat and biodiversity opportunities.

Infrastructure Protection

syrinx environmental pl

- Access to the treatment system shall preferably be via West Swan Road (Site 1) and Millhouse Road (Site 2).
- Hydraulic capacity and velocity shall be maintained to ensure protection of West Swan Road, Millhouse Road and Cruse Road.

Cultural Protection and Enhancement

- Aboriginal heritage site identification and consultation shall take place following conceptual design works.
- Access to the treatment system via roads adjacent to private properties shall be limited where possible.
- Revegetation works shall maintain existing view corridors from private properties.
- Protection of existing infrastructure and dwellings from potential fire risks.
- Community engagement and involvement prior and post construction.

System Maintenance and Operation

- Configuration of the treatment system shall allow for easy access, maintenance and, when necessary, replacement.
- Gravity fed systems shall be optimised to reduce operation costs.

<u>Monitoring</u>

 Monitoring sites shall be located upstream and downstream of the treatment system. Monitoring programs shall be developed consistent with current standards.